Manual Intelligent Weather Sensors

WS800-UMB

WS700-UMB

WS600-UMB / WS601-UMB

WS501-UMB / WS502-UMB / WS503-UMB / WS504-UMB

WS510-UMB

WS500-UMB

WS400-UMB / WS401-UMB

WS301-UMB / WS302-UMB / WS303-UMB / WS304-UMB

WS310-UMB

WS300-UMB

WS200-UMB

WS100-UMB







48.7230-WSX-E Document version V48 (12/2020)

Contents

1	Pleas	se Read Before Use	6
	1.1	Symbols Used	6
	1.2	Safety Instructions	6
	1.3	Designated Use	6
	1.4	Incorrect Use	6
	1.5	Warranty	7
	1.6	Brand Names	7
2	Scop	pe of Delivery	8
3	Orde	er Numbers	9
	3.1	Accessories	11
	3.2	Spare Parts	11
	3.3	Additional Documents and Software	11
4	Equi	pment Description	12
	4.1	Air Temperature and Humidity	
	4.2	Air Pressure	
	4.3	Precipitation	13
	4.4	Wet Bulb Temperature	
	4.5	Specific Enthalpy	
	4.6	Air Density	
	4.7	Wind	
	4.8	Compass	
	4.9	Heating	
	4.10	Global Radiation	
		Lightning Sensor	
		External Temperature Sensor	
		External Rain Gauge	
		(WS100-UMB only:) Impulse Output for Rain Gauge Simulation	
		Sensor Technology (example: WS600-UMB)	
5	Gene	eration of Measurements	16
	5.1	Current Measurement (act)	
	5.2	Minimum and Maximum Values (min and max)	
	5.3	Average Value (avg)	16
	5.4	Vectorial Average Value (vct)	
6		surement Output	
•	6.1	Air and Dewpoint Temperature	
	6.2	Wind Chill Temperature	
	6.3	Humidity	
	6.4	Air Pressure	
	6.5	Wet Bulb Temperature	
	6.6	Specific Enthalpy	
	6.7	Air Density	
	6.8	Wind Speed.	
	6.9	Wind Direction	
		Wind Measurement Quality	
		Compass	
		Precipitation Quantity - Absolute	
		Precipitation Quantity - Differential	
		Precipitation Intensity	
		Precipitation Type	
		Heating Temperature	
		Global Radiation	
		Lightning Sensor	
	-	• •	-



	6.19 Service Messages	25
	6.20 Drop Diameter Distribution (WS100 only)	25
7	Installation	26
	7.1 Fastening	
	7.2 North Alignment	27
	7.3 Selecting the Installation Location	28
8	Connections	30
•	8.1 Supply Voltage	
	8.2 RS485 Interface	
	8.3 Connection to ISOCON-UMB (8160.UISO)	
	8.4 Use of Surge Protection (8379.USP)	
	8.5 Connection of External Temperature and Precipitation Sensors	
	8.6 (WS100-UMB only:) Connection of Impulse Output for Rain Gauge Simulation	
9	Commissioning	
	-	
10	Configuration and Test	
	10.1 Factory Settings	
	10.2 Configuration with the UMB-Config-Tool	
	10.3 Function Test with UMB-ConfigTool.NET	
	10.4 Operating Modes of the Smart Weather Sensor	
	10.5 Operating Modes for Equipment Heating	
11	Firmware Update	49
12	Maintenance	
	12.1 Maintenance of the Rain Gauge	50
13	Technical Data	51
	13.1 Measuring Range / Accuracy	53
	13.2 Drawings	56
14	EC Certificate of Conformity	68
	14.1 FCC Compliance Statement (US)	
	14.2 IC Compliance Statement (CA)	
	14.3 WS 100 SRRC conformity (CN)	
15	Fault Description	73
	Disposal	
10	16.1 Within the EC	
	16.2 Outside the EC	
17	Repair / Corrective Maintenance	
	17.1 Technical Support	
18	External Sensor	
	18.1 External Temperature and Precipitation Sensors	75
19	Appendix	77
	19.1 Channel List Summary	77
	19.2 Channel List Summary per TLS2002 FG3	
	19.3 Communication in Binary Protocol	
	19.4 Communication in ASCII Protocol	84
	19.5 Communication in Terminal Mode	87
	19.6 Communication in SDI-12 Mode	
	19.7 Communication in Modbus Mode	
	19.8 Communication: XDR Protocol	
	19.9 (WS100-UMB only) Communication: UMB-ASCII 2.0 Protokoll	160
20	List of Figures	167
21	Index	168





1 Please Read Before Use

This manual is valid for devices of the Lufft WS family with device version 200 or higher(2015), WS100-UMB with device version 010 (2017) or higher. Some functions or features specified in this manual may not be available or may not be valid with older device versions. The device version is indicated as the last number of the serial number, e.g.: the device with SN: 063.1010.0701.021 has the device version 21.

If you are using an older device of the WS family, please refer to the manual for device versions up to 49 or for versions prior to 30 (www.lufft.com/en/support/downloads).

1.1 Symbols Used



Important information concerning potential hazards to the user



Important information concerning the correct operation of the equipment

1.2 Safety Instructions



- Installation and commissioning must be carried out by suitably qualified specialist personnel only.
- Never take measurements on or touch live electrical parts.
- Pay attention to the technical data and storage and operating conditions.

1.3 Designated Use

- The equipment must only be operated within the range of the specified technical data.
- The equipment must only be used under the conditions and for the purposes for which it was designed.



- The safety and operation of the equipment can no longer be guaranteed if it is modified or adapted.
- Devices with precipitation radar (WS100-UMB, WS400-UMB, WS600-UMB, WS700-UMB, WS800-UMB) subject to approval regulations which differ between countries. The radar modules have been certified for use in EU, USA and Canada. The individual approvals of each device type are listed in chapter 3 "Order Numbers".

If the user intends operation of the device in other jurisdictions the user must clarify and ensure compliance with any additional regulatory requirements and must obtain any required approvals and/ or certificates at its own risk and cost. Lufft does not warrant that these approvals or certificates will be issued. The user will hold Lufft harmless against any third party claims and any enforcement activity by authorities if the the device is operated outside of the jurisdictions listed above.

Devices with precipitation radar must be used outside and the radar dome must face vertical to the sky.



1.4 Incorrect Use

If the equipment is installed incorrectly

- It may not function.
- It may be permanently damaged.
- Danger of injury may exist if the equipment is allowed to fall.



If the equipment is not connected correctly

- It may not function.
- It may be permanently damaged.

The possibility of an electrical shock may exist.



1.5 Warranty

The Warranty period is 12 months from the date of delivery. The warranty is forfeited if the designated use is violated.

1.6 Brand Names

All brand names referred to are subject without limitation to the valid trademark and ownership rights of the respective owner.



Scope of Delivery

Equipment













WS200-UMB

WS300-UMB

WS400-UMB

WS500-UMB

WS600-UMB











WS301-UMB

WS501-UMB

WS401-UMB

WS601-UMB

WS700-UMB WS800-UMB





WS310-UMB

WS510-UMB

Connection cable 10m









3 Order Numbers

Note: For devices with precipitation radar, please observe chapter 1.3!

WS100-UMB 8367.U03 (Europe (EN))

Precipitation Radar
 8367.U04 (USA, Canada (FCC))

• Impulse Output for Raingauge Simulation

WS200-UMB 8371.U01

- Wind Direction
- Wind Speed
- Compass

WS300-UMB 8372.U01

- Air Temperature
- Relative Humidity
- Air Pressure

WS301-UMB	8374.U01
WS302-UMB	8374.U10
WS303-UMB	8374.U11
WS304-UMB	8374.U12
WS310-UMB	8374.U13

- Air Temperature
- Relative Humidity
- Air Pressure
- Global Radiation

WS400-UMB 8369.U01 (Europe)

Precipitation Radar
 8369.U01-NA (USA, Canada)

Air Temperature 8369.U02 (UK)

- Relative Humidity
- Air Pressure

WS401-UMB 8377.U01

- Precipitation Rain Gauge
- Air Temperature
- Relative Humidity
- Air Pressure

WS500-UMB 8373.U01

- Wind Direction
- Wind Speed
- Air Temperature
- Relative Humidity
- Air Pressure
- Compass



8370.U01 (Europe)

8370.U02 (UK)

8370.U01-NA (USA, Canada)

WS501-UMB 8375.U01 WS502-UMB 8375.U10 WS503-UMB 8375.U11 WS504-UMB 8375.U12 WS510-UMB 8375.U13

- Wind Direction
- Wind Speed
- Air Temperature
- Relative Humidity
- Air Pressure
- Compass
- Global Radiation

WS600-UMB

Precipitation Radar

. . co.p.tation rtada

Wind Direction

- Wind Speed
- Air Temperature
- Relative Humidity
- Air Pressure
- Compass

WS601-UMB 8376.U01

- Precipitation Rain Gauge
- Wind Direction
- Wind Speed
- Air Temperature
- Relative Humidity
- Air Pressure
- Compass

WS700-UMB 8380.U01 (Europe)

- Precipitation Radar
- Wind Direction
- Wind Speed
- Air Temperature
- Relative Humidity
- Air Pressure
- Compass
- Global Radiation

8381.U01 (Europe)

8381.U01-NA (USA, Canada)

8380.U01-NA (USA, Canada)

WS800-UMB

- Precipitation Radar
- Wind Direction
- Wind Speed
- Air Temperature
- Relative Humidity
- Air Pressure
- Compass
- Global Radiation
- Lightning Sensor

3.1 Accessories

Power supply unit 24V/100VA 8366.USV1 ISOCON-UMB 8160.UISO Surge protection 8379.USP External Rain Gauge WTB100 8353.10

External Temperature Sensors

Temperature Sensor WT1 8160.WT1
Passive Road Surface Temperature Sensor WST1 8160.WST1

3.2 Spare Parts

Connection cable 10m On enquiry

3.3 Additional Documents and Software

You can download the following documents and software via the Internet at www.lufft.com.

Operating Manual • This document

UMB-Config-Tool • Windows® software for testing, firmware updates and

configuration of UMB devices

UMB Protocol • Communications protocol for UMB devices

Firmware • The current device firmware



4 Equipment Description

The WS family is a range of low cost smart combination of weather sensors for the acquisition of a variety of measurement variables, as used for example for environmental data logging in road traffic management systems. Depending on the model, each device has a different combination of sensors for the various measurement variables.

	WS100-UMB	WS200-UMB	WS300-UMB	WS301-UMB**	WS400-UMB	WS401-UMB	WS500-UMB	WS501-UMB***	WS600-UMB	WS601-UMB	WS700-UMB	WS800-UMB
Air temperature			•	•	•	•	•	•	•	•	•	•
Humidity			0	•	•	•	0	0	•	•	•	•
Air pressure			•	•	•	•	•	•	•	•	•	•
Precipitation	•				•	•*			•	•*	•	•
Wind direction		•					•	•	•	•	•	•
Wind speed		0					•	0	•	•	•	•
Compass		•					•	•	•	•	•	•
Global Radiation				•				0			•	•
Lightning Sensor												•
Temperature (ext)		0	0	•	•	•	0	0	•	•	•	•
Rain Gauge (ext)		•	•	•			•	•				
Power Save 2		•	•	•		0	•	•		0		

^{*)} WS401-UMB and WS601-UMB use a rain gauge for precipitation measurement

Sensors marked (ext) in the table are additional accessories and not included with the device. The table shows which external sensors can be connected to the different models.

Note: The external temperature sensor and the external rain gauge use the same input, so only one of them can be connected simultaneously.

Attention: Please note that, due to the approval of the radar sensor used, there are different country options on equipment which includes precipitation measurement by radar technology.

The equipment is connected by way of an 8 pole screw connector and associated connection cable (length 10m).

The measured values are requested over the RS485 interface in accordance with UMB protocol.

During commissioning, configuration and measurement polling takes place using the UMB-Config-Tool (Windows® PC software) or the ConfigTool.NET (for WS100-UMB)

4.1 Air Temperature and Humidity

Temperature is measured by way of a highly accurate NTC-resistor while humidity is measured using a capacitive humidity sensor. In order to keep the effects of external influences (e.g. solar radiation) as low as possible, these sensors are located in a ventilated housing with radiation protection. In contrast to conventional non-ventilated sensors, this allows significantly more accurate measurement during high radiation conditions.

WS100-UMB is not intended for air temperature measurement, so it is not equipped with a radiation shield. Air temperature values with reduced accuracy are available as service channels for additional information.

Additional variables such as dewpoint, absolute humidity and mixing ratio are calculated from air temperature and relative humidity, taking account of air pressure.





^{**)} is also valid for WS302-UMB, WS303-UMB, WS304-UMB, WS310-UMB

^{***)} is also valid for WS502-UMB, WS503-UMB, WS504-UMB, WS510-UMB

4.2 Air Pressure

Absolute air pressure is measured by way of a built-in sensor (MEMS). The relative air pressure referenced to sea level is calculated using the barometric formula with the aid of the local altitude, which is user-configurable on the equipment.

4.3 Precipitation

Tried and tested radar technology from the R2S-UMB sensor is used to measure precipitation. The precipitation sensor works with a 24GHz Doppler radar, which measures the drop speed and calculates precipitation quantity and type by correlating drop size and speed.



Note: Devices with precipitation radar are subject to approval regulations which differ between countries. Please make sure to observe chapter 1.3!

WS401-UMB and WS601-UMB are using an unheated rain gauge for precipitation measurement. This version can be recommended for low power application etc.

4.4 Wet Bulb Temperature

The wet bulb temperature is the temperature of a moist or icy surface exposed to air flow.

4.5 Specific Enthalpy

Parameter of state of the humid air, composed of the specific enthalpies (heat capacity) of the components of the mixture and related to the mass fraction of the dry air (at 0°C).

4.6 Air Density

The air density indicates how much mass in a given volume of air is contained and it is calculated from the measured values of air temperature, humidity and air pressure.

4.7 Wind

The wind meter uses 4 ultrasonic sensors which take cyclical measurements in all directions. The resulting wind speed and direction are calculated from the measured run-time sound differential. The sensor delivers a quality output signal indicating how many good readings were taken during the measurement interval.

4.8 Compass

The integrated electronic compass can be used to check the north – south adjustment of the sensor housing for wind direction measurement. It is also used to calculate the compass corrected wind direction.

4.9 Heating

The precipitation sensor and wind meter are heated for operation in winter.

4.10 Global Radiation

The global radiation is measured by a pyranometer mounted in the top cover of the Smart Weather Sensor.

4.11 Lightning Sensor

WS800-UMB includes lightning detection by an integrated sensor analysing the radio wave emission of lightnings. It delivers a count of recognized lightnings.

The sensor analyses spectrum and wave form of the received signal to suppress the detection of man made electrical discharges. Nevertheless false detections can not be totally excluded specially in an environment with high power electrical equipment.

4.12 External Temperature Sensor

Optionally all models may be equipped with an external NTC temperature sensor for the acquisition from additional measurement points. The type of NTC is the same as used for the internal air temperature sensor.

External temperature sensor and external rain gauge can **not** be connected at the same time.



4.13 External Rain Gauge

Models without integrated precipitation acquisition can be equipped with an external rain gauge.

External rain gauge and external temperature sensor can **not** be connected at the same time.

4.14 (WS100-UMB only:) Impulse Output for Rain Gauge Simulation

WS100-UMB provides a digital impulse output for simulation of a rain gauge. Depending on configuration settings the output is pulsed once for each 1.0mm, 0.5mm, 0.2mm, 0.1mm or **0.01mm** (default) of precipitation.



If the WS100-UMB is configured for impulse output, the serial interface is **not** available for communication in UMB or other serial protocols.



4.15 Sensor Technology (example: WS600-UMB)




Figure 1: Sensor Technology

5 Generation of Measurements

5.1 Current Measurement (act)

In accordance with the specified sampling rate, the value of the last measurement is transmitted when the current measurement value is requested. Each measurement is stored in a circular buffer for the subsequent calculation of minimum, maximum and average values.

5.2 Minimum and Maximum Values (min and max)

When requesting the minimum and maximum values, the corresponding value is calculated - via the circular buffer at the interval (1 – 10 minutes) specified in the configuration - and transmitted.



Note: In the case of wind direction, the minimum / maximum value indicates the direction at which the minimum / maximum wind speed was measured.

5.3 Average Value (avg)

When requesting the average value, this is calculated - via the circular buffer at the interval (1 – 10 minutes) specified in the configuration - and transmitted. In this way moving averages can also be calculated.

For some values the standard deviation is calculated for the same interval. The calculation of standard deviation will only be activated after the related UMB channel has been requested for the first time.

5.4 Vectorial Average Value (vct)

In the specific case of wind measurement, measurements are calculated vectorially. To this end, the average values of the vectors are generated internally. This calculation is performed with the same configured interval time as that for the minimum, maximum and average values. Hence the value (wind speed) and angle (wind direction) of the vector are calculated.



Note: On delivery, the interval for the calculation of minimum, maximum and average values is set at 10 minutes. If necessary, this can be adjusted to the particular requirements (1 - 10 minutes) with the aid of the UMB-Config-Tool (see page 34).



Note: The evaluation of the standard deviation values is deactivated after power on of the device. The function will be activated with the first request to any of the standard deviation channels.

To get standard deviation values of the first integration period after power on a dummy request to any one of the standard deviation channels should be inserted.



6 Measurement Output

Measurements are transmitted in accordance with UMB binary protocol (Factory Settings). You can find an example of a measurement request in different protocols and a complete summary of the list of channels in the Appendix.

6.1 Air and Dewpoint Temperature

Sampling rate 1 minute

Generation of average value 1 – 10 minutes

Units °C; °F

Request channels:

	UMB C	hannel			Measuring Range			
act	min	max	avg	Measurement Variable (float32)	min	max	unit	
100	120	140	160	Air temperature	-50.0	60.0	°C	
105	125	145	165	Air temperature	-58.0	140.0	°F	
110	130	150	170	Dewpoint temperature	-50.0	60.0	°C	
115	135	155	175	Dewpoint temperature	-58.0	140.0	°F	
101				External Temperature Sensor	-40.0	80.0	°C	
106				External Temperature Sensor	-40.0	176.0	°F	

6.2 Wind Chill Temperature

Sampling rate 1 minute, computed on base of the average temperature

and average wind speed

Units °C; °F

Request channels:

	UMB C	hannel			Mea	suring R	ange
act	min	max	avg	Measurement Variable (float32)	min max		unit
111				Wind chill temperature	-60.0	70.0	°C
116				Wind chill temperature	-76.0	158.0	°F

6.3 Humidity

Sampling rate 1 minute
Generation of average value 1 - 10 minutes
Units %RH; g/m³; g/kg

Request channels:

	UMB C	hannel			Mea	suring R	ange
act	min	max	avg	Measurement Variable (float32)	min	max	unit
200	220	240	260	Relative humidity	0.0	100.0	%
205	225	245	265	Absolute humidity	0.0	1000.0	g/m³
210	230	250	270	Mixing ratio	0.0	1000.0	g/kg

6.4 Air Pressure

Sampling rate 1 minute

Generation of average value 1 – 10 minutes

Unit hPa

Request channels:

	UMB C	hannel			Mea	suring R	ange
act	min	max	avg	Measurement Variable (float32) min max		max	unit
300	320	340	360	Absolute air pressure	300	1200	hPa
305	325	345	365	Relative air pressure	300	1200	hPa



Note: For the correct calculation of relative air pressure, the altitude of the sensor must be entered in the device configuration (see Figure 11 on page 37). The factory setting for altitude is 0m; in this way both measurement variables deliver the same values.



6.5 Wet Bulb Temperature

Sampling rate 1 minute Units °C; °F

Request channels:

	UMB C	hannel		Mea	ange	
act			Measurement Variable (float32)	asurement Variable (float32) min max		
114			Wet Bulb Temperature	-50.0	60.0	°C
119			Wet Bulb Temperature	-58.0	140.0	°F

6.6 Specific Enthalpy

Sampling rate 1 minute Unit kJ/kg

Request channels:

	UMB C	hannel		Measuring Range		
act			Measurement Variable (float32)	min	max	unit
215			Specific Enthalpy	-100.0	1000.0	kJ/kg

6.7 Air Density

Sampling rate 1 minute Unit kg/m³

Request channels:

		UMB C	hannel		Mea	suring R	ange
	act			Measurement Variable (float32)	min	max	unit
ĺ	310			Air Density	0.0	3.0	kg/m³



6.8 Wind Speed

Sampling rate 1 sec / 10 sec (internal sampling frequency 15Hz)

Generation of average value 1 – 10 minutes

Generation of max/min value 1 – 10 minutes based on the internal 1 sec

measurements

Units m/s; km/h; mph; kts

Response threshold 0.3 m/s

Request channels:

	UI	MB Chan	nel			Me	asuring	Range
act	min	max	avg	vct	Measurement Variable (float32)	min	max	unit
400	420	440	460	480	Wind Speed	0	75.0	m/s
405	425	445	465	485	Wind Speed	0	270.0	km/h
410	430	450	470	490	Wind Speed	0	167.8	mph
415	435	455	475	495	Wind Speed	0	145.8	kts
401					Wind Speed Fast	0	75.0	m/s
406					Wind Speed Fast	0	270.0	km/h
411					Wind Speed Fast	0	167.8	mph
416					Wind Speed Fast	0	145.8	kts
403					Wind Speed Standard Deviation *	0	75.0	m/s
413					Wind Speed Standard Deviation *	0	167.8	mph



Note: The second measurements are averaged over 10 seconds for the output of the current (act) measurement. The 'fast' channels deliver every second a value.

6.9 Wind Direction

Sampling rate 1 sec / 10 sec (internal sampling frequency 15Hz)

Generation of average value 1 – 10 minutes

Generation of max/min value 1-10 minutes based on the internal 1 sec

measurements

Unit °

Response threshold 0.3 m/s

Request channels:

	UMB Channel				Mea	asuring R	ange	
act	min	max	avg	vct	Measurement Variable (float32)	min	max	unit
500	520	540		580	Wind Direction	0	359.9	٥
501					Wind Direction Fast	0	359.9	0
502					Wind Direction Corrected	0	359.9	0
503					Wind Dir. Standard Deviation *	0	359.0	0



Note: The second measurements are averaged over 10 seconds for the output of the current (act) measurement. The 'fast' channels deliver every second a value.

The minimum / maximum wind direction indicates the direction at which the minimum / maximum wind speed was measured.

The corrected wind direction is calculated from the wind direction measured by the wind sensor and the heading measured by the compass.

Optionally the compass correction of the wind direction can be activated for all wind direction values. (Settings by UMB Config Tool)



Note: The correction function is designed for correction of the wind direction of a statically mounted sensor. If the alignment of the sensor changes during the measurement (i.e. if the sensor is mounted on a rotating platform or similar) the correction function will not in all cases work properly, especially not for the vector average.

It is of course possible to use the correction function for mobile measurement units, where the alignment is changed between measurement periods.



*) **Note:** The evaluation of the standard deviation values will be activated after the first request of a standard deviation channel. Please see p. 13.



6.10 Wind Measurement Quality

Sampling rate 10 seconds

Unit %

Request channels:

UMB Channel				Mea	suring R	ange		
act	min	max	avg	vct	Measurement Variable (float32)	min	max	unit
805					Wind Value Quality	0	100	%
806					Wind Value Quality (fast)	0	100	%



Note: The value is updated every 10 seconds and transmits the minimum wind measurement quality for the last 10 seconds interval.

The "fast" value indicates the measurement quality of the one second measurement value.

This value allows the user to assess how well the measurement system is functioning in the respective ambient conditions. In normal circumstances the value is 90 - 100%. Values up to 50% do not represent a general problem. If the value falls towards zero the measuring system is reaching its limits.

If during critical ambient conditions the system is no longer able to conduct reliable measurements, error value 55h (85d) is transmitted (device unable to execute valid measurement due to ambient conditions).

6.11 Compass

(only device version 030 or higher) Sampling rate: 5 min

Unit °

Request channels:

	U	MB Chan	nel			Mea	suring R	ange
act	min	max	avg	vct	Measurement Variable (float)	min	max	unit
510					Compass Heading	0	359	0



Note: Reliable operation of the compass is only possible, if the sensor has been mounted according to the instructions in this manual, i.e. on top of the pole. Should the sensor be mounted on a traverse, the distribution of iron masses will be different from the situation during factory calibration. This may lead to additional deviation of the bearing. This also applies to lightning rods mounted at the pole top!

Dependent on the location of the installation the local declination of the earth magnetic field has to be considered. The declination value is entered using the UMB-Config-Tool (see page 37). The declination for the installation location can be found in the Internet, e.g. at

http://www-app3.gfz-potsdam.de/Declinationcalc/declinationcalc.html

http://www.ngdc.noaa.gov/geomagmodels/Declination.jsp



Note: When the fan is not rotating the compass measurement value will be influenced by the magnetic field of the fan. Normally the compass measurement will be performed with the fan rotating to compensate this influence. If, starting from device version 037, the fan will not be switched on in case of low operating voltage (less than 12V) deviations of the compass measurement value must be accepted.



Note: When the device is operated in Power Saving Mode 1 or 2 the compass measurement is performed only once after power on. Later changes of the orientation of the device will not be recognized.



6.12 Precipitation Quantity - Absolute

Sampling rate Event-dependent on reaching the response threshold

Response threshold 0.01mm (Radar)

Response threshold 0.2 / 0.5 mm (Rain Gauge)

Units I/m²; mm; in; mil

Request channels:

UMB Channel	Measurement Variable (float32)	Unit
600	Precipitation Quantity - Absolute	l/m²
620	Precipitation Quantity - Absolute	mm
640	Precipitation Quantity - Absolute	in
660	Precipitation Quantity - Absolute	mil



Note: This measurement indicates the accumulated precipitation quantity since the last device reboot. The measurement is retained for the duration of a short power failure. To reset this value, use the corresponding function in the UMB-Config-Tool (see page 40) or disconnect the device from the power supply. The necessary disconnected time is device dependent from a few seconds up to 1 h.

6.13 Precipitation Quantity - Differential

Sampling rate Event-dependent on reaching the response threshold

Response threshold 0.01mm (Radar)

Response threshold 0.2 / 0.5 mm (Rain Gauge)

Units I/m²; mm; in; mil

Request channels:

UMB Chanel	Measurement Variable (float32)	Unit
605	Precipitation Quantity - Differential	l/m²
625	Precipitation Quantity - Differential	mm
645	Precipitation Quantity - Differential	in
665	Precipitation Quantity - Differential	mil



Note: Each request from a differential channel sets the accumulated quantity back to zero. If the response from the device is lost due to a transmission error (e.g. poor GPRS connection), the quantity accumulated to date is also lost. The quantity accumulated to date is also reset each time the equipment is rebooted.

6.14 Precipitation Intensity

Sampling rate 1 minute
Response threshold 0.01 mm/h

Units I/m²/h; mm/h; in/h; mil/h

Request channels:

UMB Channel	Measurement Variable (float32)	Range	Unit
800	Precipitation Intensity	0 200.00	l/m²/h
820	Precipitation Intensity	0 200.00	mm/h
825	Precipitation Intensity (WS100 only)	0 3.3333	mm/min
840	Precipitation Intensity	0 7.8740	in/h
845	Precipitation Intensity (WS100 only)	0 0.13123	in/min
860	Precipitation Intensity	0 7874.0	mil/h



Note: The lower resolution of the rain gauge would lead to high fluctuation of the intensity values, so the rain gauge versions (WS401-UMB and WS601-UMB), as well as the external rain gauge, use the accumulated precipitation of the last 60 minutes prior to the current measurement for intensity calculation.



6.15 Precipitation Type

Sampling rate Event-dependent on reaching the response threshold

Response threshold 0.002mm (Radar)

Response threshold 0.2 / 0.5 mm (Rain Gauge)

Follow-up time 2 minutes

Request channels:

UMB Channel	Measurement Variable (uint8)	Coding
700	Precipitation Type	0 = No precipitation 60 = Liquid precipitation, e.g. rain 70 = Solid precipitation, e.g. snow 40 = unspecified precipitation (WS401-UMB, WS601-UMB, external rain gauge) WS100-UMB only: 67 = freezing rain 69 = sleet 90 = hail



Note: A detected precipitation type remains valid for 2 minutes after the end of the precipitation event. In order to record precipitation types which only occur for a short period (e.g. short-term rain), the request interval should be 1 minute or shorter.

Ice, hail and sleet are transmitted as rain (60) by devices other than WS100-UMB.

The versions WS401-UMB and WS601-UMB as well as the external rain gauge do not include detection of precipitation type, so in this case only type 40 (unspecified precipitation) is indicated. Due to the function of the rain gauge only liquid or molten precipitation can be recognized.




6.15.1 WMO Codes (WS100 only)

Sampling rate 1 minute (10min floating average)

Response threshold 0.1mm/h

Request channels:

UMB Chann el	Measureme nt Variable (uint8)		Coding	
		No	Description	Limits
		00	No significant weather	
		51	drizzle, not freezing, slight	< 0,1mm/h
		52	drizzle, not freezing, moderate	>= 0,1mmh < 0 ,5mm
		53	drizzle, not freezing, heavy	>= 0,5mm
	14/140	57	drizzle + rain, slight	< 2,5mm/h
	WMO Synop Code	58	drizzle + rain, moderate/heavy	>= 2,5mm/h
	4680 wawa	61	rain not freezing, slight	< 2,5mm/h
780	(Present Weather,	62	rain, not freezing, moderate	>= 2,5mm/h < 10mm
	automated	63	rain, not freezing, heavy	>= 10mm/h
	station)	67	rain/drizzle + snow, slight	< 2,5mm/h
		68	rain/drizzle + snow, mod./heavy	>= 2,5mm/h
		71	snow, slight	< 1mm/h
		72	snow, moderate	>= 1mm/h < 4,0mm/
		73	snow, heavy	> 4,0mm/h
		89	hail	,-
	not avalailable)	No	Description	Limits
		00	no cloud development observed	Lillits
		51	drizzle, not freezing, continuous, slight	< 0,1mm/h
		53	drizzle, not freezing, continuous, moderate	>= 0,1mmh < 0 ,5mm
		55	drizzle, not freezing, continuous, heavy	>= 0,5mm
		58	drizzle and rain, slight	< 2,5mm/h
	WMO Synop Code	-	rain, not freezing, continous, slight,	< 2,5mm/h
	4677 ww	63	rain, not freezing, continous, moderate	>= 2,5mm/h < 10mm/
785	(Present	65	rain, not freezing, continuous, heavy	>= 10mm/h
	weather, manned	68	rain/drizzle + snow, slight	< 2,5mm/h
	station)	69	rain/drizzle + snow, moderate/heavy	>= 2,5mm/h
		71	continuous fall of snow, slight	< 1mm/h
		73	continuous fall of snow, moderate	>= 1mm/h < 4,0mm/
		75	continuous fall of snow, heavy	> 4,0mm/h
		89	hail shower, slight	< 2,5mm/h
		90	hail shower, moderate/heavy	>= 2,5mm/h
786	WMO Synop Code 4677WW (currently not	· ·	Same coding as channel	





6.16 Heating Temperature

Sampling Rate 1 Minute Units °C; °F

Request Channels:

	UMB Channel				Measuring Range		
act	act min max avg		avg	Measurement Variable (float32)	min	max	Unit
112				Heating Temperature Wind Sensor	-50.0	150.0	°C
113				Heating Temperature Precipitation Sensor	-50.0	150.0	°C
117				Heating Temperature Wind Sensor	-58.0	302.0	°F
118				Heating Temperature Precipitation Sensor	-58.0	302.0	°F

6.17 Global Radiation

Sampling Rate 10 seconds Generation of average values 1 - 10 minutes *)

Unit W/m²

Request Channels:

	UMB Channel				М	easuring R	ange
act	min	max	avg	Measurement Variable (float32)	min max uni		unit
900	920	940	960	Global Radiation	0.0	2000.0 *)	W/m²

^{*)} Until device version .49 / .212 / Firmware v5.6: 1400.0 W/m²



*) Note: The average, maximum and minimum values are evaluated from the 1 minute averages of the 10 second spot value.

When operated in Power Saving Mode 1 (see page 45) the WS700-UMB will measure the global radiation only once per minute.

6.18 Lightning Sensor

6.18.1 Lightning Events

Sampling Rate 1 minute

Sum 1 – 30 minutes

Unit Events Request Channels:

	UMB Channel			Mea	suring R	ange
act	sum		Measurement Variable (uint16)	min	max	unit
617			Lightning Events	0	255	-
	677		Lightning Events (Interval)	0	7650	-



6.19 Service Messages

Service channels are available for the surveillance of the operation of the Smart Weather Sensor.

Request Channels:

UMB Channel		UMB Channel				Measuring Range		
act	min	max	avg	Measurement Variable (float32)	min	max	unit	
10000				Supply Voltage V	0.0	50.0	V	
11000			Rain Drop Volume μ	0.0	500.0	μl		

WS100-UMB only: Air temperature (without radiation shield)

Sampling rate 1 minute

Generation of average value 1 – 10 minutes

Units °C; °F

Request channels:

UMB Channel					Measuring Range		
act	min	max	avg	Measurement Variable (float32)	min	max	unit
4100	4120	4140	4160	Air temperature	-50.0	60.0	°C
4105	4125	4145	4165	Air temperature	-58.0	140.0	°F

6.20 Drop Diameter Distribution (WS100 only)

Drop diameters of precipitation detected by the radar sensor are shown as distribution of drop diameter classes. Diameters are calculated as volume equivalent ball diameter.

Sampling Rate Event dependent Unit Number of events

Abfragekanäle:

UMB Channel	Measurement Variable (uint32)	Unit	
4600	Total precipitation particles	Events	
4601	Total drops	Events	
UMB Channel	Measurement Variable (uint16)	Unit	
4602	Drizzle particles	Events	
4603	Snow particles	Events	
4604	Hail particles	Events	
4620	Cl. 0: Drops < 0.5mm equiv. diameter	Events	
4621	Cl 1: Drops 0.5 1.0mm equiv. diameter	Events	
4622	Cl 2: Drops 1.0 1.5mm equiv. diameter	Events	
4623	Cl 3: Drops 1.5 2.0mm equiv. diameter	Events	
4624	Cl 4: Drops 2.0 2.5mm equiv. diameter	Events	
4625	Cl 5: Drops 2.5 3.0mm equiv. diameter	Events	
4626	Cl 6: Drops 3.0 3.5mm equiv. diameter	Events	
4627	Cl 7: Drops 3.5 4.0mm equiv. diameter	Events	
4628	Cl 8: Drops 4.0 4.5mm equiv. diameter	Events	
4629	Cl 9: Drops 4.5 5.0mm equiv. diameter	Events	
4630	Cl 10: Drops 5.0 5.5mm equiv. diameter	Events	
4631	Cl 11: Drops > 5.5mm equiv. diameter	Events	



Note: Similar to the request of differential precipitation quantity the accumulated sum of events of each channel will be reset to 0 after transmission!

For consistent results all related channels should be requested in one run.

If the response from the device is lost due to a transmission error (e.g. poor GPRS connection), the quantity accumulated to date is also lost. The quantity accumulated to date is also reset each time the equipment is rebooted.



7 Installation

The sensor bracket is designed to be installed on the top of a mast with a diameter of 60 - 76mm.

The following tools are required for the installation:

- Open-end or ring spanner (SW13)
- Compass for aligning the wind meter to the North

7.1 Fastening





Figure 2: Fastening to the Mast

- Loosen nuts
- Push the sensor onto the top of the mast from above
- Tighten the nuts evenly until contact is made with the springs but the sensor can still be moved easily
- Align the sensor to the North (for wind meters)
- Tighten both nuts with 3 revolutions



7.2 North Alignment

In order for the wind direction to display correctly, the sensor must be aligned to the North. The sensor has a number of directional arrows for this purpose.






Figure 3: North Markings

Procedure:

- If the sensor is already installed, first loosen both nuts evenly until you can turn the sensor easily
- Using the compass, identify the North and fix a point of reference on the horizon
- Position the sensor in such a way that the South and North wind sensors are in alignment with the fixed point of reference in the North
- Tighten both nuts with 3 revolutions




Figure 4: Alignment to North



Note: As the magnetic North Pole indicated by the compass differs from the Geographic North Pole, account must be taken of the declination (variation) at the location when aligning the sensor.

Depending on the location, the variation can be more than 15° (in North America for example). In Central Europe the variation can be largely ignored at present (< 3°). You can find further helpful information on this subject on the Internet.

7.3 Selecting the Installation Location

In order to guarantee long service life and correct equipment operation, please pay attention to the following points when selecting the installation location.


7.3.1 General Instructions

- Stable subsurface for installing the mast
- Free access to the equipment for maintenance works
- Reliable power supply for permanent operation
- Good network coverage when transmitting over a mobile communications network



Note: The computed measurements specifically apply to the equipment location only. No conclusions can be drawn with regard to the wider environment or a complete road section.

ATTENTION:





- All relevant regulations for working at this height must be observed.
- The mast must be sized and anchored appropriately.
- The mast must be earthed in accordance with regulations.
- The corresponding safety regulations for working at road side and in the vicinity of the road carriageway must be observed.

Ŵ

If the equipment is installed incorrectly

- It may not function.

 It may be permanently damage.
- It may be permanently damaged.
- Danger of injury may exist if the equipment is allowed to fall.

7.3.2 Sensors with Wind Measurement / Compass

- · Installation at the top of the mast
- Installation height at least 2m above the ground
- Free field around the sensor



Note: Buildings, bridges, embankments and trees may corrupt the wind measurement. Equally, passing traffic may cause gusts which may influence the wind measurement.

Note: for accurate compass readings, an aluminium mast is recommended.

7.3.3 Sensors with Radar Precipitation Measurement

- Installation on the top of the mast
- Installation height at least 4.5m above the ground (if there are no moving objects in wider circumference of the sensor, a lower installation height may be considered)
- Distance to road carriageway at least 1m
- Distance from moving objects (e.g. trees, bushes and even bridges) at least 5m at the height of the sensor
- Minimum distance between devices with radar precipitation measurement: 8m.



Note: Falling or moving objects, e.g. falling leaves or leaves blowing in the wind, may cause false measurements and/or precipitation types.



Note: Strong wind can influence the accuracy of the precipitation measurement. Installation locations where wind turbulence is to be expected, e.g. caused by buildings, should be avoided.





Note: When selecting the installation location please take care to position the device at a suitable distance from other systems incorporating a 24GHz radar sensor, such as traffic counting devices on overhead gantry signs. Otherwise cross effects and system malfunctions may occur. In the final analysis, the distance to other measuring systems also depends on their range of coverage and signal strength.

7.3.4 Sensors with Rain Gauge

- Installation on the top of the mast or on crossbar with distance to the mast
- Mast or crossbar mounting shall be exactly perpendicular, otherwise the precision of the rain gauge may be influenced.



Note: The location should be selected so that pollution of the rain gauge funnel by falling leaves etc. can be avoided as far as possible.

7.3.5 Sensors with Global Radiation Measurement

- Installation on top of the pole
- Shadow free location, if possible 360° free view to the horizon at the height of the pyranometer
- Distance to shadow casting objects (trees, buildings) at least 10 times of the object height relative to the sensor.

7.3.6 Installation Sketch

Example WS600-UMB:






Figure 5: Installation Sketch

8 Connections

There is an 8 pole screw connector on the underside of the equipment. This serves to connect the supply voltage and interfaces by way of the supplied connection cable.

Equipment connector:





View on sensor connection

Figure 6: Connections

Pin assignment:

1	White	Supply voltage ground and (SDI12_GND for device version > 41)
2	Brown	Positive supply voltage (through 2.5A fuse where required)*
3	Green	RS485_A (+) or (SDI-12 GND for device version < 42)
4	Yellow	RS485_B (-) or SDI-12 Data Line
5	Grey	External Sensor a (WS100-UMB only: impulse output Uout)
6	Pink	External Sensor b (WS100-UMB only: not connected)
7	Blue	Heating voltage ground
8	Red	Positive heating voltage (through 2.5A fuse where required)*

The cable marking is in accordance with DIN 47100.



*) WS100/400/600/700/800-UMB: Supply voltage and heating voltage shall be protected by a fuses 2.5A (fine) each.



The cable shielding shall be connected to earth in the electrical cabinet.



Note: The yellow protective cap must be removed before plugging in the equipment. If the equipment is not connected correctly



- It may not function
- It may be permanently damaged
- The possibility of an electrical shock may exist

The supply voltage and the heating voltage are protected against polarity reversal.



Note: When operating the Smart Weather Sensor in SDI12 mode, line 3 (green) shall be connected only if the SDI12 logger is DC-isolated from the supply voltage of the device. If signal ground (SDI-12-GND) of the data logger and power supply ground are identical, only the SDI12-Data-Line (line 4, yellow) may be connected.



Note for SDI12 operation of devices starting from device version 42 or 51 (WS700) and all WS100: If data logger and device supply voltage are DC-isolated the signal ground (SDI12_GND) must be connected to line 1 (white). Line 3 (green) shall not be connected. (see SDI12 connection drawings in chapter 19.6)



8.1 Supply Voltage

The supply voltage for the Smart Weather Sensor is 12 - 24V DC. The power supply unit used must be approved for operation with equipment of protection class III (SELV).

Starting with device version 037 the Smart Weather Sensor has an extended supply voltage range of 4 ... 32V DC. Operation with a supply voltage of 24V is recommended. Limitations apply in case of supply voltages lower than 12V (see below).

8.1.1 Limitations in 12V mode

If the heating is operated on 12V DC, account must be taken of the functional restrictions in winter operation.



8.1.2 Limitations in Case of Operation with Supply Voltage Below 12V

When operating a Smart Weather Sensor (device version >= 037) with supply voltages lower than 12V DC, the fan will be not switched on, independent of the fan operating mode. This may influence the accuracy of temperature and humidity measurement in case of solar radiation.

Additionally deviations of the compass measurement values have to be accepted.

When operating the Smart Weather Sensor in Power Save Modes with supply voltages below 12V the minimal supply voltage depends on the length of the connection cable.

The minimal permitted supply voltage (U_{Bmin})can be approximately evaluated from the equation:

 $U_{Bmin} = 4V + 0.3V$ (cable length / m)

The minimal supply voltage for a 10m cable is then $U_{\text{Bmin}} = 6V$. The influence of the cable length on minimal supply voltage can be reduced by using of a cable with larger wire cross section.

8.2 RS485 Interface

The equipment has an electrically isolated, half-duplex, 2 wire RS485 interface for configuration, measurement polling and the firmware update.

See page 51 for technical details.



8.3 Connection to ISOCON-UMB (8160.UISO)




Figure 7: Connection to ISOCON-UMB



Warning: The heating voltage (red = positive heating voltage; blue = heating voltage ground) is **not** connected to the ISOCON-UMB but wired direct to the power supply unit. During installation please also refer to the operating manual for the ISOCON-UMB.

8.4 Use of Surge Protection (8379.USP)

When using surge protection (Order No.: 8379.USP), please pay attention to the connection example in the surge protection operating instructions.

8.5 Connection of External Temperature and Precipitation Sensors

External sensors are to be connected to pins 5 and 6 of the plug connector, i.e. to the gray and pink wires of the cable delivered with the Smart Weather Sensor.

The temperature sensors as well as the external rain gauge are unipolar, so any connection sequence can be chosen.

The type of external sensor has to be set using the UMB Config Tool.

For details please refer to Chapter18.

8.6 (WS100-UMB only:) Connection of Impulse Output for Rain Gauge Simulation

The digital impulse output is available between pin 7 (gray wire) Uout and pin 1 (white) GND. In idle state the voltage level at Uout is approximately equal to the supply voltage. Each time the configured amount of precipitation is reached, Uout is pulsed for about 50ms to GND level.

Activation of the rain gauge simulation mode and selection of the resolution have to be set by ConfigTool.NET.

For details please refer to Chapter 10.2.



9 Commissioning

After the equipment has been installed and connected correctly, the sensor begins autonomously to take measurements. A Windows® PC with serial interface, ConfigTool.NET software and interface cable (SUB-D 9 pole; jack - socket; 1:1) are required for configuration and test purposes.

Attention must be paid to the following points:

Check for correct equipment operation on site by carrying out a measurement request with the aid of ConfigTool.NET (see page 44).

- Configure the local altitude in order to ensure the correct calculation of relative air pressure (see page 37).
- The device must be aligned to the North in order to ensure correct wind measurement (see page 27), or the automatic compass correction must be activated (see page 37).
- In order to get correct compass headings the local declination must be configured (see page 20and 37).
- If several Smart Weather Sensors are operated on a UMB network, a unique device ID must be assigned to each device (see page 36).

There is no protective cover to remove on the sensor itself.



10 Configuration and Test

For Configuration and Test Lufft provides the proprietary software ConfigTool.NET (successor of UMB-Config-Tool). ConfigTool.NET can also be used to update the firmware of the Smart Weather Sensor.

The PC version of the software is available from the Lufft hom page: https://www.lufft.com/resources/

Download the software UMB-ConfigTool.NET and install it on your computer. Use the online help to get familiar with the program in general.

The following chapters only deal with the device specific aspects applying to the Smart Weather Sensor.

The functions explained following may not be available for all subtypes of the Smart Weather Sensor.



Note: Make sure to always use the latest version of ConfigTool.NET for configuration oft he Smart Weather Sensor.



Note: During configuration and test other devices polling the UMB-Bus, e.g. modem or LCOM must be disconnected!



Note: The connection settings of ConfigTool.NET must conform to the settings of the device. Factory settings of the Smart Weather Sensor: Baudrate 19200Baud, data format 8N1.



Note: The previous UMB-Config-Tool is not suitable for configuration settings of the WS100-UMB. ConfigTool.NET shall be used for configuration settings of the WS100-UMB.

Attempts to modify the settings of the WS100-UMB by UMB-Config-Tool may render the device inoperative.



10.1 Factory Settings

The Smart Weather Sensor is delivered with the following settings:

Class ID: 7 (cannot be modified)

Device ID: 1 (gives address 7001h = 28673d)

Baud rate: 19200 RS485 protocol: Binary

Calculation interval: 10 measurements

Local altitude: 0 m



Note: The device ID must be changed if several Smart Weather Sensors are operated on a UMB network, as each device requires a unique ID. It makes sense to start from ID 1 and continue in ascending order.

10.2 Configuration with the UMB-Config-Tool

The operation of the UMB-ConfigTool.NET is described in detail in help function of the Windows® PC software. For this reason only the menus and functions specific to the Smart Weather Sensor are described here.

10.2.1 Sensor Selection

Select an existing workspace or create a new one.




Figure 8: Select a Workspace

Add a new device to the workspace by clicking the "+" button.

The Smart Weather Sensor is shown here as sensor selection WSx-UMB (Class ID 7).

Enter a name for the new device and adjust the device ID if necessary. Store the modifications with "OK".




Figure 9: Sensor Selection



10.2.2 Configuration

After a configuration has been loaded, all relevant settings and values can be adjusted. Depending on the device type, only the settings pertinent to the respective available sensors

10.2.3 General Settings




Figure 10: General Settings

> ID: Device ID (factory setting 1; assign device IDs to additional devices in

> > ascending order).

Description: In order to differentiate the devices you can enter a description here, e.g.

the location.

Linespeed: Transmission speed of the RS485 interface (factory setting 19200; DO NOT

CHANGE for operation with ISOCON-UMB).

Protocol: Communications protocol of the sensor (UMB-Binary, UMB-ASCII, SDI-12,


Modbus-RTU, Modbus-ASCII, Terminal-Mode, XDR).

Timeout: In the event of a temporary changeover of the communications protocol, the

system switches back to the configured protocol after this time (in minutes)

Important note: If the baud rate is changed, after saving the configuration on the sensor, the sensor communicates at the new baud rate. When operating the sensor in a UMB network with ISOCON-UMB, this baud rate must not be changed; otherwise the sensor is no longer addressable and can no longer be configured.

10.2.4 Temperature, Humidity and Fan Settings



Temperature, Humidity and Fan Settings

Figure 11:

Temp. Offset:

Rel. Hum.Off: Absolute offset on the measurement in the unit indicated in the parameter

description field (for on-site calibration).

Time in minutes for the minimum, maximum and average value calculation Interval:

interval.

Fan: to reduce electrical power consumption, the fan can be switched off.

> Note: if the fan is switched off, all heaters will also be switched off! With the fan switched off deviations in temperature and humidity measurement can occur by solar radiation!

Note: In order to calculate dew point, absolute humidity and mixing ratio, the temperature and humidity measurement always requires the same interval. For this reason different intervals cannot be set.



10.2.5 Pressure,




Figure 12: Pressure Settings

Altitude: Enter the local altitude in meters here for the correct calculation of

relative air pressure (referenced to sea level).

Offset: Absolute offset on the measurement in the unit indicated in the parameter

description field.

Interval: Time in minutes for the minimum, maximum and average value

calculation interval.

10.2.6 Wind and Compass Settings




Figure 13: Wind Settings

Compass correction:

With activated compass correction all wind direction values will be corrected according to the alignment of the sensor, as evaluated by the compass.

compass

Windspeed min: Minimum wind speed from which a measurement is transmitted, in the

unit unit indicated in the parameter description field

Setpoint Temp.: Setpoint temperature in °C for the wind sensor heating

Interval: Time in minutes for the minimum, maximum and average value

calculation interval.

Heater mode: The device can be configured for heating in different operating modes.

Configure as 'automatic' in normal operating mode. You can find a

precise description of the operating modes on page 47.

Heater Temp. Mode 1:

Temperature in °C, below which the heating is active in Mode 1

Eco Mode Follow Up Time:

On-time of the heating in Eco Mode 1

Deviation: Dependent on the location of the installation; the local declination of the

earth magnetic field has to be considered.

10.2.7 Precipitation Sensor Settings (Radar)




Figure 14: Precipitation Sensor Settings (Radar)

Heater mode: The device can be configured for heating in different operating modes.

Configure as 'automatic' in normal operating mode. You can find a detailed description of the operating modes and related parameters on page 47.

Followup time precipitation type: for this time (in seconds) the detected precipitation type is shown; to cover all events, this time must be adjusted to the poll rate.



Note: The other parameters (evaporation, correction factors, ...) can be used to adapt the precepetation detection to special local conditions. They should only be modified after consultation with Lufft, as they have a major influence on the functioning and accuracy of the sensor.

10.2.8 Precipitation Sensor Settings (Rain Gauge)

The rain gauge module can be operated with resolutions 0.2mm or 0.5mm. The setting of the resolution is to be done in two steps:

- Mechanical setting
- Configuration setting

The mechanical setting works by modifying the effective area of the funnel. The sensor is delivered with a reduction ring, which can be mounted on the funnel to reduce the area.

Funnel with reduction ring resolution 0.5mm
Funnel without reduction ring resolution 0.2mm

Then the resolution is set in the sensor configuration using the UMB Config Tool.

Evaporation per day	0.24	
Rainfall correction factor	1	
Snowfall correction factor	1	
Follow up time	120	
Shnow factor	20	
Rain factor	50	
Heater mode	Auto	
Heater temperature Mode 1	5	
Set point temperature	70	
Follow up time Mode 1	30	
Operation mode	Standard	
Rain gauge resolution	0.2 mm	

Figure 15: Precipitation Sensor Settings (Rain Gauge)



Caution: If mechanical setting and configuration setting do not conform, the sensor will deliver wrong precipitation values!



Figure 16: Global

Radiation Settings

Figure 17: Lightning Sensor Settings

10.2.9 Global Radiation Settings

Global radiation			
	Global radiation interval	10	

Interval:

Time in minutes for minimum, maximum and average value calculation

10.2.10 Lightning Sensor Settings



Interval:

Time in minutes for minimum, maximum and average value calculation

10.2.11 Energy Management




Figure 18: Energy Management Settings

> By setting the operating and heating mode, the energy consumption of the device can be adapted to the circumstances of the installation.

The different settings are described in the following chapters:

- operating modes of Smart Weather Sensor from page 45
- operating modes of the heating from page 47

10.2.12 Reset Precipitation Quantity

To reset the accumulated absolute precipitation quantity UMB-ConfigTool.NET offers the following function:

Click the reset symbol, top left of the window header





Figure 19: Reset Precipitation Quantity

Select Reset Type "Custom Reset", then click the "Reset" button.

The device clears the precipitation amount and performs a device restart.

You can select if the reset function shall be performed for the device currently selected only, for a class of devices or for all devices connected to the respective UMB network. Default selection is the currently selected device.







10.2.13 (WS100-UMB only) Setting of Rain Gauge Simulation

Note: For configuration settings of the WS100-UMB do not use UMB-Config-Tool, but ConfigTool.NET. For details of operation please refer to the software manual of ConfigTool.NET.



Note: while the rain gauge simulation is active communication through the serial interface in UMB or another serial protocol is not possible. To still allow access to the device for modification of settings etc. UMB protocol will be active during the first 5 sec after power on. The necessary procedure is described in detail in chapter 19.6.1.

Rain gauge simulation is selected as a protocol setting.




Figure 20: Select operation mode "Simulated Rain Gauge"

The resolution of the simulated rain gauge is defined in the field "Sim. RainGauge Resolution". Factory setting is 0.01mm, alternatively 1.0mm, 0.5mm, 0.2mm or 0.1mm may be selected.

Radar rain senso	or .		
Evaporation per	day	0.24	=
Rainfall correction	on factor	1	100
Snowfall correct	ion factor	1	
Follow up time		120	
Snow factor		20	
Rain factor		50	
Heater mode		Auto	
Heater temperat	ure Mode 1	5	
Set point tempe	rature	15	
Follow up time I	Mode 1	30	
Operation mode		Standard	
Sim. RainGauge	Resolution	Sim. Resolution 0.01mm	4

Figure 21: Configure the resolution of the simulated rain gauge

10.2.14 WMO Station settings (WS100-UMB only)

In connection with the output of the WMO Synop Codes (see 6.15.1), detailed information on the respective station can be stored in the device. These settings can be found in the "WMO" configuration section.


Figure 22: WMO station settings

WMO		
Station ID	1234	
Station name	WS100 - Fellbach	
Location latitude	48.8299026	
Location longitude	9.260161	
Location altitude	282	
Country	Germany	



10.2.15 (WS100-UMB only) UMB-ASCII 2.0 Settings

The structure of the telegrams of the UMB-ASCII 2.0 protocol is largely configurable and can thus be adapted to the requirements of a measurement data logger.



Automatic Transmission	Off	
Tranmission Interval	60	
Message Start Character	2	
Message End Control Character	4	
Line Break Mode	CRLF	
Decimal Separator Character	46	
Parameter Separator Character	59	
Block Separator Character	58	



Automatic Transmission	If one of the standard sets is selected, it is transmitted at the specified intervals
Transmission Intervall	Time in seconds between automatic telegram transmission
Message Start Character	ASCII character marking the start of a response telegram; factory setting is 2 / 02h (STX)
Message End Character	ASCII character marking the end of a response telegram; factory setting is 4 / 04h (STX)
Line Break Mode	End of line character sequence for a telegram; factory setting is CRLF (0Dh, 0Ah), alternatives are CR (0Dh) or LF (0Ah)
Decimal Separator Character	Decimal separator character; factory setting is a decimal point 46 / 2Eh ('.')
Parameter Separator Character	Separator character for parameters in the telegram; factory setting is a semicolon 59 / 3Bh (';')
Block Separator Character	Separator character for the individual blocks of a telegram; factory setting is a colon 58 / 3Ah (':')



10.3 Function Test with UMB-ConfigTool.NET

The functions of the Smart Weather Sensor can be tested with UMB-ConfigTool.NET by polling various channels.



Note: All other devices which are used in the polling process, e.g. modems, LCOM etc., must be disconnected from the UMB network during configuration.

10.3.1 Channels for Measurement Polling

You can select the channel for measurement polling by UMB-ConfigTool.NET by clicking on the respective channel.




Figure 24 Measurement Polling Channels

10.3.2 Example of Measurement Polling




Figure 25 Example of Measurement Polling



Note: The UMB Config Tool is provided for test and configuration purposes only. It is not suitable for the permanent acquisition of measurement data. We recommend the use of professional software solutions for this purpose, e.g. Lufft SmartView3.



10.4 Operating Modes of the Smart Weather Sensor

The power consumption of the Smart Weather Sensor can be adjusted to the properties of the individual installation by setting the operation mode.

The operation of the power save modes however has certain constraints. These have to be considered when designing the installation.

In normal operation, where all specified properties of the Smart Weather Sensor are fully available, the power consumption is mostly determined by heating and fan operation.

10.4.1 Power Saving Mode 1

Following measures are active in power saving mode 1:

- The ventilation of the temperature / humidity unit is switched off
- · All heaters are switched off
- The radar rain sensor (WS800-UMB, WS700-UMB, WS600-UMB, WS400-UMB, WS100-UMB) is not working continuously. The sensor is activated once per minute for one second (WS100-UMB: 5sec), if precipitation is detected, it remains turned on until the end of the event, otherwise it is deactivated after this one second again.
- Compass measurement is only performed once after power up. The fan, which is otherwise deactivated, will be switched on shortly for the time of this measurement.
- The WS700-UMB / WS800-UMB increases the measuring cycle time for global radiation from 10 seconds to 1 minute.



Note: This setting has the following restrictions:

- With the fan switched off deviations in temperature and humidity measurement can occur by solar radiation.
- Only limited winter operation is possible in this operating mode because any icing might prevent the correct operation of the rain sensor or wind meter.
- The rain detection may be delayed up to 2 minutes. Short events are possibly not detected. Thus, deviations in the accuracy of the precipitation quantity are possible.

Compared with normal operation the power consumption of a WS600-UMB can be reduced to 10% even neglecting the heating. (during precipitation events the consumption is slightly higher, due to the rain sensor then permanently switched on, about 20% compared to normal operation).



10.4.2 Power Saving Mode 2

Power saving mode 2 permits another relevant reduction of the power consumption, but adds on the other hand more severe restrictions.

In this operation mode the device will be almost completely switched off and will wake up only by the data request for one measurement cycle. During measurement and data transmission the device will be switched on for about 10 - 15 sec. The total consumption will be mostly determined by the data request interval.



Note: This operating mode has the following restrictions:

- All restrictions of power saving mode 1
- Power saving mode 2 is not available for devices with radar rain sensor (WS800-UMB, WS700-UMB, WS600-UMB, WS400-UMB, WS100-UMB). We recommend devices with tipping bucket rain gauge for low power applications.
- The calculation of average, minimum and maximum as well as precipitation intensity are not available. Only instantaneous values will be transmitted.
- Compass measurement is only performed once after power up. The fan, which is otherwise deactivated, will be switched on shortly for the time of this measurement.
- Communication protocol Modbus is not available
- When using the UMB protocol a certain request sequence and timing is required (s. Chap. 19.3.7). The interval length must be at least 15sec to make sure that the measurement and transmission cycle can be completed. Shorter interval could cause the device to stay in transmission state without starting a new measurement.
- The joint operation with other sensors in an UMB network is possible, but it has to be considered that each telegram (even when addressed to another device) will cause the Smart Weather Sensor to wake up for at least several seconds, thus increasing the total power consumption. The minimum interval length must be hold up under consideration of the telegrams with other addresses. Mixed operation of devices in power saving mode 2 with devices in normal operation and fast request rates within the same UMB network is not possible.



10.5 Operating Modes for Equipment Heating

Heating is configured to 'Automatic' when the product is delivered. This is the recommended operating mode for heating the sensor.

You can set the following operating modes:

Heater Mode	WS100- UMB	WS200- UMB	WS400- UMB	WS500- UMB	WS501- UMB *)	WS600- UMB **)	WS601- UMB
Automatic	•	•	•	•	•	•	•
Off	•	•	•	•	•	•	•
Mode 1	•		•	•	•	•	•
Eco-Mode 1	•		•			•	

^{*)} is also valid for WS502-UMB, WS503-UMB, WS504-UMB, WS510-UMB

^{**)} is also valid for WS700-UMB and WS800-UMB



Note: Model WS30x-UMB and WS401-UMB are not heated.

The rain sensor and wind meter settings must be adjusted in the respective configuration mask. The examples show the wind meter setting.

10.5.1 Automatic

In this operating mode, the sensor is maintained constantly at the control temperature, generally in order to prevent the effects of snow and ice.





Figure 26: Operating Modes for Equipment Heating

Setpoint Temp.: The heating controls at this temperature (in °C)

Heating mode1 Temp.: Threshold temperature (in °C) with effect from

which air temperature heating is enabled

Eco mode1 follow-up time: Follow-up time (in minutes)



10 5 2 Off

In the 'Off' operating mode heating is completely disabled. Winter operation is not possible in this operating mode because any icing might prevent the correct operation of the rain sensor or wind meter.

10.5.3 Mode 1

In 'Mode 1' operating mode heating is only enabled when the outside temperature falls below the HeatingMode1 temperature (in °C). In this mode power consumption can be reduced in frost-free situations with no great restriction on winter operation.



10.5.4 Eco-Mode 1

Eco Mode1 is an advanced energy saving mode.


Heating is only switched on when the following conditions are met:

- The outside temperature is below the threshold temperature and precipitation was detected. Heating then runs at the control temperature for 30 minutes (after the last precipitation event).
- When the outside temperature lies constantly below the threshold temperature and there
 was no heating for more than 20h, heating is switched on for 30 minutes as a
 precautionary measure in order to thaw any icing.


However, the precautionary 20h-heating only runs if the outside temperature was measured at below the threshold temperature for the entire period and conditions were constantly bright for at least 3 hours.

Examples:

Outside temperature constantly below 5°C; no precipitation for more than 24h



Outside temperature constantly below 5°C; with precipitation





11 Firmware Update

To keep the sensor in accordance with the latest state-of-the-art, it is possible to carry out a firmware update on site with no need to remove the sensor and return it to the manufacturer.

The firmware update is carried out with ConfigTool.NET.

The description of the firmware update can be found in ConfigTool.NET Help pages (Ch. Workspaces) Please download the latest firmware and ConfigTool.NET from our website www.lufft.com and install it on a Windows® PC.



Note: When a firmware update takes place, under certain circumstances the absolute precipitation quantities are reset (channel 600 - 660).

There is one firmware for the entire product family (except WS100-UMB) which supports all models (WSx_Release_Vxx.mot).

The firmware for WS100-UMB is named WS100_Release_Vxx.bin.



Important Note: please read the included text file in WSx_Release_Vxx.zip; it contains important information about the update!

12 Maintenance

In principle the equipment is maintenance-free.

However, it is recommended to carry out a functional test on an annual basis. When doing so, pay attention to the following points:

- Visual inspection of the equipment for soiling
- Check the sensors by carrying out a measurement request
- Check the operation of the fan (not on WS200-UMB)

In addition, an annual calibration check by the manufacturer is recommended for the humidity sensor (not on WS200-UMB). It is not possible to remove or replace the humidity sensor. The complete Smart Weather Sensor must be sent to the manufacturer for testing.

Cleaning of the glass dome at regular intervals is suggested for devices with global radiation measurement. The length of the interval should be adapted to the local degree of pollution.

Devices with precipitation measurement by rain gauge (WS401-UMB, WS601-UMB): The rain gauge funnel needs to be cleaned at regular intervals (see below). The length of the interval should be adapted to the local degree of pollution.



Devices with precipitation radar must be disconnected from power during maintenance service.



12.1 Maintenance of the Rain Gauge

The function of the rain gauge will be significantly influenced by pollution of the funnel or the tipping bucket mechanism. Regular check and, if necessary, cleaning is required. The maintenance interval depends very much on local conditions and also on seasons (leaves, pollen, etc.) and therefore cannot be exactly defined here (it may be in the range of weeks).




Figure 27: WS601-UMB with removed funnel

- Only clean when obviously polluted
- Avoid moving the tipping mechanism (otherwise wrong counts will occur)
- Use water, soft cloth and / or a soft brush for cleaning
- Unlock funnel by turning it to the left and lift it off
- Clean funnel, specially the sieve slots
- Check the inside of the rain gauge module for pollution, especially for spider webs and insects, if necessary, clean it
- Check tipping bucket for pollution, if necessary wash carefully with clean water.
 Caution: each movement of the bucket generates a counting pulse and thus may cause faulty precipitation amounts
- Check water drain, clean if necessary
- Put funnel back in place and lock it by turning it to the right



13 Technical Data

Power supply: 24VDC +/- 10%

12VDC with restrictions (see page 31)

Device version >= 037: 4 ... 32V DC Limitations apply in case of supply voltage

less than 12V (see p. 31 f.)

Current consumption – sensor; values for devices prior to version 037 in brackets:

Mode ¹	Standard		Power Sav	ving Mode 1	Power Savi	ng Mode 2
Supply	24VDC ²	12VDC	24VDC	12VDC	24VDC	12VDC
WS100-UMB	42 mA	82 mA	17 mA	33 mA		
WS200-UMB	16 mA	25 mA	15 mA	24 mA	1 (4) mA	2 mA
WS300-UMB	135 mA	70 mA	7 mA	7 mA	1 (4) mA	2 mA
WS301-UMB WS302-UMB WS303-UMB WS304-UMB WS310-UMB	135 mA	70 mA	8 mA	8 mA	1 (4) mA	2 mA
WS400-UMB	160 mA	110 mA	7 mA	7 mA		
WS401-UMB	130 mA	65 mA	6 mA	6 mA	1 (4) mA	2 mA
WS500-UMB	140 mA	85 mA	16 mA	25 mA	1 (4) mA	2 mA
WS501-UMB WS502-UMB WS503-UMB WS504-UMB WS510-UMB	145 mA	85 mA	16 mA	25 mA	1 (4) mA	2 mA
WS600-UMB WS700-UMB WS800-UMB	160 mA	130 mA	16 mA	25 mA		
WS601-UMB	140 mA	85 mA	15 mA	24 mA	1 (4) mA	2 mA

Current consumption and power input - heating:

WS100-UMB	380 mA / 9.1VA at 24VDC
WS200-UMB	833 mA / 20VA at 24VDC
WS400-UMB	833 mA / 20VA at 24VDC
WS500-UMB, WS501-UMB, WS502-UMB	833 mA / 20VA at 24VDC
WS503-UMB, WS504-UMB, WS510-UMB	
WS600-UMB, WS700-UMB, WS800-UMB	1,7 A / 40VA at 24VDC
WS601-UMB	833mA / 20VA at 24VDC

Dimensions including mounting bracket:

Environment in relating in earling practice.	
WS100-UMB	Ø 150mm, height 190mm
WS200-UMB	Ø 150mm, height 194mm
WS300-UMB	Ø 150mm, height 223mm
WS301-UMB	Ø 150mm, height 268mm
WS302-UMB	Ø 150mm, height 253mm
WS303-UMB	Ø 150mm, height 328mm
WS304-UMB	Ø 150mm, height 313mm
WS310-UMB	Ø 150mm, height 311mm
WS400-UMB	Ø 150mm, height 279mm
WS401-UMB	Ø 164mm, height 380mm
WS500-UMB	Ø 150mm, height 287mm
WS501-UMB	Ø 150mm, height 332mm
WS502-UMB	Ø 150mm, height 377mm
WS503-UMB	Ø 150mm, height 392mm
WS504-UMB	Ø 150mm, height 317mm
WS510-UMB	Ø 150mm, height 376mm
WS600-UMB	Ø 150mm, height 343mm
WS601-UMB	Ø 164mm, height 445mm
WS700-UMB	Ø 150mm, height 344mm
WS800-UMB	Ø 150mm, height 344mm

 $^{^{\}rm 1}$ Description of operating modes, see page 35

²Factory default, recommended setting



Weight including mounting bracket, excluding connection cable: WS100-UMB ca. 0.6 kg WS200-UMB ca. 0.8 kg WS300-UMB ca. 1.0 kg WS400-UMB, WS301-UMB, WS302-UMB, ca. 1.3 kg WS303-UMB, WS304-UMB, WS310-UMB **WS401-UMB** ca. 1.5 kg WS500-UMB ca. 1.2 kg WS600-UMB, WS501-UMB, WS502-UMB, ca. 1.5 kg WS503-UMB, WS504-UMB, WS700-UMB WS510-UMB, WS800-UMB WS601-UMB ca. 1.7 kg

Fastening: Stainless steel mast bracket for Ø 60 - 76mm

Protection class: III (SELV)
Protection type: IP66

Storage Conditions

Permissible storage temperature: $-50^{\circ}\text{C} \dots +70^{\circ}\text{C}$ Permissible relative humidity: $0 \dots 100\% \text{ RH}$

Operating Conditions

Permissible operating temperature: $-50^{\circ}\text{C} \dots +60^{\circ}\text{C}$ Permissible relative humidity: $0 \dots 100\% \text{ RH}$

Permissible altitude above sea level: N/A

RS485 interface, 2 wire, half-duplex

Data bits: 8 (SDI-12 mode: 7)

Stop bit: 1

Parity: No (SDI-12 mode: even, Modbus mode none or

even)

Tri-state: 2 bits after stop bit edge

Adjustable baud rates: 1200, 2400, 4800, 9600, 14400, 19200³, 28800, 57600

(In SDI-12 mode, the interface is changed to meet the requirements of the standard.)

Housing: Plastic (PC)



³Factory setting; baud rate for operation with ISOCON-UMB and firmware update.

13.1 Measuring Range / Accuracy

13.1.1 Air temperature

Measurement process: NTC

Measuring range: -50°C ... +60°C

Resolution: 0.1°C (-20°C...+50°C), otherwise 0.2°C

Sensor accuracy: +/- 0.2°C (-20°C ... +50°C), otherwise +/-0.5°C (>-30°C)

Sampling rate: 1 minute Units: °C; °F

(WS100-UMB: the accuracy of the air temperature service channels is not specified)

13.1.2 Humidity

Measurement process:

Measuring range:

Capacitive

0 ... 100% RH

Resolution:

0.1% RH

4ccuracy:

+/- 2% RH

Sampling rate:

1 minute

Units:

% RH; g/m³; g/kg

13.1.3 Dewpoint Temperature

Measurement process: Passive, calculated from temperature and humidity

Measuring range: -50°C ... +60°C

Resolution: 0.1°C

Accuracy: Computed +/- 0.7°C

Units: °C; °F

13.1.4 Air Pressure

Measurement process: MEMS sensor - capacitive

Measuring range: 300 ... 1200hPa

Resolution: 0.1hPa

Accuracy: +/- 0.5hPa (0 ... +40°C)

Sampling rate: 1 minute hPa

13.1.5 Wind Speed

Measurement process: Ultrasonic

Measuring range: 0 ... 75m/s (WS601-UMB: 0 ... 30m/s)

Resolution: 0.1m/s

Accuracy: $\pm 0.3 \text{ m/s or } \pm 3\% \text{ (0...35 m/s)}$

±5% (>35m/s) RMS

Response threshold: 0.3 m/s
Internal sampling frequency: 15Hz

Instantaneous value: 1 sec / 10sec

Output rate for average and

peak gust values: 1min – 10min (peak calculated from 1sec values)

Units: m/s; km/h; mph; kts

13.1.6 Wind Direction

Measurement process: Ultrasonic Measuring range: $0-359.9^{\circ}$ Resolution: 0.1°

Accuracy: < 3° (> 1m/s) RMSE

Response threshold: 0.3 m/s Internal sampling frequency: 15Hz

Instantaneous value: 1 sec / 10sec

Output rate for average and

peak gust values: 1min – 10min (peak calculated from 1sec values)



13.1.7 Precipitation

13.1.7.1 WS100-UMB / WS400-UMB / WS600-UMB / WS700-UMB /WS800-UMB

Measurement process: Radar sensor
Measuring range (drop size): 0.3 mm ... 5.0 mm

Liquid precipitation resolution:

Precipitation types:

Repeatability:

Response threshold:

0.01 mm

Rain, snow

Typically > 90%

0.002 mm

Sampling rate: Event-dependent on reaching response threshold Precipitation intensity: 0 ... 200 mm/h; Sampling rate 1 min, resol. 0.01mm/h

13.1.7.2 WS401-UMB / WS601-UMB

Measurement process: Rain Gauge

Liquid precipitation resolution: 0.2 mm / 0.5mm (adjustable by reduction ring)

Precipitation types: Rain
Accuracy: 2%
Sampling rate: 1 minute

13.1.8 Compass

Measurement process: Integrated electronic compass

Measurement range: 0 ... 359°
Resolution: 1.0°
Accuracy: +/- 10°
Sampling rate: 5 minutes

13.1.9 Global Radiation

Measurement Process Thermopile pyranometer
Measurement Range 0.0 ... 2000.0 W/m²

Resolution < 1W/m²
Sampling Rate 10 seconds

13.1.9.1 WS301-UMB / WS501-UMB

Response time (95%) 18s Non-stability(change/year) <1% Non-linearity (0 to 1000 W/m²) <1%

Directional error (at 80° with 1000 W/m²) <20 W/m²

Temperature dependence of sensitivity <5% (-10 to +40°C)

Tilt error (at 1000 W/m²) <1%

Spectral range (50% points) 300 ... 2800nm

13.1.9.2 WS302-UMB / WS502-UMB / WS700-UMB / WS800-UMB

Response time (95%) <1s

Spectral range (50% points) 300 ... 1100nm

13.1.9.3 WS310-UMB / WS510-UMB

Response time (95%) 5s Non-stability(change/year) <0.5% Non-linearity (0 to 1000 W/m²) <0.2%

Directional error (at 80° with 1000 W/m²) <10 W/m²

Temperature dependence of sensitivity <1% (-10 to +40°C)

Tilt error (at 1000 W/m²) <0.2%

Spectral range (50% points) 285 ... 2800nm



13.1.10 External Temperature SensorWT1 / WST1

Measurement process: NTC

Measuring range: -40°C ... +80°C

Resolution: 0.25°C

Sensor accuracy: +/- 1°C (WST1: +/-0.3°C between -10°C ...+10°C)

Sampling rate: 1 minute Units: °C; °F

13.1.11 External Rain GaugeWTB100

Measurement process: Rain Gauge with bounce-free reed contact (normally

closed)

Liquid precipitation resolution: 0.2 mm / 0.5mm (adjustable by reduction ring)

Precipitation types: Rain
Accuracy: 2%
Sampling rate: 1 minute

In principle, all rain sensors with bounce-free reed contact (normally open or normally closed) and with a resolution of 0.1 mm, 0.2 mm, 0.5 mm or 1.0 mm can be used.



13.2 Drawings




Figure 28: WS100-UMB




Figure 29: WS200-UMB




Figure 30: WS200-UMB




Figure 31: WS301-UMB

WS302-UMB, WS303-UMB und WS304-UMB are similar.






Figure 32: WS310-UMB




Figure 33: WS400-UMB




Figure 34: WS401-UMB




Figure 35: WS500-UMB




Figure 36: WS501-UMB

WS502-UMB, WS503-UMB und WS504-UMB are similar.




Figure 37: WS510-UMB




Figure 38: WS600-UMB




Figure 39: WS601-UMB




Figure 40: WS700-UMB, WS800-UMB

14 EC Certificate of Conformity

Product: Smart Weather Sensor

Type: WS100-UMB (Order No.: 8367.U03 / 8367.U05)

WS200-UMB (Order No.: 8371.U01)
WS300-UMB (Order No.: 8372.U01)
WS301-UMB (Order No.: 8374.U01)
WS302-UMB (Order No.: 8374.U10)
WS303-UMB (Order No.: 8374.U11)
WS304-UMB (Order No.: 8374.U12)
WS310-UMB (Order No.: 8374.U13)

WS400-UMB (Order No.: 8369.U01 / 8369.U02)

WS401-UMB (Order No.: 8377.U01) WS500-UMB (Order No.: 8373.U01) WS501-UMB (Order No.: 8375.U01) WS502-UMB (Order No.: 8375.U10) WS503-UMB (Order No.: 8375.U11) WS504-UMB (Order No.: 8375.U12) WS510-UMB (Order No.: 8375.U13)

WS600-UMB (Order No.: 8370.U01 / 8370.U02)

WS601-UMB (Order No.: 8376.U01) WS700-UMB (Order No.: 8380.U01) WS800-UMB (Order No.: 8381.U01)

We herewith certify that the above mentioned equipment complies in design and construction with the Directives of the European Union and specifically the EMC Directive in accordance with 2014/30/EU, the RoHS Directive 2011/65/EU and, where required, Directive 2014/53/EU.

The complete Certificate of Conformity is available for download from the Lufft website www.lufft.com



14.1 FCC Compliance Statement (US)

Product: Smart Weather Sensor

Productname	Part#	FCC
WS100-UMB	8367.U04	This device contains FCC ID: UF9WS100
WS800-UMB	8381.U01-NA	FCC ID: UF9-WSX00
WS700-UMB	8380.U01-NA	FCC ID: UF9-WSX00
WS600-UMB	8370.U01-NA	FCC ID: UF9-WSX00
WS400-UMB	8369.U01-NA	FCC ID: UF9-WSX00

This device complies with 15 of the FCC Rules. Operation is subject to the following two conditions:

- (1) This device may not cause harmful interference, and
- (2) this device must accept any interference received, including interference that may cause undesired operation.

Note: This equipment has been tested and found to comply with the limits for a Class A digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a commercial environment. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instruction manual, may cause harmful interference to radio communications. Operation of this equipment in a residential area is likely to cause harmful interference in which case the user will be required to correct the interference at his own expense.

This device complies with part 18 of the FCC Rules.

Changes and modifications not expressly approved by manufacturer could void the user's authority to operate the equipment.



14.2 IC Compliance Statement (CA)

Product: Smart Weather Sensor

Productname	Part#	IC
WS100-UMB	8367.U04	This equipment contains equipment certified under IC: 6650A-WS100
WS800-UMB	8381.U01-NA	IC: 6650A-WSX00
WS700-UMB	8380.U01-NA	IC: 6650A-WSX00
WS600-UMB	8370.U01-NA	IC: 6650A-WSX00
WS400-UMB	8369.U01-NA	IC: 6650A-WSX00

This device contains licence-exempt transmitter(s)/receiver(s) that comply with Innovation, Science and Economic Development Canada's licence-exempt RSS(s).

Operation is subject to the following two conditions:

- 1. This device may not cause interference.
- 2. This device must accept any interference, including interference that may cause undesired operation of the device.

L'émetteur/récepteur exempt de licence contenu dans le présent appareil est conforme aux CNR d'Innovation, Sciences et Développement économique Canada applicables aux appareils radio exempts de licence. L'exploitation est autorisée aux deux conditions suivantes :

- 1. L'appareil ne doit pas produire de brouillage;
- 2. L'appareil doit accepter tout brouillage radioélectrique subi, même si le brouillage est susceptible d'en compromettre le fonctionnement



appareils radio exempts de licence. L'exploitation est autorisée aux deux conditions suivantes:

- 1. L'appareil ne doit pas produire de brouillage;
- 2. L'appareil doit accepter tout brouillage radioélectrique subi, même si le brouillage est susceptible d'en compromettre le fonctionnement



14.3 WS 100 SRRC conformity (CN)

Product: Smart Weather Sensor

Type: WS100-UMB (Order No.: 8367.U05)

This equipment contains equipment certified under SRRC.

3.1 measuring frequency range of spurious emission			
Working frequency space	Frequency range of spurious emission test		
	Lower limit	High limit	
Above 13 GHz	30 MHz	2 x harmonic waves	

3.2 spurious emission limits				
3.2.1 transmitting mo	ode @max. power			
Frequency range	Test bandwidth	limits	Demodulation type	
30MHz – 1GHz	100kHz(3dB)	-36dBm	RMS(effective value)	
1GHz – 40GHz	1MHz(3dB)	-30dBm	RMS(effective value)	
>40GHz	100kHz(3dB)	-20dBm	RMS(effective value)	
3.2.2 standby or sleeping mode				
Frequency range	Test bandwidth	limits	Demodulation type	
30MHz – 1GHz	100kHz(3dB)	-47dBm	RMS(effective value)	



15 Fault Description

Error description	Cause - Remedy
Device does not allow polling / does not respond	 Check power supply Check interface connection Incorrect device ID → check ID; devices are delivered with ID 1.
The device measures precipitation but it is not raining	Check that the sensor was installed correctly in accordance with the instructions.
The measured temperature appears too high / measured humidity appears too low	Check the operation of the fan on the underside of the device.
Wind direction values are incorrect	Device is not correctly aligned → check that the device is aligned to the North.
Device transmits error value 24h (36d)	A channel is being polled that is not available on this device type; e.g. Channel 200 = humidity is being polled on a WS200-UMB.
Device transmits error value 28h (40d)	The device is in the initialization phase following startup→ the device delivers measurements after approx. 10 seconds.
Device transmits error value 50h (80d)	The device is being operated above the limit of the specified measuring range.
Device transmits error value 51h (81d)	The device is being operated below the limit of the specified measuring range.
Device transmits error value 55h (85d) during wind measurement	The device is unable to execute a valid measurement due to the ambient conditions. This may be due to the following reasons: The device is being operated well above the limit of the specified measuring range Very strong horizontal rain or snow The wind meter sensors are very dirty → clean sensor The wind meter sensors are iced over → check heating mode in the configuration and check heating function / connection There are foreign objects within the measuring section of the wind meter One of the wind meter's sensors is faulty → return device to manufacturer for repair
The quality of the wind measurement is not always100%	In normal operation the device should always transmit 90 – 100%. Values up to 50% do not represent a general problem. When the error value 55h (85d) is transmitted this value is 0%. If the device permanently transmits values below 50% this may mean that there is a fault.
Device transmits an error value not listed here	This may be due to a number of reasons → contact the manufacturer's technical support department.



16 Disposal

16.1 Within the EC

The device shall be disposed of in accordance with European Directives 2002/96/EC and 2003/108/EC (waste electrical and electronic equipment).

16.2 Outside the EC

Please comply with the applicable regulations for the proper disposal of waste electrical and electronic equipment in your respective country.

17 Repair / Corrective Maintenance

Please arrange for any faulty equipment to be checked and, if necessary, repaired by the manufacturer exclusively. Do not open the equipment and do not under any circumstances attempt to carry out your own repairs.

In matters of warranty or repair please contact:

G. Lufft Mess- und Regeltechnik GmbH

Gutenbergstraße 20 70736 Fellbach P.O. Box 4252 70719 Fellbach Germany

Phone: +49 711 51822-0 Hotline: +49 711 51822-52 Fax: +49 711 51822-41 E-mail: info@lufft.de

or your local distributor.

17.1 Technical Support

Our Hotline is available for technical questions via the following e-mail address:

hotline@lufft.de

You can also consult frequently asked questions at http://www.lufft.com/ (menu header: SUPPORT / FAQs).



18 External Sensor

18.1 External Temperature and Precipitation Sensors

18.1.1 Connection of Temperature and Precipitation Sensors

Additional external sensor can cover the requirements of special measurement requirements or extend the functionality of Smart Weather Sensors.

Currently the accessory list includes external temperature sensors and the precipitation detection by tipping bucket rain gauge.

One input is available for this extension, so alternatively one temperature sensor or one precipitation sensor may be used.

The connection uses the standard connector plug of the Smart Weather Sensor, so normally the external device will be connected at the end of the cable included with the delivery, in the control cabinet. As this cable is part of the measuring line care shall be taken when designing the cabling to avoid parasitic coupling etc. The cable should be as short as possible. In special cases, e.g. when the external sensor is mounted near to the Smart Weather Sensor while the control cabinet is distant, the installation of an additional distribution box should be considered.

The external sensor is connected to pins 5 and 6 of the connector plug, i.e. the grey and pink wires of the standard cable.

All currently available sensors are unipolar, so the connection sequence is not relevant.

The Smart Weather Sensor must be configured for the selected type of external sensor (temperature or precipitation) to enable the correct evaluation of the measurement data. The selection of the sensor type is done through UMB-ConfigTool.NET.




Figure 41: Setting type of external sensor

If the data from the channels of the sensor type currently not selected are requested, the device will respond with "invalid channel".

18.1.2 External Temperature Sensor

All models of the WS family (except WS100-UMB) can be used with an external temperature sensor.

For different application various types of NTC sensor are in supply:

- WT1 for temperature acquisition of devices and surfaces
- WST1 for mounting in the road surface (road surface temperature)

Mounting / installation of the temperature sensors is shown in the sensor manual.

18.1.3 External Rain Gauge

All models of the WS family without integrated precipitation detection can be used with an external rain gauge. Models WS100-UMB, WS400-UMB, WS600-UMB, WS401-UMB, WS601-UMB, WS700-UMB, WS800-UMB with R2S sensor resp. integrated tipping bucket **cannot** be equipped with an external rain gauge.

The measurement values of the external rain gauge are on the same channels as the data of the internal precipitation sensors of WS100-UMB, WS400-UMB, WS600-UMB, WS401-UMB, WS700-UMB and WS800-UMB.

The external rain gauge WTB100 uses the same technology as the integrated rain gauge of models WS401-UMB and WS601-UMB.

The resolution of the rain gauge WTB100 can be modified by the reduction ring delivered with the sensor from 0.2mm to 0.5mm.

In principle, all rain sensors with bounce-free reed contact (normally open or normally closed) and with a resolution of 0.1 mm, 0.2 mm, 0.5 mm or 1.0 mm can be used.



Note: To get the correct amount of rain this "mechanical" selection must be also be set in Smart Weather Sensors configuration.

The setting is done with the UMB-ConfigTool.NET by the same procedure as with WS401-UMB and WS601-UMB (s. Chap.10.2.8).

The WS601/401-UMB's advices for installation (Chap.0) and maintenance (Chap.12.1) are as well valid for the external rain gauge.

Example with WS501-UMB and WTB100 without reduction ring:




Figure 42: Example WS501-UMB and WTB100



19 Appendix

19.1 Channel List Summary

The channel assignment applies to online data requests in binary and ASCII protocol.

	UMB C	hannel				Mea	suring R	ange
act	min	max	avg	special	Measurement Variable (float32)	min	max	unit
Tempera	atures				()			
100	120	140	160		temperature	-50.0	60.0	°C
105	125	145	165		temperature	-58.0	140.0	°F
101					external temperature	-40.0	80.0	°C
106					external temperature	-40.0	176.0	°F
110	130	150	170		dewpoint	-50.0	60.0	°C
115	135	155	175		dewpoint	-58.0	140.0	°F
111					wind chill temperature	-60.0	70.0	°C
116					wind chill temperature	-76.0	158.0	°F
114					wet bulb temperature	-50.0	60.0	°C
119					wet bulb temperature	-58.0	140.0	°F
112					wind heater temp.	-50.0	150.0	°C
113					R2S heater temp.	-50.0	150.0	°C
117					wind heater temp.	-58.0	302.0	°F
118					R2S heater temp.	-58.0	302.0	°F
Humidity	y							
200	220	240	260		relative humidity	0.0	100.0	%
205	225	245	265		absolute humidity	0.0	1000.0	g/m³
210	230	250	270		mixing ratio	0.0	1000.0	g/kg
Enthalpy	/							
215					specific enthalpy	-100.0	1000.0	kJ/kg
Pressure	9							
300	320	340	360		abs. air pressure	300	1200	hPa
305	325	345	365		rel. air pressure	300	1200	hPa
Air Dens	sity							
310					air density	0.0	3.0	kg/m³
Wind								
				vect. avg				
400	420	440	460	480	wind speed	0	75.0	m/s
405	425	445	465	485	wind speed	0	270.0	km/h
410	430	450	470	490	wind speed	0	167.8	mph
415	435	455	475	495	wind speed	0	145.8	kts
401					wind speed fast	0	75.0	m/s
406					wind speed fast	0	270.0	km/h
411					wind speed fast	0	167.8	mph
416					wind speed fast	0	145.8	kts
403					wind speed standard deviation	0	75.0	m/s
413					wind speed standard deviation	0	167.8	mph
500	520	540		580	wind direction	0	359.9	0
501					wind direction fast	0	359.9	۰
502					wind direction corr.	0	359,9	٥
503					wind direction standard deviation	0	359.0	۰
805				1	wind value quality	0	100.0	%
806		L	L		wind value quality (fast)	0	100.0	%
Compas	S							
510					compass heading	0	359	0



Precipitation Qu	antity		Range	Unit		
600	float32	Precipitation Quantity - Absolute	0 100000	liters/m²		
620	float32	Precipitation Quantity - Absolute	0 100000	mm		
640	float32	Precipitation Quantity - Absolute	0 3937	inches		
660	float32	Precipitation Quantity - Absolute	0 3937008	mil		
605	float32	Precipitation Quantity - Differential	0 100000	liters/m²		
625	float32	Precipitation Quantity - Differential	0 100000	mm		
645	float32	Precipitation Quantity - Differential	0 3937	inches		
665	float32	Precipitation Quantity - Differential	0 3937008	mil		
Precipitation Typ	oe .	·				
700	uint8	Precipitation Type	0 = No precipitation 40 = unspecified precipitation 60 = Liquid precipitation, e.g. 70 = Solid precipitation, e.g. WS100-UMB only: 67 = freezing rain 69 = sleet 90 = hail			
WMO Code (WS	100 only)					
780	uint8	WMO Synop Code 4680 wawa (Present Weather, automated station)	Code (see 0	Ch. 6.15.1)		
781	uint8	WMO Synop Code 4680 WaWa (currently not avalailable)	Same coding as	s channel 780		
785	uint8	WMO Synop Code 4677 ww (Present weather, manned station)	Code (see C	Ch. 6.15.1)		
786	uint8	WMO Synop Code 4677WW (currently not available)	Same coding as	s channel 785		
Precipitation Inte	ensity		Range	unit		
800	float32	Precipitation Intensity	0.00 200.00	l/m²/h		
820	float32	Precipitation Intensity	0.00 200.00	mm/h		
825	float32	Precipitation Intensity (WS100 only)	0.00 3.3333	mm/min		
840	float32	Precipitation Intensity 0.00 7.8740 in/h				
845	float32	Precipitation Intensity (WS100 only)	0.00 0.13123	in/min		
860	float32	Precipitation Intensity	0.0 7874.0	mil/h		



Global F	Radiation							
act	min	max	avg	special	Measurement Variable (float32)	min	max	unit
900	920	940	960		Global Radiation	0	1400	W/m²
ightnin	g Detecti	ion						
act	min	max	avg	sum	Measurement Variable (uint16)	min	max	unit
617					Lightning event (minute)	0	255	-
				677	Lightning event (interval)	0	7650	-
Service	Channels	5						
10000					Supply Voltage V	0.0	50.0	V
11000					Rain Drop Volume µI	0.0	500.0	μl
4100	4120	4140	4160		temperature	-50.0	60.0	°C
4105	4125	4145	4165		temperature	-58.0	140.0	°F
4600					Precipitation: total particles	0	4294967295	-
4601					Precipitation: total drops	0	4294967295	-
4602					Precipitation: drizzle particles	0	65535	-
4603					Precipitation: snow particles	0	65535	-
4604					Precipitation: hail particles	0	65535	-
4620					Precipitation: Drop class 0	0	65535	-
4621					Precipitation: Drop class 1	0	65535	-
4622					Precipitation: Drop class 2	0	65535	-
4623					Precipitation: Drop class 3	0	65535	-
4624					Precipitation: Drop class 4	0	65535	-
4625					Precipitation: Drop class 5	0	65535	-
4626					Precipitation: Drop class 6	0	65535	-
4627					Precipitation: Drop class 7	0	65535	-
4628					Precipitation: Drop class 8	0	65535	-
4629					Precipitation: Drop class 9	0	65535	-
4630					Precipitation: Drop class 10	0	65535	-
4631					Precipitation: Drop class 11	0	65535	-



Note: Which channels are actually available depends on the WSxxx-UMB type in use.



19.2 Channel List Summary per TLS2002 FG3

The following channels are available specifically for data requests for further processing in TLS format. These channels are only available in the UMB-Binary protocol.

DE Type	UMB Channel	Meaning	Format	Range	Resolution	Coding
48	1048	Result message Air Temperature LT	16 bit	-30 +60°C	0.1°C	60.0 = 600d = 0258h 0.0 = 0d = 0000h -0.1 = -1d = FFFFh -30.0 = -300d = FED4h
53	1053	Result message Precipitation Intensity NI	16 bit	0 200 mm/h	0.1 mm/h	0.0 = 0d = 0000h 200.0 = 2000d = 07D0h
54	1054	Result message Air Pressure LD	16 bit	8001200 hPa	1 hPa	800 = 800d = 0320h 1200 = 1200d = 04B0h
55	1055	Result message Relative Humidity RLF	8 bit	10% 100%	1% RH	10% = 10d = 0Ah 100% = 100d = 64h
56	1056	Result message Wind Direction WR	16 bit	0 359°	1°	0° (N) = 0d = 0000h 90° (O) = 90d = 005Ah 180° (S) = 180d = 00B4h 270° (W) = 270d = 010Eh FFFFh = not definable
57	1057	Result message Wind Speed. (average) WGM	16 bit	0.0 60.0 m/s	0.1 m/s	0.0 = 0d = 0000h 60.0 = 600d = 0258h
64	1064	Result message Wind Speed (peak) WGS	16 bit	0.0 60.0 m/s	0.1 m/s	0.0 = 0d = 0000h 60.0 = 600d = 0258h
66	1066	Result message Dewpoint Temperature TPT	16 bit	-30 +60°C	0.1°C	60.0 = 600d = 0258h 0.0 = 0d = 0000h -0.1 = -1d = FFFFh -30.0 = -300d = FED4h
71	1071	Result message Precipitation Type NS	8 bit			0 = No precipitation 40 = unspecified precipitation 60 = Liquid precipitation, e.g. rain 70 = Solid precipitation, e.g. snow WS100-UMB only: 67 = freezing rain 69 = sleet 90 = hail
90	1090	Result message Precipitation Intensity NI	16 bit	0 200 mm/h	0.1 mm/h	0.00 = 0d = 0000h 200.00 = 20000d = 4E20h



Note: Which channels are actually available depends on the WSxxx-UMB type in use. The previous channels 1153 and 1253 are no longer supported. Channels 840 and 860 can be used in their place.



19.3 Communication in Binary Protocol

Only one example of an online data request is described in this operating manual. Please refer to the current version of the UMB Protocol for all commands and the exact mode of operation of the protocol (available for download at www.lufft.com).



Note: Communication with the sensor takes place in accordance with the master-slave principle, i.e. there may only be ONE requesting unit on a network.

19.3.1 Framing

The data frame is constructed as follows:

1	2	3 - 4	5 - 6	7	8	9	10	11 (8 + len) optional	9 + len	10 + len 11 + len	12 + len
SOH	<ver></ver>	<to></to>	<from></from>	<len></len>	STX	<cmd></cmd>	<verc></verc>	<payload></payload>	ETX	<cs></cs>	EOT

SOH Control character for the start of a frame (01h); 1 byte Header version number, e.g.: V 1.0 → <ver> = 10h = 16d; 1 byte <ver> <to> Receiver address; 2 bytes <from> Sender address; 2 bytes <len> Number of data bytes between STX and ETX; 1 byte STX Control character for the start of payload transmission (02h); 1 byte <cmd> Command; 1 byte Version number of the command; 1 byte <verc> Data bytes; 0 - 210 bytes <payload> **ETX** Control character for the end of payload transmission (03h); 1 byte Check sum, 16 bit CRC; 2 bytes <CS>

EOT Control character for the end of the frame (04h); 1 byte Control characters: SOH (01h), STX (02h), ETX (03h), EOT (04h).

19.3.2 Addressing with Class and Device ID

Addressing takes place by way of a 16 bit address. This breaks down into a Class ID and a Device ID.

Ad	Address (2 bytes = 16 bit)										
Bit	s 15 – 12 (upper 4 bits)	Bits 11 – 8 (middle 4 bits)	Bits 7 – 0 (lov	ver 8 bits)							
Cla	ss ID (0 to 15)	Reserve	Device ID (0	– 255)							
0	Broadcast		0	Broadcast							
7	Smart Weather Sensor (WS200-UMB – WS600-UMB)		1 - 255	Available							
15	Master or control devices										

ID = 0 is provided as broadcast for classes and devices. Thus it is possible to transmit a broadcast on a specific class. However this only makes sense if there is only one device of this class on the bus; or in the case of a command, e.g. reset.



19.3.3 Examples for Creating Addresses

If, for example, you want to address WS400-UMB with the device ID 001, this takes place as follows:

The class ID for the Smart Weather Sensor is 7d = 7h;

the device ID is e.g. 001d = 001h

Putting the class and device IDs together gives the address 7001h (28673d).

19.3.4 Example of a Binary Protocol Request

If, for example, a Smart Weather Sensor with the device ID 001 is to be polled from a PC for the current temperature, this takes place as follows:

Sensor

The class ID for the Smart Weather Sensors 7 = 7h;

The device ID is 001 = 001h

Putting the class and device IDs together gives a target address of 7001h.

PC:

The class ID for the PC (master unit) is 15 = Fh;

the PC ID is e.g. 001d = 01h.

Putting the class and device IDs together gives a sender address of F001h.

The length <len> for the online data request command is 4d = 04h;

The command for the online data request is 23h;

The version number of the command is 1.0 = 10h.

The channel number is in <payload>; as can be seen from the channel list (page 77), the current temperature in °C in the channel is 100d = 0064h.

The calculated CRC is D961h.

The request to the device:

S	ОН	<ver></ver>	<t< th=""><th>0></th><th><frc< th=""><th>m></th><th><len></len></th><th>STX</th><th><cmd></cmd></th><th><verc></verc></th><th><cha< th=""><th>nnel></th><th>ETX</th><th><0</th><th>:S></th><th>EOT</th></cha<></th></frc<></th></t<>	0>	<frc< th=""><th>m></th><th><len></len></th><th>STX</th><th><cmd></cmd></th><th><verc></verc></th><th><cha< th=""><th>nnel></th><th>ETX</th><th><0</th><th>:S></th><th>EOT</th></cha<></th></frc<>	m>	<len></len>	STX	<cmd></cmd>	<verc></verc>	<cha< th=""><th>nnel></th><th>ETX</th><th><0</th><th>:S></th><th>EOT</th></cha<>	nnel>	ETX	<0	:S>	EOT
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
C)1h	10h	01h	70h	01h	F0h	04h	02h	23h	10h	64h	00h	03h	61h	D9h	04h

The response from the device:

SOH	<ver></ver>	<t< th=""><th>0></th><th><frc< th=""><th>m></th><th><len></len></th><th>STX</th><th><cmd></cmd></th><th><verc></verc></th><th><status></status></th><th><cha< th=""><th>nnel></th><th><typ></typ></th></cha<></th></frc<></th></t<>	0>	<frc< th=""><th>m></th><th><len></len></th><th>STX</th><th><cmd></cmd></th><th><verc></verc></th><th><status></status></th><th><cha< th=""><th>nnel></th><th><typ></typ></th></cha<></th></frc<>	m>	<len></len>	STX	<cmd></cmd>	<verc></verc>	<status></status>	<cha< th=""><th>nnel></th><th><typ></typ></th></cha<>	nnel>	<typ></typ>
1	2	3	4	5	6	7	8	9	10	11	12	13	14
01h	10h	01h	F0h	01h	70h	0Ah	02h	23h	10h	00h	64h	00h	16h

	<va< th=""><th>lue></th><th></th><th>ETX</th><th colspan="2"><cs></cs></th><th>EOT</th></va<>	lue>		ETX	<cs></cs>		EOT
15	16	17	18	19	20 21		22
00h	00h	B4h	41h	03h	C6h	22h	04h

Interpretation of the response:

<status> = 00h device o.k. (≠ 00h signifies error code; see page 83)

<typ> = Data type of the following value; 16h = float (4 bytes, IEEE format)

<value> = 41B40000h as a float value corresponds to 22.5

The temperature is therefore 22.5°C.

The correct data transmission can be checked with the aid of the check sum (22C6h).



Note: Little Endian (Intel, low byte first) applies when transmitting word and float variables of addresses or the CRC, for example. This means first the LowByte and then the HighByte.



19.3.5 Status and Error Codes in Binary Protocol

If a measurement request delivers the <status> 00h, the sensor is working correctly. You can find a complete list of additional codes in the description of the UMB protocol.

Extract from list:

<status></status>	Description
00h (0d)	Command successful; no error; all o.k.
10h (16d)	Unknown command; not supported by this device
11h (17d)	Invalid parameter
24h (36d)	Invalid channel
28h (40d)	Device not ready; e.g. initialization / calibration running
50h (80d)	Measurement variable (+offset) is outside the set display range
51h (81d)	
52h (82d)	Measurement value (physical) is outside the measuring range (e.g. ADC over range)
53h (83d)	
54h (84d)	Error in measurement data or no valid data available
55h (85d)	Device / sensor is unable to execute valid measurement due to ambient conditions

19.3.6 CRC Calculation

CRC is calculated according to the following rules:

Norm: CRC-CCITT

Polynomial: $1021h = x^{16} + x^{12} + x^5 + 1$ (LSB first mode)

Start value: FFFFh

You can find further information in the description of a CRC calculation in UMB Protocol.

19.3.7 Data Request in Power Saving Mode 2

When in power saving mode2 the processor of the Smart Weather Sensor will be usually in sleep state. For the acquisition of measurement data a certain command sequence and a certain timing is required:

- "Wake Up" bei sending a <Break>, any character or any telegram (a telegram will
 not be properly detected and get no response, because the UART is just starting)
- 1000msec pause for the processor start up
- Activation of the measurement cycle by (any) valid telegram addressed to this
 device
- 2000msec pause for the execution of the measurement sequence
- Request of the measurement results

Example of a Request Sequence:

Command Data Request (0x23), Channel 100

No response

Wait 1 sec

Command Data Request (0x23), Channel 100

Discard data

Wait 2 sec

CommandMultiData Request (0x2F), Ch. 100, 200, 300, 620, 605, 700 Store data





19.4 Communication in ASCII Protocol

Note: UMB-ASCII protocol is not recommended for new projects. New features and sensors will not be implemented for this protocol for devices newer than device version 223 (WS100-UMB device version 04).

Text-based communication with devices is possible using ASCII protocol.

To do this, in the device configuration, interface settings, the protocol mode must be set to ASCII (see page 36).

ASCII protocol is network-compatible and serves exclusively for online data requests. The device will not respond to incomprehensible ASCII commands.



Note: The use of binary protocol is recommended for lengthy transmission routes (e.g. network, GPRS/UMTS), as ASCII protocol is unable to detect transmission errors (not CRC-secured).



Note: TLS channels are not available in ASCII protocol.

19.4.1 Structure

An ASCII command is introduced by the '&' character and completed by the CR (0Dh) sign. There is a space character (20h) between the individual blocks in each case; this is represented by an underscore character '_'. Characters that represent an ASCII value are in ordinary inverted commas.

19.4.2 Summary of ASCII Commands

Command	Function	вс	AZ
М	Online data request		I
Х	Switches to binary protocol		k
R	Triggers software reset	•	k
D	Software reset with delay	•	k
I	Device information		k

These operating instructions describe the online data request only. You can find the description of the other commands in the UMB protocol.

19.4.3 Online Data Request (M)

Description: By way of this command, a measurement value is requested from a specific channel.

Request: '&' <ID>5 'M' <channel>5 CR

Response: '\$'_<ID>5_'M'_<channel>5_<value>5 CR

<ID>5 Device address (5 decimal places with leading zeros)

<channel>5 Indicates the channel number (5 decimal places with leading zeros)

<*value*>⁵ Measurement value (5 decimal places with leading zeros); a measurement

value standardized to 0 - 65520d. Various error codes are defined from

65521d - 65535d.

Example:

Request: &_28673_M_00100

By way of this request, channel 100 of the device with address 28673 is interrogated (Smart Weather Sensor with device ID 001).

Response: \$_28673_M_00100_34785

This channel outputs a temperature from -50 to +60°C, which is calculated as follows:

0d corresponds to -50°C 65520d corresponds to +60°C

36789d corresponds to $[+60^{\circ}\text{C} - (-50^{\circ}\text{C})] / 65520 * 34785 + (-50^{\circ}\text{C}) = 8.4^{\circ}\text{C}$

Note: TLS channels are not available in ASCII protocol.





19.4.4 Standardization of Measurement Values in ASCII Protocol

The standardization of measurement values from 0d-65520d corresponds to the measuring range of the respective measurement variable.

range of the respective mea					
Measurement Variable	Measuring Range				
Tammavatura	Min	Max	Unit		
Temperature Temperature	-50.0	60.0	°C		
Dew point			_		
Wet Bulb Temperature	-58.0	140.0	°F		
External Temperature	-40.0	80.0	°C		
,	-40.0	176.0	°F		
Wind chill temperature	-60.0	70.0	°C °F		
Humidity	-76.0	158.0	7		
Relative humidity	0.0	100.0	%		
Absolute humidity			g/m³		
Mixing ratio	0.0	1000.0	g/kg		
Specific Enthalpy	-100.0	1000.0	kJ/kg		
Pressure					
Relative air pressure Absolute air pressure	300.0	1200.0	hPa		
Air Density					
air density	0.0	3.0	kg/m³		
Wind	T	T			
	0.0	75.0	m/s		
Wind speed	0.0	270.0	km/h		
·	0.0	167.8	mph		
	0.0	145.8	kts °		
Wind direction	0.0	359.9			
wind value quality 0.0 100.0 %					
Kalli	0.0	6552.0	litres / m²		
	0.0	6552.0	mm		
Quantity	0.0	257.9	inches		
	0.0	257952.7	mil		
	0.0	655.2	litres / m²		
	0.0	655.2	mm		
Quantity since last request	0.0	25.79	inches		
	0.0	25795.2	mil		
Precipitation type	0 = No precipitation 40 = Precipitation 60 = Liquid precipitation, e.g. rain 70 = Solid precipitation, e.g. snow WS100-UMB only: 67 = freezing rain 69 = sleet 90 = hail				
	0.0	200.0	l/m²/h		
Precipitation intensity	0.0	200.0	mm/h		
	0.0	7.874	in/h		
	0.0	7874	mil/h		
Global Radiation Global Radiation until device version .049 / .212	0.0	1400.0	W/m²		
Global Radiation from device version .050 / .213 (software version > v5.6)	0.0	2000.0	W/m²		
Lightning Sensor		ı			
<u> </u>					
Lightning events (min)	0	255	-		





19.4.5 Error Codes in the ASCII Protocol

Various error codes are defined from 65521d – 65535d in addition to the standardisation for the transmission of measurement values.

<code></code>	Description
65521d	Invalid Channel
65523d	Value Overflow
65524d	Value Underflow
65525d	Error in measurement data or no valid data available
65526d	Device / sensor is unable to execute valid measurement due to ambient conditions
65534d	Invalid Calibration
65535d	Unknown Error



19.5 Communication in Terminal Mode

It is possible to communicate with a device in a very simple text-based manner using the terminal mode.

To do this, in the device configuration, interface settings, the protocol mode must be set to terminal (see page 36).



Note: In the case of communication in the terminal mode, only one single unit may be connected to the interface, as this protocol is **NOT** network-compatible. It is used for very simple measurement value requests.



Note: The use of binary protocol is recommended for lengthy transmission routes (e.g. network, GPRS/UMTS), as it is not possible to detect transmission errors in terminal mode (not CRC-secured).



Note: In the terminal mode, measurement values are not available in all units. Furthermore, status and error messages are not transmitted.

19.5.1 Structure

A terminal consists of an ASCII character and a numeric character. The command is completed with the <CR> sign. There is no echo on entry.

The individual values in the response are separated by a semi-colon (;). The response is completed with <CR><LF>.

An invalid terminal command is acknowledged with 'FAILED'. Control commands are acknowledged with 'OK'.

The command to which the response relates is given at the beginning of each response.

Note: No response times are specified in the terminal mode.





19.5.2 Terminal Commands

The terminal commands transmit the following values or have the following functions:

E0 <cr></cr>	Temperature in °C Dew point temperature in °C Wind chill temperature in °C Relative humidity in % Relative air pressure in hPa Wind speed in m/s Wind direction in ° Precipitation quantity in mm Precipitation type Precipitation intensity in mm/h	Ta Tp Tw Hr Pa Sa Da Ra Rt Ri		(Channel 100) (Channel 110) (Channel 111) (Channel 200) (Channel 305) (Channel 400) (Channel 500) (Channel 620) (Channel 700) (Channel 820)
E1 <cr></cr>	Temperature in °F Dew point temperature in °F Wind chill temperature in °F Relative humidity in % Relative air pressure in hPa Wind speed in mph Wind direction in ° Precipitation quantity in inches Precipitation intensity in inches/h	Ta Tp Tw Hr Pa Sa Da Ra Rt Ri	F F P H S D I N I	(Channel 105) (Channel 115) (Channel 116) (Channel 200) (Channel 305) (Channel 410) (Channel 500) (Channel 640) (Channel 700) (Channel 840)
E2 <cr></cr>	Act. wind speed in m/s Min. wind speed in m/s Max. wind speed in m/s Avg. wind speed in m/s Vct. wind speed in m/s Act. wind direction in ° Min. wind direction in ° Vct. wind direction in ° Vct. wind direction in °	Sa Sn Sx Sg Sv Da Dn Dx	M M M M D D	(Channel 400) (Channel 420) (Channel 440) (Channel 460) (Channel 480) (Channel 500) (Channel 520) (Channel 540) (Channel 580)
E3 <cr></cr>	Act. wind speed in mph Min. wind speed in mph Max. wind speed in mph Avg. wind speed in mph Vct. wind speed in mph Act. wind direction in ° Min. wind direction in ° Vectorial wind direction in °	Sa Sn Sx Sg Sv Da Dn Dx	\$ \$ \$ \$ \$ D D D	(Channel 410) (Channel 430) (Channel 450) (Channel 470) (Channel 490) (Channel 500) (Channel 520) (Channel 540) (Channel 580)
E4 <cr></cr>	Act. Compass heading in ° Act. Global Radiation in W/m² Min. Global Radiation in W/m² Max. Global Radiation in W/m² Avg. Global Radiation in W/m² Act. Specific Enthalpy in KJ/Kg Act. Wet Bulb Temperature in °C Act. Wet Bulb Temperature in °F Act. Air Density in kg/m³	Ca Ga Gn Gx Gg Ea Ba Ad	D W W W J C F G	(Channel 510) (Channel 900) (Channel 920) (Channel 940) (Channel 960) (Channel 215) (Channel 114) (Channel 119) (Channel 310)
E5 <cr></cr>	reserved reserved external temperature (act) °C external temperature (act) °F lightning events (min) lightning events (interval)	La Lb Te Te Lm Li	X X C F E	(Channel 710) (Channel 711) (Channel 101) (Channel 106) (Channel 617) (Channel 677)



E9 <cr>*</cr>	precipitation total particles	Τt	-	(Channel 4600)
	precipitation total drops	Td	-	(Channel 4601)
	precipitation drizzle particles	Dr	-	(Channel 4602)
	precipitation snow particles	Sn	-	(Channel 4603)
	precipitation hail particles	Ha	-	(Channel 4604)
	precipitation drop class 0	C0	-	(Channel 4620)
	precipitation drop class 1	C1	-	(Channel 4621)
	precipitation drop class 2	C2	-	(Channel 4622)
	precipitation drop class 3	C3	-	(Channel 4623)
	precipitation drop class 4	C4	-	(Channel 4624)
	precipitation drop class 5	C5	-	(Channel 4625)
	precipitation drop class 6	C6	-	(Channel 4626)
	precipitation drop class 7	C7	-	(Channel 4627)
	precipitation drop class 8	C8	-	(Channel 4628)
	precipitation drop class 9	C9	-	(Channel 4629)
	precipitation drop class 10	C10	-	(Channel 4630)
	precipitation drop class 11	C11	-	(Channel 4631)

Mx <cr></cr>	Displays the same values as ${\tt Ex},$ but without additional information such as the measurement variable and unit
IO <cr></cr>	Serial number; date of manufacture; project number; parts list version; SPLAN version; hardware version; firmware version; E2 version; device version
I1 <cr></cr>	Outputs the device description
R0 <cr> R1<cr></cr></cr>	Executes a device reset Resets the accumulated rain quantity and executes a device reset
X0 <cr></cr>	Temporarily switches to UMB binary protocol

^{*)} Command E9/M9 is only supported by WS100-UMB

Examples:

E0 <cr></cr>	E0;Ta+024.9C;Tp+012.2C;Tw+026.8C;Hr+045.0P;Pa+0980.6H; Sa+005.1M;Da+156.6D;Ra+00042.24M;Rt+060N;Ri+002.63M;
M0 <cr></cr>	M0;+024.9;+012.2;+026.8;+045.0;+0980.6; +005.1;+156.6;+00042.24;+060;+002.63;
E2 <cr></cr>	E2;Sa+005.1M;Sn+001.1M;Sx+007.1M;Sg+005.1M;Sv+005.0M; Da+156.6D;Dn+166.6D;Dx+176.6D;Dv+156.6D;
M2 <cr></cr>	M2;+005.1;+001.1;+007.1;+005.1;+005.0; +156.6;+166.6;+176.6;+156.6;
I0 <cr></cr>	I0;001;0109;0701;004;005;001;016;011;00002; <cr><lf></lf></cr>
R0 <cr></cr>	R0;OK; <cr><lf></lf></cr>



19.6 Communication in SDI-12 Mode


The communication in the SDI-12 mode of the Smart Weather Sensor is conforming to the standard defined in ,SDI-12 A Serial-Digital Interface Standard for Microprocessor-Based Sensors Version 1.3 January 12, 2009'. WS100-UMB also supports SDI-12 Version 1.4 beginning from firmware version v2.4. The device may be operated in bus mode together with other SDI-12 sensors, connected to one SDI master (logger).

19.6.1 Preconditions for SDI-12 Operation


As the interface settings defined in the SDI-12 standard are significantly different from the UMB default settings the related parameters have to be set properly by the UMB-ConfigTool.NET (latest version!).


The protocol mode of the device has to be set to "SDI-12", baudrate to 1200Bd and (for WS100 only) parity to 7E1.

Figure 43: Sensor Configuration SDI-12



Measurement data can be transmitted alternatively in metric or US units. The selection is done by the UMB Config Tool.





Metric units, US units




Note: Please observe drawings on next page and notes on page 30 when connecting a SDI12 data logger!



When operating the device in SDI-12 mode it is basically no more possible to access the device with the UMB Config Tool, due to the different interface parameter settings. To enable configuration access nevertheless the interface is operated in standard UMB mode (19200 8N1) for the first 5 seconds(*) after reset / power on. During this time the UMB device ID, if unequal 1, is set to 200 (WS100: always 200, even when original ID = 1), so access will be possible even if the device ID is unknown. If a valid UMB telegram is received within this 5 sec, the device will stay in UMB mode for the configured time out (several minutes) so that the configuration can be modified.

- Connect the PC to the Smart Weather Sensor through an RS-485 converter
- Start the UMB Config Tool and create a WSxxx-UMB with the address (1 or 200) of the actual device and activate at least one sensor. Start the measurement (will report connection error at first)
- Reset the device (Power off / on)
- When measurement values are received the measurement can be terminated, the interface is now open for configuration.



This timing only applies in case of cold start after power on or reset. This phase will not occur after "wake up" in Power Saving Mode 2. In this case the device will respond within the time defined by the SDI12 standard.

Figure. 45: Connecting to a logger with

integrated power supply




Figure. 46: Connecting to a logger and a separate power supply up to device version 41





Figure. 47: Connecting to a logger and a separate power supply device version 42 and newer, all WS100





19.6.2 Command Set



For details of the SDI-12 protocol please refer to the above mentioned standard document.

The commands listed in following table are available for devices of the WS family. The links in table column "details" guide you to the description of buffer contents and additional functions.

The composition of the minimal and the full basic data set depends on the variant (WS100-UMB ... WS800-UMB) of the device in question (see below). The same applies to the availability of the additional measurement commands (aM1!, aC1! etc.)

Due the applied measurement processes the devices of the WS family will, different from other sensors described in the SDI-12 document, in **normal operation mode** always measure continuously. This causes some special properties while in this mode:

- The device does not need a "Wakeup" and does not have a sleep mode. So the reactions to "Break" signals and any related timings are inapplicable. "Break" will be ignored by WS devices.
- Data requested with M- or C- commands are always available immediately. The
 device will always respond with a000n resp. a000nn. This means the device will not
 send any service request and will ignore measurement abort signals. The logger
 should request the data immediately.
- M- and C- command only differ in the number of values made available in the buffers (in both cases the maximum permitted by the standards of 9 resp. 20).
- We recommend to use the commands for continuous measurement (R-commands) to request the data.
- When in **power saving mode 2** the device will wake up by a "Break" signal. Other functions of the "Break" signal are not implemented.
- When in power saving mode 2 the device responds to M or C commands with a002n resp. a002nn and holds the data available within 2 seconds. It will not send a service request, signals to abort the measurement are ignored.
- For the reduced data set in power saving mode 2 a unified data buffer structure for all device models has been defined. Depending on the individual model unused channels will be set to the "invalid" marker 999.9.

Command	Function	Details
?!	Address search (Wildcard request, one device only on bus!)	Standard
a!	Request device active?	Standard
al!	Request device identification	<u>all</u>
aAb!	Address change to b (0 9, AZ, a z)	Standard
аМ!	Measurement basic minimal data set	WS 600/700/800, 500, 400, 300, 200, 100, 501-510, 301-310, 601, 401, PSM 2 all
aM1!	Measurement temperatures	<u>all</u>
aM2!	Measurement humidity	all
aM3!	Measurement air pressure	all
aM4!	Measurement wind	all
aM5!	Measurement compass	<u>all</u>
aM6!	Measurement precipitation	all
aM7!	Measurement global radiation	all
aM8!	Measurement external temperature	all
aMC!	Measurement, basic minimal data set, transmit values with CRC	see aM!
aMC1! aMC8!	Measurement (assignment of values as for aMn! commands), transmit values with CRC	see aM1! aM8!
aC!	Concurrent measurement, full basic data set	see aM1!



Command	Function	Details
aC1! aC8!	Concurrent measurement, assignment of values as for aMn! commands, partly extended data sets	see aM1! aM8!
aCC!	Concurrent measurement, transmit values with CRC	see aM!
aCC1! aCC8!	Concurrent measurement, assignment of values as for aMn! commands, partly extended data sets, transmit values with CRC	see aM1! aM8!
aD0!	Data request buffer 0	Standard
aD1!	Data request buffer 1	Standard
aD2!	Data request buffer 2	Standard
aD3!	Data request buffer 3	Standard
aD4!	Data request buffer 4	Standard
aR0!	Data request from continuous measurement, data set 0	WS <u>600/700/800</u> , <u>500</u> , <u>400</u> , <u>300</u> , <u>200</u> , <u>100</u> , <u>501-510</u> , <u>301-310</u> , <u>601</u> , <u>401</u> , <u>PSM 2</u> <u>all</u>
aR1!	Data request from continuous measurement, data set 1	see R0!
aR2!	Data request from continuous measurement, data set 2	see R0!
aR3!	Data request from continuous measurement, data set 3	see R0!
aR4!	Data request from continuous measurement, data set 4	see R0!
aRC0!	Data request from cont. meas., data set 0 with CRC	see R0!
aRC1!	Data request from cont. meas., data set 0 with CRC	see R0!
aRC2!	Data request from cont. meas., data set 0 with CRC	see R0!
aRC3!	Data request from cont. meas., data set 0 with CRC	see R0!
aRC4!	Data request from cont. meas., data set 0 with CRC	see R0!
aV!	Command verification: Evaluate sensor status and heating temperatures, data request with aD0!, aD1!	all
aXU <m u="">!</m>	Change the unit system for SDI data	<u>all</u>
aXH+nnnn!	Set local altitude of the device for calculation of rel. air pressure	all
aXD+nnn.n!	Set local compass deviation	<u>all</u>
aXL <n s="" w="">!</n>	Set power saving mode	<u>all</u>
aXMn!	Set the heating mode of the device	<u>all</u>
aXA <t p="" w="">+nn!</t>	Integration time for average and min/max evaluation	<u>all</u>
aXC!	Clear the abs. precipitation amount (includes a device reset)	all
aXR!	Device reset	<u>all</u>
	WS100-UMB beginning from device version v2.4 (SDI-12 v1.4)	
alM!, alMC!	Request number of measurement values	<u>WS100</u>
alMn!, alMCn!		
alC!, alCC! alCN!, alCCn!		
alVn!		
alM_00m!,alMC_00m!	Request measurement value identification	WS100
alMn_00m!,alMCn_00m!		
alC_00n!, alCC_00n!		
alCn_00m!,alCCn_00m! alR_00n!, alV_00n		
ant_oon;, arv_oon		



19.6.3 Address Configuration

UMB Device-ID and SDI-12 Address are connected, but the different address ranges and the fact, that UMB ID's are integer numbers, while SDI-12 addresses are ASCII characters, have to be considered.

The SDI-12 address is built from the UMB device ID as follows:

UMB Device ID 1 (default) corresponds to SDI-12 Address '0' (SDI-12 default).

Changing the SDI12 address by SDI12 setting command also modifies the UMB device ID accordingly.

Valid Address Ranges:

UMB (dec)			SI	DI-12 (ASC	II)
1	to	10	'0'	to	' 9'
18	to	43	'A'	to	ʻZ'
50	to	75	ʻa'	to	'z'



19.6.5 Data Messages

In the interest of simplified evaluation the assignment of measurement values to data buffers '0' ... '9' has been defined unified for all measurement commands. For this reason the responses to C-requests have been restricted to 35 characters, not using the 75 characters permitted for these requests

Currently buffers '0' to '4' are in use.

As with M-requests max. 9 values may be transmitted; the base data set of 9 values has been assigned to buffers '0' and '1'. Buffers '2' to '4' contain further measurement values. This definition guaranties the compatibility to loggers designed according to older versions of the SDI-12 standard.

The buffer assignment depends on the device variant (WS100-UMB ... WS800-UMB).

The complete set of measurement values, as defined for the UMB protocol has been made available also in the SDI-12 environment. They can be accessed using the additional M and C commands (aM1! ... aM8!, aMC1! ... aMC8!, aC1! ... aC8!, aCC1! ... aCC8!) (see below).

If the measurement value is not available for some reason, e.g. sensor failure, this is indicated by a value of +999.0. or -999.9 The logger can then evaluate the reason of failure by a aV! Verification request. The following tables show the measurement values in the sequence they are arranged in the telegram (see example).

Depending on the configuration of the device the values will be transmitted in metric or US units.



Note: The configured system of units is not indicated in the data messages. The logger may request this setting with the I-command and adjust the evaluation of the data messages accordingly



Note: The examples in the following sections use italics to print the requests from the logger (OV!)

Example: M Request from a WS600-UMB

0M!

00009<CR><LF>

9 measurement values are available

0D0!

0+13.5+85.7+1017.0+2.5+3.7<CR><LF>

Air temperature 13.5°C, rel. humidity 85.7%, rel. air pressure 1017hPa avg. wind speed 2.5m/s, max wind speed 3.7m/s.

0D1!

0+43.7+9.8+60+4.4<CR><LF>

Wind direction 43.7° wet bulb temperature 9.8°C, type of precipitation 60 (rain), precipitation intensity 4.42mm/h



Example: C Request from a WS600-UMB

0C!

000020<CR><LF>

20 measurement values are available

0D0!

0+13.5+85.7+1017+2.5+3.7<CR><LF>

air temperature 13.5°C, rel. humidity 85.7%, rel. air pressure 1017hPa avg. wind speed 2.5m/s, max wind speed 3.7m/s.

0D1!

0+43.7+9.8+60+4.4<CR><LF>

wind direction 43.7° wet bulb temperature 9.8°C, type of precipitation 60 (rain), precipitation intensity 4.42mm/h

0D2!

0+11.2+10.3+1.10<CR><LF>

dewpoint 11.2°C, wind chill temperature 10,3°C diff. precipitation 1.10mm

0D3!

0+3.2+0.0+3.5+100.0<CR><LF>

act. wind speed 3,2m/s, min. wind speed 0.0 m/s vect. avg. wind speed 3.5m/s, quality of wind values 100%

0D4!

0+43.7+41.3+45.7+29.3<CR><LF>

act. wind direction 43,7°, min. wind direction 41,3°, max. wind direction 45,7°, specific enthalpy29,3kJ/kg



19.6.5.1 Buffer assignment Basic Data Set WS600-UMB / WS700-UMB / WS800-UMB

Device configured for measurement values in metric units:

Measurement value	UMB Channel	Min	Max	Unit
Buffer '0'				
Air temperature (act)	100	-50.0	60.0	°C
Rel. Humidity (act)	200	0.0	100.0	%
Rel. Air Pressure	305	300.0	1200.0	hPa
Wind Speed (avg)	460	0.0	75.0	m/s
Wind Speed (max)	440	0.0	75.0	m/s
Buffer '1'				
Wind Direction (vct)	580	0.0	359.9	0
Wet Bulb Temperature (act)	114	-50.0	60.0	°C
Precipitation Type	700	0, 60, 70)	
Precipitation Intensity	820	0.00	200.00	mm/h
Buffer '2'				
Dew Point (act)	110	-50.0	60.0	°C
Wind chill Temperature (act)	111	-60.0	70.0	°C
Amount of Precip. difference	625	0.00	100000.00	mm
Buffer '3'				
Wind Speed (act)	400	0.0	75.0	m/s
Wind Speed (min)	420	0.0	75.0	m/s
Wind Speed (vct)	480	0.0	75.0	m/s
Wind Quality	805	0.0	100.0	%
Buffer '4'				
Wind Direction (act)	500	0.0	359.9	0
Wind Direction (min)	520	0.0	359.9	0
Wind Direction (max)	540	0.0	359.9	o
Specific Enthalpy (act)	215	-100.0	1000.0	kJ/kg

Example: Request Buffer '0'

0D0!

0+13.5+85.7+2.5+3.7<CR><LF>

Air Temperature 13.5°C, rel. Humidity 85.7%, average wind speed 2.5m/s, peak wind speed 3.7m/s



Device configured for measurement values in US units:

Measurement Value	UMB Channel	Min	Max	Unit	
Buffer '0'					
Air Temperature (act)	105	-58.0	140.0	°F	
Rel. Humidity (act)	200	0.0	100.0	%	
Rel. Air Pressure	305	300.0	1200.0	hPa	
Wind Speed (avg)	470	0.0	167.8	mph	
Wind Speed (max)	450	0.0	167.8	mph	
Buffer '1'					
Wind Direction (vct)	580	0.0	359.9	0	
Wet Bulb Temperature (act)	119	-58.0	140.0	°F	
Precipitation Type	700	0, 60, 70			
Precipitation Intensity	840	0.0000	7.8740	in/h	
Buffer '2'					
Dew Point (act)	115	-58.0	140.0	°F	
Wind chill Temperature (act)	116	-76.0	158.0	°F	
Amount of Precip. difference	645	0.0000	3937.0000	in	
Buffer '3'					
Wind Speed (act)	410	0.0	167.8	mph	
Wind Speed (min)	430	0.0	167.8	mph	
Wind Speed (vct)	490	0.0	167.8	mph	
Wind Quality	805	0.0	100.0	%	
Buffer '4'					
Wind Direction(act)	500	0.0	359.9	0	
Wind Direction (min)	520	0.0	359.9	0	
Wind Direction (max)	540	0.0	359.9	0	
Specific Enthalpy (act)	215	-100.0	1000.0	kJ/kg	



19.6.5.2 Buffer Assignment Basic Data Set WS500-UMB

Device configured for measurement values in metric units:

Measurement value	UMB Channel	Min	Max	Unit
Buffer '0'				
Air temperature (act)	100	-50.0	60.0	°C
Rel. Humidity (act)	200	0.0	100.0	%
Rel. Air Pressure	305	300.0	1200.0	hPa
Wind Speed (avg)	460	0.0	75.0	m/s
Wind Speed (max)	440	0.0	75.0	m/s
Buffer '1'				
Wind Direction (vct)	580	0.0	359.9	0
Wet Bulb Temperature (act)	114	0.0	359.9	°C
Dew Point (act)	110	-50.0	60.0	°C
Wind chill Temperature (act)	111	-60.0	70.0	°C
Buffer '2'				
Wind Speed (act)	400	0.0	75.0	m/s
Wind Speed (min)	420	0.0	75.0	m/s
Wind Speed (vct)	480	0.0	75.0	m/s
Wind Quality	805	0.0	100.0	%
Buffer '3'				
Wind Direction (act)	500	0.0	359.9	0
Wind Direction (min)	520	0.0	359.9	o
Wind Direction (max)	540	0.0	359.9	0
Specific Enthalpy (act)	215	-100.0	1000.0	kJ/kg

Example: Request Buffer '0'

0D0!

0+13.5+85.7+2.5+3.7<CR><LF>

 $\hbox{Air Temperature 13.5°C, rel. Humidity 85.7\%, average wind speed 2.5m/s, peak wind speed 3.7m/s } \\$



Device configured for measurement values in US units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Air Temperature (act)	105	-58.0	140.0	°F
Rel. Humidity (act)	200	0.0	100.0	%
Rel. Air Pressure	305	300.0	1200.0	hPa
Wind Speed (avg)	470	0.0	167.8	mph
Wind Speed (max)	450	0.0	167.8	mph
Buffer '1'				
Wind Direction (vct)	580	0.0	359.9	o
Wet Bulb Temperature (act)	119	-58.0	140.0	°F
Dew Point (act)	115	-58.0	140.0	°F
Wind chill Temperature (act)	116	-76.0	158.0	°F
Buffer '2'				
Wind Speed (act)	410	0.0	167.8	mph
Wind Speed (min)	430	0.0	167.8	mph
Wind Speed (vct)	490	0.0	167.8	mph
Wind Quality	805	0.0	100.0	%
Buffer '3'				
Wind Direction(act)	500	0.0	359.9	0
Wind Direction (min)	520	0.0	359.9	o
Wind Direction (max)	540	0.0	359.9	o
Specific Enthalpy (act)	215	-100.0	1000.0	kJ/kg



19.6.5.3 Buffer Assignment Basic Data Set WS400-UMB

Device configured for measurement in metric units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Air Temperature (act)	100	-50.0	60.0	°C
Rel. Humidity (act)	200	0.0	100,0	%
Dew Point (act)	110	-50.0	60.0	°C
Abs. Air Pressure(act)	300	300.0	1200.0	hPa
Rel. Air Pressure (act)	305	300.0	1200.0	hPa
Buffer '1'				
Precipitation Type	700	0, 60, 70)	
Precipitation Intensity	820	0.00	200.00	mm/h
Amount of Precip. Difference	625	0.00	100000.00	mm
Amount of Precip. Absolute	620	0.0	100000.0	mm
Buffer '2'				
Air Temperature (min)	120	-50.0	60.0	°C
Air Temperature (max)	140	-50.0	60.0	°C
Air Temperature (avg)	160	-50.0	60.0	°C
Rel. Humidity (min)	220	0.0	100.0	%
Rel. Humidity (max)	240	0.0	100.0	%
Buffer '3'				
Rel. Humidity (avg)	260	0.0	100.0	%
Rel. Air Pressure(min)	325	300.0	1200.0	hPa
Rel. Rel. Humidity (max)	345	300.0	1200.0	hPa
Rel. Rel. Humidity (avg)	365	300.0	1200.0	hPa
Wet Bulb Temperature (act)	114	-50.0	60.0	°C
Specific Enthalpy (act)	215	-100.0	1000.0	kJ/kg

Example: Request Buffer '0'

0D0!

0+13.5+85.7+11.2+1017.0+1001.0

Air temperature 13.5°C, rel. humidity 85.7%, dew point 11.2°C, rel. air pressure 1017.0hPa, abs. pressure 1001.0hPa



Device configured for measurement in US units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Air Temperature (act)	105	-58.0	140.0	°F
Rel. Humidity (act)	200	0.0	100.0	%
Dew Point (act)	115	-58.0	14.0	°F
Abs. Air Pressure(act)	300	300.0	1200.0	hPa
Rel. Air Pressure (act)	305	300.0	1200.0	hPa
Buffer '1'				
Precipitation Type	700	0, 60, 70)	
Precipitation Intensity	840	0.0000	7.8740	in/h
Amount of Precip. Difference	645	0.0000	3937.0000	in
Amount of Precip. Absolute	640	0.000	3937.000	in
Buffer '2'				
Air Temperature (min)	125	-58.0	140.0	°F
Air Temperature (max)	145	-58.0	140.0	°F
Air Temperature (avg)	165	-58.0	140.0	°F
Rel. Humidity (min)	220	0.0	100.0	%
Rel. Humidity (max)	240	0.0	100.0	%
Buffer '3'				
Rel. Humidity (avg)	260	0.0	100.0	%
Rel. Air Pressure(min)	325	300.0	1200.0	hPa
Rel. Rel. Humidity (max)	345	300.0	1200.0	hPa
Rel. Rel. Humidity (avg)	365	300.0	1200.0	hPa
Wet Bulb Temperature (act)	119	-58.0	140.0	°F
Specific Enthalpy	215	-100.0	1000.0	kJ/kg



19.6.5.4 Buffer Assignment Basic Data Set WS300-UMB

Device configured for measurement in metric units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Air Temperature (act)	100	-50.0	60.0	°C
Rel. Humidity (act)	200	0.0	100.0	%
Dew Point (act)	110	-50.0	60.0	°C
Abs. Air Pressure(act)	300	300.0	1200.0	hPa
Rel. Air Pressure (act)	305	300.0	1200.0	hPa
Buffer '1'				
Air Temperature (min)	120	-50.0	60.0	°C
Air Temperature (max)	140	-50.0	60.0	°C
Air Temperature (avg)	160	-50.0	60.0	°C
Rel. Humidity (avg)	260	0.0	100.0	%
Buffer '2'				
Rel. Humidity (min)	220	0.0	100,0	%
Rel. Humidity (max)	240	0.0	100,0	%
Rel. Air Pressure (min)	325	300.0	1200.0	hPa
Rel. Air Pressure (max)	345	300.0	1200.0	hPa
Rel. Air Pressure (avg)	365	300.0	1200.0	hPa
Buffer '3'				
Abs. Humidity (min)	225	0.0	1000.0	g/m³
Abs. Humidity (max)	245	0.0	1000.0	g/m³
Abs. Humidity (avg)	265	0.0	1000.0	g/m³
Buffer '4'				
Wet Bulb Temperature (act)	114	-50.0	60.0	°C
Specific Enthalpy (act)	215	-100.0	1000.0	kJ/kg

Example: Request buffer '0'

0D0!

0+13.5+85.7+11.2+1017.0+1001.0

Air temperature 13.5°C, rel. humidity 85.7%, dew point 11.2°C, rel. air pressure 1017.0hPa, abs. pressure 1001.0hPa



Device configured for measurement in US units:

Measurement Value	UMB Channel	Min	Max	Unit	
Buffer '0'					
Air Temperature (act)	105	-58.0	140.0	°F	
Rel. Humidity (act)	200	0.0	100.0	%	
Dew Point (act)	115	-58.0	140.0	°F	
Abs. Air Pressure(act)	300	300.0	1200.0	hPa	
Rel. Air Pressure (act)	305	300.0	1200.0	hPa	
Buffer '1'					
Air Temperature (min)	125	-58.0	140.0	°F	
Air Temperature (max)	145	-58.0	140.0	°F	
Air Temperature (avg)	165	-58.0	140.0	°F	
Rel. Humidity (avg)	260	0.0	100.0	%	
Buffer '2'					
Rel. Humidity (min)	220	0.0	100,0	%	
Rel. Humidity (max)	240	0.0	100,0	%	
Rel. Air Pressure (min)	325	300.0	1200.0	hPa	
Rel. Air Pressure (max)	345	300.0	1200.0	hPa	
Rel. Air Pressure (avg)	365	300.0	1200.0	hPa	
Buffer '3'					
Abs. Humidity (min)	225	0.0	1000.0	g/m³	
Abs. Humidity (max)	245	0.0	1000.0	g/m³	
Abs. Humidity (avg)	265	0.0	1000.0	g/m³	
Buffer '4'					
Wet Bulb Temperature (act)	119	-58.0	140.0	°F	
Specific Enthalpy (act)	215	-100.0	1000.0	kJ/kg	



19.6.5.5 Buffer Assignment Basic Data Set WS200-UMB

Device configured for measurement values in metric units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Wind Speed (avg)	460	0.0	75.0	m/s
Wind Speed (max)	440	0.0	75.0	m/s
Wind Direction (vct)	580	0.0	359.9	0
Wind Direction (act)	500	0.0	359.9	0
Compass Heading(act)	510	0.0	359.0	0
Buffer '1'				
Wind Speed (act)	400	0.0	75.0	m/s
Wind Speed (min)	420	0.0	75.0	m/s
Wind Speed (vct)	480	0.0	75.0	m/s
Wind Quality	805	0.0	100.0	%
Buffer '2'				
Wind Direction (min)	520	0.0	359.9	0
Wind Direction (max)	540	0.0	359.9	0
Wind Direction corr. (act)	502	0.0	359.9	0

Example: Request Buffer '0'

0D0!

0+2.5+3.7+45.5+37.8+10.3<CR><LF>

Avg. wind speed 2.5 m/s, peak wind speed 3.7 m/s, avg wind direction (vect.) 45.5° , wind direction (act.) 37.8° , compass heading 10.3°



Device configured for measurement values in US units:

Measurement Value	UMB Channel	Min	Max	Unit		
Buffer '0'						
Wind Speed (avg)	470	0.0	167.8	mph		
Wind Speed (max)	450	0.0	167.8	mph		
Wind Direction (vct)	580	0.0	359.9	0		
Wind Direction (act)	500	0.0	359.9	0		
Compass Heading(act)	510	0.0	359.0	0		
Buffer '1'						
Wind Speed (act)	410	0.0	167.8	mph		
Wind Speed (min)	430	0.0	167.8	mph		
Wind Speed (vct)	490	0.0	167.8	mph		
Wind Quality	805	0.0	100.0	%		
Buffer '2'	Buffer '2'					
Wind Direction (min)	520	0.0	359.9	0		
Wind Direction (max)	540	0.0	359.9	o		
Wind Direction corr. (act)	502	0.0	359.9	o		



19.6.5.6 Buffer Assignment Basic Data Set WS100-UMB

Device configured for measurement values in metric units

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Amount of Precip. absolute	620	0.0	100000.0	mm
Amount of Precip. difference	625	0.00	100000.00	mm
Precipitation Intensity	820	0.00	200.00	mm/h
Precipitation Type	700	0, 60, 70 (67, 69, 90)*		
Precipitation Int. (WS100 only)	825	0.0000	3.3333	mm/min
Buffer '1' (WS100 only)				
WMO Synop Code 4680 wawa	780	Code (see Ch. 6.15.1)		
WMO Synop Code 4680 WaWa	781	Code (see Ch. 6.15.1)		
WMO Synop Code 4677 ww	785	Code (see Ch. 6.15.1)		
WMO Synop Code 4680 WW	786	Code (see Ch. 6.15.1)		

^{)*} additional precipitation types: WS100-UMB only

Example: Request Buffer '0'

0D0!

0+23.5+0.2+3.24+60+0.0540<CR><LF>

Precipitation abs. 23,5mm, precipitation difference 0,2mm, precipitation intensity 3,2mm/h, precipitation type 60 (rain), precipitation intensity 0.0540mm/min

Device configured for measurement values in US units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Amount of Precip. absolute	640	0.000	3937.000	in
Amount of Precip. difference	645	0.0000	3937.0000	in
Precipitation Intensity	840	0.0000	7.8740	in/h
Precipitation Type	700	0, 60, 70 (67, 69, 90)*		
Precipitation Int. (WS100 only)	845	0.0000	0.13123	in/min
Buffer '1' (WS100 only)				
WMO Synop Code 4680 wawa	780	Code (see Ch. 6.15.1)		
WMO Synop Code 4680 WaWa	781	Code (see Ch. 6.15.1)		
WMO Synop Code 4677 ww	785	Code (see Ch. 6.15.1)		
WMO Synop Code 4680 WW	786	Code (see Ch. 6.15.1)		

^{)*} additional precipitation types: WS100-UMB only



19.6.5.7 Buffer Assignment Basic Data Set WS501-UMB, WS502-UMB, WS504-UMB, WS510-UMB

Device configured for measurement values in metric units:

Measurement value	UMB Channel	Min	Max	Unit
Buffer '0'				
Air temperature (act)	100	-50.0	60.0	°C
Rel. Humidity (act)	200	0.0	100.0	%
Rel. Air Pressure	305	300.0	1200.0	hPa
Wind Speed (avg)	460	0.0	75.0	m/s
Wind Speed (max)	440	0.0	75.0	m/s
Buffer '1'				
Wind Direction (vct)	580	0.0	359.9	o
Global Radiation (act)	900	0.0	2000.0 *)	W/m²
Dew Point (act)	110	-50.0	60.0	°C
Wind Chill Temperature (act)	111	-60.0	70.0	°C
Buffer '2'				
Wind Speed (act)	400	0.0	75.0	m/s
Wind Speed (min)	420	0.0	75.0	m/s
Wind Speed (vct)	480	0.0	75.0	m/s
Wind Quality	805	0.0	100.0	%
Buffer '3'				
Wind Direction (act)	500	0.0	359.9	0
Wet Bulb Temperature (act)	114	-50.0	60.0	°C
Specific Enthalpy (act)	215	-100.0	1000.0	kJ/kg
Buffer '4'				
Global Radiation (min)	920	0.0	2000.0 *)	W/m²
Global Radiation (max)	940	0.0	2000.0 *)	W/m²
Global Radiation (avg)	960	0.0	2000.0 *)	W/m²

^{*)} Until device version .49 / .212 / Firmware v5.6: 1400.0 W/m²

Example: Request Buffer '0'

0D0!

0+13.5+85.7+2.5+3.7<CR><LF>

Air Temperature 13.5°C, rel. Humidity 85.7%, average wind speed 2.5m/s, peak wind speed 3.7m/s



Device configured for measurement values in US units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Air Temperature (act)	105	-58.0	140.0	°F
Rel. Humidity (act)	200	0.0	100.0	%
Rel. Air Pressure	305	300.0	1200.0	hPa
Wind Speed (avg)	470	0.0	167.8	mph
Wind Speed (max)	450	0.0	167.8	mph
Buffer '1'				
Wind Direction (vct)	580	0.0	359.9	0
Global Radiation (act)	900	0.0	2000.0 *)	W/m²
Dew Point (act)	115	-58.0	140.0	°F
Windchill Temperature (act)	116	-76.0	158.0	°F
Buffer '2'				
Wind Speed (act)	410	0.0	167.8	mph
Wind Speed (min)	430	0.0	167.8	mph
Wind Speed (vct)	490	0.0	167.8	mph
Wind Quality	805	0.0	100.0	%
Buffer '3'				
Wind Direction(act)	500	0.0	359.9	0
Wet Bulb Temperature (act)	119	-58.0	140.0	°F
Specific Enthalpy (act)	215	-100.0	1000.0	kJ/kg
Buffer '4'				
Global Radiation (min)	920	0.0	2000.0 *)	W/m²
Global Radiation (max)	940	0.0	2000.0 *)	W/m²
Global Radiation (avg)	960	0.0	2000.0 *)	W/m²

^{*)} Until device version .49 / .212 / Firmware v5.6: 1400.0 W/m²



19.6.5.8 Buffer Assignment Basic Data Set WS301-UMB, WS302-UMB, WS304-UMB, WS310-UMB

Device configured for measurement in metric units:

Measurement Value	UMB Channel	Min	Max	Unit	
Buffer '0'					
Air Temperature (act)	100	-50.0	60.0	°C	
Rel. Humidity (act)	200	0.0	100.0	%	
Dew Point (act)	110	-50.0	60.0	°C	
Global Radiation(act)	900	0.0	2000.0 *)	W/m²	
Rel. Air Pressure (act)	305	300.0	1200.0	hPa	
Buffer '1'					
Air Temperature (min)	120	-50.0	60.0	°C	
Air Temperature (max)	140	-50.0	60.0	°C	
Air Temperature (avg)	160	-50.0	60.0	°C	
Rel. Humidity (avg)	260	0.0	100.0	%	
Buffer '2'					
Rel. Humidity (min)	220	0.0	100,0	%	
Rel. Humidity (max)	240	0.0	100,0	%	
Rel. Air Pressure (min)	325	300.0	1200.0	hPa	
Rel. Air Pressure (max)	345	300.0	1200.0	hPa	
Rel. Air Pressure (avg)	365	300.0	1200.0	hPa	
Buffer '3'					
Abs. Humidity (act)	205	0.0	1000.0	g/m³	
Wet Bulb Temperature (act)	114	-50.0	60.0	°C	
Specific Enthalpy (act)	215	-100.0	1000.0	kJ/kg	
Buffer '4'					
Global Radiation (min)	920	0.0	2000.0 *)	W/m²	
Global Radiation (max)	940	0.0	2000.0 *)	W/m²	
Global Radiation (avg) *) Until device version, 49 / 2	960	0.0	2000.0 *)	W/m²	

^{*)} Until device version .49 / .212 / Firmware v5. $\overline{6}$: 1400.0 W/m²

Example: Request buffer '0'

0D0!

0+13.5+85.7+11.2+1017.0+780.0

Air temperature 13.5°C, rel. humidity 85.7%, dew point 11.2°C, rel. air pressure 1017.0hPa, global radiation $780.0W/m^2$



Device configured for measurement in US units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Air Temperature (act)	105	-58.0	140.0	°F
Rel. Humidity (act)	200	0.0	100.0	%
Dew Point (act)	115	-58.0	140.0	°F
Global Radiation(act)	900	0.0	2000.0 *)	W/m²
Rel. Air Pressure (act)	305	300.0	1200.0	hPa
Buffer '1'				
Air Temperature (min)	125	-58.0	140.0	°F
Air Temperature (max)	145	-58.0	140.0	°F
Air Temperature (avg)	165	-58.0	140.0	°F
Rel. Humidity (avg)	260	0.0	100.0	%
Buffer '2'				
Rel. Humidity (min)	220	0.0	100,0	%
Rel. Humidity (max)	240	0.0	100,0	%
Rel. Air Pressure (min)	325	300.0	1200.0	hPa
Rel. Air Pressure (max)	345	300.0	1200.0	hPa
Rel. Air Pressure (avg)	365	300.0	1200.0	hPa
Buffer '3'				
Abs. Humidity (act)	205	0.0	1000.0	g/m³
Wet Bulb Temperature (act)	119	-58.0	140.0	°F
Specific Enthalpy (act)	215	-100.0	1000.0	kJ/kg
Buffer '4'				
Global Radiation (min)	920	0.0	2000.0 *)	W/m²
Global Radiation (max)	940	0.0	2000.0 *)	W/m²
Global Radiation (avg)	960	0.0	2000.0 *)	W/m²

^{*)} Until device version .49 / .212 / Firmware v5.6: 1400.0 W/m²



19.6.5.9 Buffer assignment Basic Data Set WS601-UMB

Device configured for measurement values in metric units:

Measurement value	UMB Channel	Min	Max	Unit
Buffer '0'				
Air temperature (act)	100	-50.0	60.0	°C
Rel. Humidity (act)	200	0.0	100.0	%
Rel. Air Pressure	305	300.0	1200.0	hPa
Wind Speed (avg)	460	0.0	75.0	m/s
Wind Speed (max)	440	0.0	75.0	m/s
Buffer '1'				
Wind Direction (vct)	580	0.0	359.9	0
reserved				
Precipitation Type	700	0, 40		
Precipitation Intensity	820	0.00	200.00	mm/h
Buffer '2'				
Dew Point (act)	110	-50.0	60.0	°C
Wind chill Temperature (act)	111	-60.0	70.0	°C
Amount of Precip. difference	625	0.00	100000.00	mm
Buffer '3'				
Wind Speed (act)	400	0.0	75.0	m/s
Wind Speed (min)	420	0.0	75.0	m/s
Wind Speed (vct)	480	0.0	75.0	m/s
Wet Bulb Temperature (act)	114	-50.0	60.0	°C
Buffer '4'				
Wind Direction (act)	500	0.0	359.9	0
Wind Direction (min)	520	0.0	359.9	o
Wind Direction (max)	540	0.0	359.9	o
Specific Enthalpy (act)	215	-100.0	1000.0	kJ/kg

Example: Request Buffer '0'

0D0!

0+13.5+85.7+2.5+3.7<CR><LF>

Air Temperature $13.5^{\circ}C$, rel. Humidity 85.7%, average wind speed 2.5m/s, peak wind speed 3.7m/s



Device configured for measurement values in US units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Air Temperature (act)	105	-58.0	140.0	°F
Rel. Humidity (act)	200	0.0	100.0	%
Rel. Air Pressure	305	300.0	1200.0	hPa
Wind Speed (avg)	470	0.0	167.8	mph
Wind Speed (max)	450	0.0	167.8	mph
Buffer '1'				
Wind Direction (vct)	580	0.0	359.9	0
reserved				
Precipitation Type	700	0, 40		
Precipitation Intensity	840	0.0000	7.8740	in/h
Buffer '2'				
Dew Point (act)	115	-58.0	140.0	°F
Wind chill Temperature (act)	116	-76.0	158.0	°F
Amount of Precip. difference	645	0.0000	3937.0000	in
Buffer '3'				
Wind Speed (act)	410	0.0	167.8	mph
Wind Speed (min)	430	0.0	167.8	mph
Wind Speed (vct)	490	0.0	167.8	mph
Wet Bulb Temperature (act)	119	-58.0	140.0	°F
Buffer '4'				
Wind Direction(act)	500	0.0	359.9	0
Wind Direction (min)	520	0.0	359.9	0
Wind Direction (max)	540	0.0	359.9	o
Specific Enthalpy (act)	215	-100.0	1000.0	kJ/kg



19.6.5.10 Buffer Assignment Basic Data Set WS401-UMB

Device configured for measurement in metric units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Air Temperature (act)	100	-50.0	60.0	°C
Rel. Humidity (act)	200	0.0	100,0	%
Dew Point (act)	110	-50.0	60.0	°C
reserved				
Rel. Air Pressure (act)	305	300.0	1200.0	hPa
Buffer '1'				
Precipitation Type	700	0, 40		
Precipitation Intensity	820	0.00	200.00	mm/h
Amount of Precip. Difference	625	0.00	100000.00	mm
Amount of Precip. Absolute	620	0.0	100000.0	mm
Buffer '2'				
Air Temperature (min)	120	-50.0	60.0	°C
Air Temperature (max)	140	-50.0	60.0	°C
Air Temperature (avg)	160	-50.0	60.0	°C
Rel. Humidity (min)	220	0.0	100.0	%
Rel. Humidity (max)	240	0.0	100.0	%
Buffer '3'				
Rel. Humidity (avg)	260	0.0	100.0	%
Rel. Air Pressure(min)	325	300.0	1200.0	hPa
Rel. Rel. Humidity (max)	345	300.0	1200.0	hPa
Rel. Rel. Humidity (avg)	365	300.0	1200.0	hPa
Wet Bulb Temperature (act)	114	-50.0	60.0	°C
Specific Enthalpy (act)	215	-100.0	1000.0	kJ/kg

Example: Request Buffer '0'

0D0!

0+13.5+85.7+11.2+1017.0+1001.0

Air temperature 13.5°C, rel. humidity 85.7%, dew point 11.2°C, rel. air pressure 1017.0hPa, abs. pressure 1001.0hPa



Device configured for measurement in US units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Air Temperature (act)	105	-58.0	140.0	°F
Rel. Humidity (act)	200	0.0	100.0	%
Dew Point (act)	115	-58.0	14.0	°F
reserved				
Rel. Air Pressure (act)	305	300.0	1200.0	hPa
Buffer '1'				
Precipitation Type	700	0, 40		
Precipitation Intensity	840	0.0000	7.8740	in/h
Amount of Precip. Difference	645	0.0000	3937.0000	in
Amount of Precip. Absolute	640	0.000	3937.000	in
Buffer '2'				
Air Temperature (min)	125	-58.0	140.0	°F
Air Temperature (max)	145	-58.0	140.0	°F
Air Temperature (avg)	165	-58.0	140.0	°F
Rel. Humidity (min)	220	0.0	100.0	%
Rel. Humidity (max)	240	0.0	100.0	%
Buffer '3'				
Rel. Humidity (avg)	260	0.0	100.0	%
Rel. Air Pressure(min)	325	300.0	1200.0	hPa
Rel. Rel. Humidity (max)	345	300.0	1200.0	hPa
Rel. Rel. Humidity (avg)	365	300.0	1200.0	hPa
Wet Bulb Temperature (act)	119	-58.0	140.0	°F
Specific Enthalpy	215	-100.0	1000.0	kJ/kg



19.6.5.11 Buffer Assignment Basic Data Set Power Saving Mode 2 (all Models)

Device configured for measurement in metric units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Air Temperature (act)	100	-50.0	60.0	°C
Rel. Humidity (act)	200	0.0	100.0	%
Amount of Precip. Difference	625	0.00	100000.00	mm
Rel. Air Pressure(act)	305	300.0	1200.0	hPa
Wind Speed (act)	400	0.0	75.0	m/s
Buffer '1'				
Wind Direction(act)	500	0.0	359.9	o
Global Radiation	900	0.0	2000.0 *)	W/m²
reserved				
External Temperature	101	-20.0	80.0	°C
Buffer '2'				
Amount of Precip. Absolute	620	0.0	100000.0	mm
Dew point (act)	110	-50.0	60.0	°C
Abs. Humidity (act)	205	0.0	1000.0	g/m³
Mixing Ratio(act)	210	0.0	1000.0	g/kg
Abs. Air Pressure(act)	300	300.0	1200.0	hPa
Buffer '3'				
Wet Bulb Temperature (act)	114	-50.0	60.0	°C
Specific Enthalpy (act)	215	-100.0	1000.0	kJ/kg
Air Density	310	0.000	3.000	kg/m3
Compass (act)	510	0.0	359.0	۰

^{*)} Until device version .49 / .212 / Firmware v5.6: 1400.0 W/m²

Example: Request Buffer '0'

0D0!

0+13.5+85.7+0.2+1017.0+1.8

Air temperature 13.5°C, rel. humidity 85.7%, precipitation 0.2°C, rel. air pressure 1017.0hPa, wind speed1.8m/s



Device configured for measurement in US units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Air Temperature (act)	105	-58.0	140.0	°F
Rel. Humidity (act)	200	0.0	100.0	%
Amount of Precip. Difference	645	0.0000	3937.0000	in
Rel. Air Pressure(act)	305	300.0	12000	hPa
Wind Speed (act)	410	0.0	167.8	mph
Buffer '1'				
Wind Direction(act)	500	0.0	359.9	0
Global Radiation	900	0.0	2000.0 *)	W/m²
reserved				
External Temperature	106	-4.0	176.0	°F
Buffer '2'				
Amount of Precip. Absolute	640	0.000	3937.000	in
Dew point (act)	115	-58.0	140.0	°F
Abs. Humidity (act)	205	0.0	1000.0	g/m³
Mixing Ratio(act)	210	0.0	1000.0	g/kg
Abs. Air Pressure(act)	300	300.0	1200.0	hPa
Buffer '3'				
Wet Bulb Temperature (act)	119	-58.0	140.0	°F
Specific Enthalpy (act)	215	-100.0	1000.0	kJ/kg
Air Density	310	0.000	3.000	kg/m3
Compass (act)	510	0.0	359.0	0

^{*)} Until device version .49 / .212 / Firmware v5.6: 1400.0 W/m²



19.6.6 Additional Measurement Commands

With the additional measurement commands

aM1! ... aM8!

aMC1! ... aMC8! (M-Command, data transmission with CRC)

aC1! ... aC8!

aCC1! ... aCC8! (C- Command, data transmission with CRC)

The complete data sets of the Smart Weather Sensor, as defined for the UMB protocol are available in a SDI-12 environment as well.

The measurement values are ordered according to sensor types.

Equally to the base data sets max. 9 values can be requested with an additional M command, while an additional C request allows for up to 20 values.

The buffer assignment as documented in the following paragraphs has consequently been structured in a way that with each M command the buffers D0 and D1 are used. If the respective sensor type has more values available the buffers D2 up to D4 will be occupied if required.

M1 / C1	Temperature	M: 9 Values	C: 9 Values
M2 / C2	Humidity	M: 9 Values	C: 13 Values
M3 / C3	Air Pressure	M: 9 Values	C: 9 Values
M4 / C4	Wind	M: 9 Values	C: 14 Values
M5 / C5	Compass	M: 1 Values	C: 1 Values
M6 / C6 WS401/601: Others:	Precipitation Precipitation	M: 9 Values M: 4 Values	C: 9 Values C: 4 Values
M7 / C7 WS800-UMB: WS100-UMB: Others:	Global Radiation, Lightning Sensor Drop Diameter Distrib. Global Radiation	M: 9 Values M: M: 4 Values	C: 10 Values C: 17 Values C: 4 Values
M8 / C8	Ext. Temperature	M: 1 Value	C: 1 Value

If the sensor type requested with the measurement command is not available with the actual variant of the Smart Weather Sensor (WS100-UMB ... WS800-UMB) the device will respond with

a0000<CR><LF> resp.

a00000<CR><LF>



19.6.6.1 Buffer Assignment Additional Measurement Commands M1 / C1: Temperature

Device configured for measurement values in metric units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Air Temperature (act)	100	-50.0	60.0	°C
Air Temperature (min)	120	-50.0	60.0	°C
Air Temperature (max)	140	-50.0	60.0	°C
Air Temperature (avg)	160	-50.0	60.0	°C
Dew Point (act)	110	-50.0	60.0	°C
Buffer '1'				
Dew Point (min)	130	-50.0	60.0	°C
Dew Point (max)	150	-50.0	60.0	°C
Dew Point (avg)	170	-50.0	60.0	°C
Wet Bulb Temperature (act)	114	-50.0	60.0	°C

Example: Request with M command

0M1!

00009<CR><LF>

0D0!

0+12.5+10.7+13.5+11.8+5.3<CR><LF>

0D1!

0+4.2+5.9+5.6+9.8<CR><LF>

Device configured for measurement values in US units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Air Temperature (act)	105	-58.0	140.0	°F
Air Temperature (min)	125	-58.0	140.0	°F
Air Temperature (max)	145	-58.0	140.0	°F
Air Temperature (avg)	165	-58.0	140.0	°F
Dew Point (act)	115	-58.0	140.0	°F
Buffer '1'				
Dew Point (min)	135	-58.0	140.0	°F
Dew Point (max)	155	-58.0	140.0	°F
Dew Point (avg)	175	-58.0	140.0	°F
Wet Bulb Temperature (act)	119	-58.0	140.0	°F



19.6.6.2 Buffer Assignment Additional Measurement Commands M2 / C2: Humidity

Device configured for measurement values in metric or US units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Rel. Humidity (act)	200	0.0	100.0	%
Rel. Humidity (min)	220	0.0	100.0	%
Rel. Humidity (max)	240	0.0	100.0	%
Rel. Humidity (avg)	260	0.0	100.0	%
Buffer '1'				
Abs. Humidity (act)	205	0.0	1000.0	g/m³
Abs. Humidity (min)	225	0.0	1000.0	g/m³
Abs. Humidity (max)	245	0.0	1000.0	g/m³
Abs. Humidity (avg)	265	0.0	1000.0	g/m³
Specific Enthalpy (act)	215	-100.0	1000.0	kJ/kg
Buffer '2'				
Mixing Ratio(act)	210	0.0	1000.0	g/kg
Mixing Ratio (min)	230	0.0	1000.0	g/kg
Mixing Ratio (max)	250	0.0	1000.0	g/kg
Mixing Ratio (avg)	270	0.0	1000.0	g/kg

Example: Request with M command

0M2!

00009<CR><LF>

0D0!

0+48.5+48.2+48.8+48.5<CR><LF>

0D1!

0+5.7+5.5+5.9+5.7+29.3<CR><LF>

Example: Request with C command

0C2!

000013<CR><LF>

0D0!

0+48.5+48.2+48.8+48.5<CR><LF>

0D1!

0+5.7+5.5+5.9+5.7+29.3<CR><LF>

0D2!

0+4.6+4.4+5.0+4.6<CR><LF>



19.6.6.3 Buffer Assignment Additional Measurement Commands M3 / C3: Air Pressure

Device configured for measurement values in metric or US units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Abs. Air Pressure(act)	300	300.0	1200.0	hPa
Abs. Air Pressure (min)	320	300.0	1200.0	hPa
Abs. Air Pressure (max)	340	300.0	1200.0	hPa
Abs. Air Pressure (avg)	360	300.0	1200.0	hPa
Air Density (act)	310	0.000	3.000	kg/m3
Buffer '1'				
Rel. Air Pressure (act)	305	300.0	1200.0	hPa
Rel. Air Pressure (min)	325	300.0	1200.0	hPa
Rel. Air Pressure (max)	345	300.0	1200.0	hPa
Rel. Air Pressure (avg)	365	300.0	1200.0	hPa

Example: Request with M command

0M3!

00009<CR><LF>

0D0!

0+1001.0+1000.0+1002.0+1001.0+1.119<CR><LF>

0D1!

0+1017.0+1016.0+1018.0+1017.0<CR><LF>

Example: Request with C command

0C3!

000009<CR><LF>

0D0!

0+1001.0+1000.0+1002.0+1001.0+1.119<CR><LF>

0D1!

0+1017.0+1016.0+1018.0+1017.0<CR><LF>



19.6.6.4 Buffer Assignment Additional Measurement Commands M4 / C4: Wind

Device configured for measurement values in metric units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Wind Speed (act)	400	0.0	75.0	m/s
Wind Speed (min)	420	0.0	75.0	m/s
Wind Speed (max)	440	0.0	75.0	m/s
Wind Speed (avg)	460	0.0	75.0	m/s
Wind Speed (vct)	480	0.0	75.0	m/s
Buffer '1'				
Wind Direction (act)	500	0.0	359.9	0
Wind Direction (min)	520	0.0	359.9	0
Wind Direction (max)	540	0.0	359.9	0
Wind Direction (vct)	580	0.0	359.9	0
Buffer '2'				
Wind Direction corr. (act)	502	0.0	359.9	0
Wind Quality	805	0.0	100.0	%
Wind Chill Temperature (act)	111	-60.0	70.0	°C
Wind Speed Standard Dev.*	403	0.0	60.0	m/s
Wind Direction Standard Dev.*	503	0.0	359.9	o

Device configured for measurement values in US units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Wind Speed (act)	410	0.0	167.8	mph
Wind Speed (min)	430	0.0	167.8	mph
Wind Speed (max)	450	0.0	167.8	mph
Wind Speed (avg)	470	0.0	167.8	mph
Wind Speed (vct)	490	0.0	167.8	mph
Buffer '1'				
Wind Direction (act)	500	0.0	359.9	0
Wind Direction (min)	520	0.0	359.9	0
Wind Direction (max)	540	0.0	359.9	0
Wind Direction (vct)	580	0.0	359.9	0
Buffer '2'				
Wind Direction corr. (act)	502	0.0	359.9	0
Wind Quality	805	0.0	100.0	%
Wind chill Temperature (act)	116	-76.0	158.0	°F
Wind Speed Standard Dev.*	413	0.0	167.8	mph
Wind Direction Standard Dev.*	503	0.0	359.9	0

^{*)} **Note**: Std.Dev. values will be available after the first request. See p. 13.



19.6.6.5 Buffer Assignment Additional Measurement Commands M5 / C5: Compass

Device configured for measurement values in metric or US units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Compass (act)	510	0.0	359.0	0

Example: Request with M command

0M5!

00001<CR><LF>

0D0!

0+348.0<CR><LF>

Example: Request with C command

0C5!

000001<CR><LF>

0D0!

0+348.0<CR><LF>



19.6.6.6 Buffer Assignment Additional Measurement Commands M6 / C6: Precipitation

Device configured for measurement values in metric units:

Measurement Value	UMB Channel	Min	Max	Unit	
Buffer '0'					
Precip. Amount absolute	620	0.0	100000.0	mm	
Precip. Amount difference	625	0.00	100000.00	mm	
Precipitation Intensity	820	0.00	200.00	mm/h	
Precipitation Type	700	0, 40, 60	0, 40, 60, 70 (67, 69, 90)*		
Precipitation Int.(WS100 only)	825	0.0000	3.3333	mm/min	
Buffer '1' (WS100 only)					
WMO Synop Code 4680 wawa	780	Code	(see Ch. 6.15	.1)	
WMO Synop Code 4680 WaWa	781	Code (see Ch. 6.15.1)			
WMO Synop Code 4677 ww	785	Code (see Ch. 6.15.1)			
WMO Synop Code 4680 WW	786	Code	(see Ch. 6.15	.1)	

^{)*} additional precipitation types: WS100-UMB only

Example: Request with M command

0M6!

00009<CR><LF>

0D0!

0+1324.5+1.10+4.46+60<CR><LF>

Device configured for measurement values in US units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Precip. Amount absolute	640	0.000	3937.000	In
Precip. Amount difference	645	0.0000	3937.0000	In
Precipitation Intensity	840	0.000	7.874	in/h
Precipitation Type	700	0, 40, 60, 70 (67, 69, 90)*		
Precipitation Int.(WS100 only)	845	0.000	0.1312	in/min
Buffer '1' (WS100 only)				
WMO Synop Code 4680 wawa	780	Code (se	ee Ch. 6.15.	1)
WMO Synop Code 4680 WaWa	781	Code (see Ch. 6.15.1)		
WMO Synop Code 4677 ww	785	Code (see Ch. 6.15.1)		
WMO Synop Code 4680 WW	786	Code (se	ee Ch. 6.15.	1)

^{)*} additional precipitation types: WS100-UMB only



19.6.6.7 Buffer Assignment Additional Measurement Commands M7 / C7: Global Radiation, Lightning Detection (WS100-UMB: Drop Diameter Distribution)

Assignment for WS30x-UMB, WS50x-UMB, WS700-UMB, WS800-UMB

Device configured for measurement values in metric units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Global Radiation (act)	900	0.0	2000.0 *)	W/m²
Global Radiation (min)	920	0.0	2000.0 *)	W/m²
Global Radiation (max)	940	0.0	2000.0 *)	W/m²
Global Radiation (avg)	960	0.0	2000.0 *)	W/m²
Buffer '1' (WS800-UMB only)				
Lightning Events (minute)	617	0	255	-
Lightning Events (Intervall)	677	0	999	-
reserved				
reserved				
reserved				
Buffer '2' (WS800-UMB only)				
reserved				

^{*)} Until device version .49 / .212 / Firmware v5.6: 1400.0 W/m²

Example: Request with M Command

0M7!

00004<CR><LF>

0D0!

0+780.0+135.0+920.0+530.0<CR><LF>

Device configured for measurement values in US units:

Device deringuises for measurement values in 22 arms.					
Measurement Value	UMB Channel	Min	Max	Unit	
Buffer '0'					
Global Radiation (act)	900	0.0	2000.0 *)	W/m²	
Global Radiation (min)	920	0.0	2000.0 *)	W/m²	
Global Radiation (max)	940	0.0	2000.0 *)	W/m²	
Global Radiation (avg)	960	0.0	2000.0 *)	W/m²	
Buffer '1' (WS800-UMB only)					
Lightning Events (minute)	617	0	255	-	
Lightning Events (Intervall)	677	0	999	-	
reserved					
reserved					
reserved					
Buffer '2' (WS800-UMB only)					
reserved					

^{*)} Until device version .49 / .212 / Firmware v5.6: 1400.0 W/m²



Assignment for WS100-UMB, C7 Request only

Device configured for measurement values in metric or US units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
Total precipitation particles	4600	0	9999999	Event
Total drops	4601	0	9999999	Event
Drizzle particles	4602	0	65535	Event
Snow particles	4603	0	65535	Event
Hail particles	4604	0	65535	Event
Drop class 0	4620	0	65535	Event
Drop class 1	4621	0	65535	Event
Drop class 2	4622	0	65535	Event
Buffer '1'				
Drop class 3	4623	0	65535	Event
Drop class 4	4624	0	65535	Event
Drop class 5	4625	0	65535	Event
Drop class 6	4626	0	65535	Event
Drop class 7	4627	0	65535	Event
Drop class 8	4628	0	65535	Event
Drop class 9	4629	0	65535	Event
Drop class 10	4630	0	65535	Event
Drop class 11	4631	0	65535	Event



19.6.6.8 Buffer Assignment Additional Measurement Commands M8 / C8: External Temperature

Device configured for measurement values in metric units:

Measurement Value	UMB Channel	Min	Max	Unit
Buffer '0'				
External Temperature (act)	101	-40.0	80.0	°C

Example: Request with M Command

0M8!

00001<CR><LF>

0D0!

0+13.5<CR><LF>

Device configured for measurement values in US units:

Measurement Value	UMB Channel	Min	Max	Unit	
Buffer '0'					
External Temperature (act)	106	-40.0	176.0	°F	



19.6.7 Message Device Identification

The device responds to the identification request with following message (example for SDI-12 device address '0':

0I!

013Lufft.deWSx00ynnn

x: device type (4, 5, 6, 2, 3)

y: Metric / US units (m = metric, u = US)

nnn: Software version

i.e. for a WS600-UMB, configured for US units:

0I!

013Lufft.deWS600u022

19.6.8 Message Verification

The command verification aV! is used to evaluate status information of the device. The device responds with

a0005<CR<LF> WS700/800-UMB: a0006<CR<LF>

to the request, i.e. 5 (6) values are available in the buffers.

The first 3 (4) "measurement values", transmitted in buffer '0' contain the status information of the measurement channels.

The status data of the channels are assembled to form "fake measurement values", where each digit represents one status. See below for the coding of states. Generally each sensor has two status values, one for the direct value and another for the measurement value buffer used for the evaluation of the average, min, and max values.

The last two values, transmitted in buffer '1', show the heating temperatures of wind and precipitation sensor.

Buffer '0'						
Status group1: +nnnn	Air temper buffer	Air temperature, air temperature buffer, dew point, dew point buffer				
Status group1: +nnnnnn (WS401 / WS601 only)		Air temperature, air temperature buffer, dew point, dew point buffer, reserved, reserved				
Status group 2: +nnnnnn				fer, abs. Humidity, abs nixing ration buffer		
Status group 3: +nnnnnn	Air pressure, air pressure buffer, wind, wind buffer, compass, precipitation (WS301/501 transmits the global radiation status instead of the precipitation status)					
Status group 4: +nnnn (WS700-UMB, WS800-UMB only)	Global radiation status, global radiation buffer status, lightning detector status, lightning detector buffer status					
Buffer '1', device configured for me	etric units					
Measurement value	UMB Channel	min	max	Unit		
Heating temp. Wind sensor	112 -50 +150 °C					
Heating temp. Precip. sensor	113 -50 +150 °C					
Buffer '1', device configured for US	Buffer '1', device configured for US units					
Heating temp. Wind sensor	117 -58 +302 °F					
Heating temp. Precip. sensor	118	-58	+302	°F		



Sensor status codes:

Sensor status	Code
OK	0
UNGLTG_KANAL	1
E2_CAL_ERROR E2_CRC_KAL_ERR FLASH_CRC_ERR FLASH_WRITE_ERR FLASH_FLOAT_ERR	2
MEAS_ERROR	3
MEAS_UNABLE	4
INIT_ERROR	5
VALUE_OVERFLOW CHANNEL_OVERRANGE	6
VALUE_UNDERFLOW CHANNEL_UNDERRANGE	7
BUSY	8
other sensor status	9

Example (WS600-UMB, SDI-12 Address '0', no error):

0V!
00005<CR><LF>
0D0!
0+0000+000000+000000<CR><LF>
0D1!
0+73.0+65.3<CR><LF>

Example (WS600-UMB, SDI-12 Address '0', compass failure):

0V!
00005<CR><LF>
0D0!
0+0000+000000+000030<CR><LF>
0D1!
0+73.0+65.3<CR><LF>



19.6.9 Message Change of Unit System

The command is used to change the unit system used for the SDI12 data between metric and US units. It is implemented as manufacturer specific X command.

Command: aXU<u/m>!

Response: aU<u/m><CR><LF>

u: US unitsm: metric units

Example: change to metric units, SDI-12 address '0'

0XUm!

OUm<CR><LF>

19.6.10 Message: Setting of the Averaging Interval Length

The avg, min, max and vct values of the measurement values are evaluated over a floating interval with a length of 1 to 10 min. The length of this interval can be adjusted separately for the groups temperature / humidity, air pressure and wind. (The averaging algorithm is not applied to precipitation and compass).

Command: aXA<t/p/w/r>+nn!

t: Temperature and Humidity

p: Air pressure

w: Wind

r: Global radiation

nn: Interval in minutes, valid range: 1 bis 10 Response: aXA<t/p/w/r>+nn<CR><LF>

The response to the attempt of setting of an invalid interval length is

aXAf<CR><LF>

Example: Setting the interval for temperature and humidity to 5 minutes

0XAt+5!

0XAt+5<CR><LF>

19.6.11 Message: Setting of the Local Altitude

For the calculation of the relative air pressure the local altitude of the device is required.

Command: aXH+nnnn!

nnnn: local altitude of the sensor in m Response: aXH+nnnn<CR><LF>

The response to the attempt of setting of an invalid altitude (-100 < altitude < 5000) is aXHf < CR > < LF >

Example: The altitude of the installation location is 135m above sea level

0XH+135!

0XH+135<CR><LF>



19.6.12 Setting of the Local Magnetic Declination

For exact compass heading the local magnetic declination must be set.

Command: aXD+nnn.n!

nnn.n: local magnetic declination at installation site in ° *)

Response: aXD+nnn.n<CR><LF>

The response to the attempt of setting of an invalid altitude (-180.0<declination<+180.0) is aXDf<CR><LF>

Example: The declination at the installation location is -5.3°

0XD-5.3!

0XD-5.3<CR><LF>

*) The magnetic declination is available from various web sites, e.g. http://www.ngdc.noaa.gov/geomag-web/#declination

19.6.13 Message: Activation / Deactivation of Compass Correction

The correction of the wind direction by the compass bearing can be activated or deactivated.

Command: aXW<c/u>!

c: wind direction is corrected by the compass bearing

u: wind direction is not corrected Response: aXW<c/u>

The response to the attempt of setting an invalid option is

aXWf<CR><LF>

Example: Compass correction of wind direction is activated

OXWc!

0XWc<CR><LF>

19.6.14 Message: Setting the Power Saving Mode

For installations with limited power supply the Smart Weather Sensor may be operated in power saving mode (see Chap. 45).



Note: Operation in power saving mode has some functional restrictions!

Command: aXL<n/s/w>!

n: Normal Operation

s: Power saving mode 1 (Heating/Fan off)
w: Power saving mode 2 (Sleep mode)

Response: aXL<n/s/w><CR><LF>

The response is followed by the device reset, i.e. the device will be offline for a few seconds.

The response to the selection of an invalid option or of an invalid combination of mode and device model is

aXLf<CR><LF>

Example: The device shall be set to power saving mode 2

0XLw!

0XLw<CR><LF>



19.6.15 Message: Setting the Heating Mode

The heating of the precipitation and the wind sensors can be configured in different operation modes (see chapter 10.4). Depending on the actual variant of the Smart Weather Sensor (WS100-UMB ...WS800-UMB) only certain combinations of operating modes are available. The Smart Weather Sensor evaluates the valid combinations from the device heating mode requested in the command automatically.

Command: aXMn!

n: Heating Operating Mode (0: Automatic, 1: Mode 1, 2: Off, 3: Eco Mode 1)

Response: aXMnm<CR><LF>

n: Selected Heating Mode Wind Sensor

m: Selected Heating Mode Precipitation Sensor

The response to the attempt of setting an invalid operation mode is aXMf<CR><LF>

Example: A WS400-UMB shall be set to Mode 1

0XM1!

0XM21<CR><LF>

As the WS400-UMB does not have a wind sensor the heating mode wind is automatically set to 2 (= off).

0XD+633.0<CR><LF>



19.6.16 Message: Setting of the Rain Gauge Resolution

The resolution of the tipping bucket rain gauge of WS401-UMB and WS601-UMB, as well as the resolution of an optional external rain gauge connected to a model without internal precipitation measurement can be mechanically adjusted (see p. 38). The mechanical resolution must be set in the sensor configuration.

Command: aXK+n!

n: resolution of the rain gauge in 1/10mm, valid settings 1, 2, 5, 10

(0.1mm, 0.2mm, 0.5mm, 1.0mm)

Response: aXK+n<CR><LF>

The response to the attempt of setting of an invalid resolution is

aXKf<CR><LF>

Example: The mechanical resolution of the rain gauge is 0.2mm

0XK+2!

0XK+2<CR><LF>

19.6.17 Message: Clearing the Absolute Precipitation Amount

The command clears the accumulated absolute precipitation amount to 0.0mm. At the same time a device reset is applied.

Command: aXC!

Response: aXCok<CR><LF>

The response is followed by the device reset, i.e. the device will be offline for a few seconds.

Example:

OXC!

0XCok<CR><LF>

19.6.18 Message: Device Reset

The command initiates a device reset.

Command: aXR!

Response: aXRok<CR><LF>

The response is followed by the device reset, i.e. the device will be offline for a few seconds.

Example:

0XR!

0XRok<CR><LF>



19.6.19 Message: Request Measurement Parameter Identification (SDI-12 v1.4, WS100 only)

The command requests the measurement parameter identification of a single measurement value.

Message: aI<Meas.Command>_0mm!

Meas.Command: M, MC, M1...M9, MC1...MC9, C, CC, C1...C9,

CC1...CC9, R1...R9, V

mm: Position of measurement value

Antwort: a,<meas_value_code>,<unit>,<value_type><CR>LF>

meas_value_code	Measurement Value
THR	Heating temperature
PPTT	Total precipitation
PPD	Precipitation difference
PPI	Precipitation intensity
PPTP	Precipitation type
STA1 STA3	Device_Status
PPDDP	Distribution total particles
PPDDR	Distribution total drops
PPDDD	Distribution drizzle
PPDDS	Distribution snow
PPDDH	Distribution hail
PPDD0	Distribution drop class 0 11
PPDD11	

value_type	
cur	Current / spot value
min	Minimum
max	Maximum
avg	Average
vct	Vector average

Example:

0IM_001!

0,PPTT,mm,cur<CR><LF>



19.7 Communication in Modbus Mode

For a simpler integration of WS family Smart Weather Sensors into a PLC environment the Modbus communication protocol has been made available.

Measurement values are mapped to Modbus Input Registers. The range of values available is basically the same as for the UMB protocol, including different unit systems.

In the interest of simple and safe integration the use of register pairs for floating point values or 32 bit integers, which is not part of the Modbus standard, has not been applied. All measurement values are mapped to 16bit integers using suitable scaling factors.

19.7.1 Modbus Communication Parameters

The Smart Weather Sensor can be configured for MODBUS-RTU or for MODBUS-ASCII.

The base configuration has to be done using the UMB Config Tool.

When selecting MODBUS RTU or MODBUS-ASCII with the UMB Config Tool,

communication parameters 19200 Bd, even parity, will be preselected.

Modbus operating modes:

MODBUS-RTU, MODBUS-ASCII

Baud rate: 19200 (9600, 4800 or lower)

Interface Setting 8E1, 8N1, 8N2



NOTE: The Modbus communication has been tested for a poll rate of 1 sec. The proper function of the Smart Weather Sensor with higher Modbus poll rates has not been tested.

We suggest to set the poll rate to 10 sec or slower, as, with the exception of the channels "wind speed / wind directions fast", which are provided for special purposes, the update rate of the data is >= 10sec. Anyway for most of the weather data significant changes have tob e expected more in the range of minutes.

19.7.2 Addressing

The Modbus address is deducted from the the UMB device ID (see Chap. 19.3.2).

A device with UMB device ID 1 also has the UMB address 1, etc..

The valid address range of Modbus from 1 to 247 is smaller than that of the UMB device IDs. If a UMB device ID > 247 has been selected, the Modbus address will be set to 247.

19.7.3 Modbus Functions

The functions of conformance class 0 and 1 have been implemented as far as they are applicable for the Smart Weather Sensor, i.e. all functions operating on register level.

Starting with device version 227 / firmware version v60 additional coil functions are available which are used for selected operations. This coil functions are currently not implemented for WS100-UMB.

	Conformance Class 0	
0x03	Read Holding Registers	Selected configuration settings
0x16	Write Multiple Registers	Selected configuration settings
	Conformance Class 1	
0x01	Read Coils	Selected additional operations *)
0x04	Read Input Registers	Measurement values and status information
0x05	Write Single Coil	Selected additional operations *)
0x06	Write Single Register	Selected configuration settings
0x07	Read Exception Status	Currently not used
	Conformance Class 2	(partly)
0x0F	Write Multiple Coils	Selected additional operations *)
	Diagnostics	
0x11	Report Slave ID	(responds also to broadcast address)

^{*)} Verfügbar ab Geräteversion 227



19.7.3.1 Functions 0x01 Read Coils, 0x05 Write Single Coil, 0x0F Write Multiple Coils

Coil function are used to trigger certain selected operation mode changes, particularly concerning the sensors power consumption, e.g. temporary deactivation off an and heatings.

(not available for WS100-UMB)

Coil Nr.	Coil Adr.	Function	Read	Write
1	0	Fan ON/OFF	1: Fan ON 2: Fan OFF or AUTOMATIC	ON: Set Fan to mode ON, set coil No. 2 to 0
		*) temporary		OFF: Set Fan to mode OFF, set coil No. 2 to 0
2	1	Fan ON/AUTOMATIC	1: Lüfter AUTOMATIC 2: Lüfter OFF oder ON	ON: Set Fan to mode AUTOMATIC, set coil No. 1 to 0
		*) temporary	2. Luitei OFF odel ON	OFF: Set Fan to mode OFF, set coil No. 1 to 0
3	2	Wind heating OFF	Wind heater operating in configured mode	ON: Set wind heater to OFF
		*) temporary	configured mode	OFF: Set wind heater to configured mode
		/ temperary	1: Wind heater OFF	
4	3	R2S heating OFF	0: R2S heater operating in configured mode	ON: Set R2S heater to OFF
		*) temporär	comgarou mous	OFF: Set R2S heater to configured mode
		, ,	1: R2S heater OFF	
5	4	Device Power Mode, s. Chapter. 10.4.1	0: Power mode Normal	ON: Set power saving mode 1
		Ghapter: 10.4.1	1: Power saving mode 1	OFF: Set power mode normal
		*)permanent	1.1 Gwol Saving mode 1	
6 20	5 19	Derzeit ohne Funktion		

^{*)} temporary: status and operation change immediately, but are not written into the permanent configuration storage. I.e. after a reset the device will return to it's originally configured mode.



*)permanent: the modification is written into the permanent configuration storage. It will be effective only after a device reset (Modbus: write 12871 into holding register no. 9)

Note: Modifications of the fan operating mode are not permitted during the execution of compass measurement. If a fan mode switch is attempted during compass measurement the execution will be delayed until the compass measurement has been completed. The delay may take up to one minute.



19.7.3.2 Function 0x03 Read Holding Registers

The Holding Registers are used to make a selected set of adjustable parameters available for Modbus access. As for the measurement values the parameters are mapped to 16bit integers.

Reg. No.	Reg. Addr	Function	Values	Scale
1	0	Local Altitude	Altitude in m, for calculation of relative air pressure Value range -100 5000	
2	1	Deviation	Local deviation for the correction of compass heading.	10.0
			Value range -3599 3599 (equalling -359.9° +359.9°)	
3	2	Averaging Interval	Interval for averaging and min/max evaluation in minutes	1.0
		TFF	Value range 1 10	
4	3	Averaging Interval	Interval for averaging and min/max evaluation in minutes	1.0
		Air Pressure	Value range 1 10	
5	4 Averaging Interval		Interval for averaging and min/max evaluation in minutes	1.0
		Wind	Value range 1 10	
6	5	Averaging Interval	Interval for averaging and min/max evaluation in minutes	1.0
		Global Radiation	Value range 1 10	
7	6	Heating Mode	High-Byte: Heating Mode Wind Low-Byte Heating Mode R2S	
			Value range of each byte 0 3	
			(Details s. 10.5)	
8	7	Reset abs. Rain	(Function only when writing to the register, reading will give 0 always)	
9	8	Device reset	(Function only when writing to the register, reading will give 0 always)	

Heating Modes (see 10.5):

Automatic 0 Mode 1 1 Off 2 Eco 1 3

19.7.3.3 Function 0x06 Write Holding Register, 0x10 Write Multiple Registers

By writing into the holding registers selected parameters of the Smart Weather Sensor can be adjusted through Modbus.

Register assignment see19.7.3.2

Local altitude, compass deviation and averaging intervals are set by writing the new values into the related registers. Depending on the selected register the value has to be scaled by the factor given in the table:

Example: for compass deviation the table shows a scaling factor of 10.0. If the deviation is 4.8° a value of 48 shall be written into register 2 (reg.addr. 1).

The transmitted values will be checked for plausibility. Illegal values will not be accepted and cause a Modbus exception.

When writing the value 0x3247 (12871d) to register no. 8 (reg. addr. 7) the stored absolute rain amount will be set to 0. Subsequently a device reset will be initiated.

When writing the value 0x3247 (12871d) to register no. 9 (reg. addr. 8) a device reset will be initiated.

Setting of the heating mode:

The wind sensor heating mode is coded into the high byte of the 16bit register no. 7, the precipitation sensor heating mode into the low byte of this register

Example:

Heating mode wind: Mode 1 (Code 1)
Heating mode precipitation: Off (Code 2)

Write to register 7 (reg. addr. 6): 0x0102 (=258d)



Setting for minimum power consumption, both heatings off (Code 2): Write to register 7 (reg. addr. 6): 0x0202 (=514d)

The factory setting for a WS600-UMB is automatic mode for both heatings, i.e. 0x0000.

When attempting to set a heating mode not supported by the individual device variant, e.g. activating the precipitation heating of a device without precipitation sensor, the device will automatically adjust the value written to the register, so that the value read back from the register might be different from the written value.



19.7.3.4 Function 0x04 Read Input Registers

The input registers are containing the measurement values of the Smart Weather Sensor and the related status information.

The measurement values are mapped to the 16bit registers using scaling factors (0 ... max. 65530 for unsigned values, -32762 ... 32762 for signed values).

Values 65535 (0xffff) resp. 32767 are used for the indication of erroneous or not available measurement values. A more detailed specification of the error can be evaluated from the status registers.

The assignment of values to the available register addresses (0 ... 124) has been arranged in a way so that the user can read the most frequently used data with few (ideally only one) register block requests

Following blocks have been defined:

- Status information
- Frequently used values which are independent of the unit system (met./ imp.) in use
- Frequently used values in metric units
- Frequently used values in imperial units
- Other measurement values

When using the metric unit system the first three blocks can the supply all data usually required with one request.

There is no difference in the register assignment between the sub types of the WS family. If, dependent on the type, some value is not available, this will be indicated by setting the register to the error value.

For detailed information about measurement ranges, units etc. please refer to the related description of the UMB channels (Chapter 6 and 19.1)

Reg. No.	Reg. Addr.	Value (UMB Channel)	Range	Scaling Factor, Remarks
		Status Information	on	
1	0	Identification	High Byte: WS-Type (2,3,4,5,6) Low Byte: Software Version	Type coding, see below
2	1	Device Status		
3	2	Sensor Status 1	Air temperature buffer, air temperature, dew point buffer, dew point(high byte -> low byte, see table below)	Coding 4 bit per status, see below
4	3	Sensor Status 2	Rel. humidity buffer, rel. humidity, abs. humidity buffer, abs. humidity(high byte -> low byte, see table below)	Coding 4 bit per status, see below
5	4	Sensor Status 3	Mixing ratio buffer, mixing ration, air press. buffer, air press. (high byte -> low byte, see table below)	Coding 4 bit per status, see below
6	5	Sensor Status 4	Wind buffer, wind, precipitation, compass(high byte -> low byte, see table below)	Coding 4 bit per status, see below
7	6	Sensor Status 5	Global radiation buffer, global radiation, reserved, reserved (high byte -> low byte, see table below)	Coding 4 bit per status, see below
8	7	Sensor Status 6	External temperature / external rain gauge, lightning sensor, lightning sensor buffer (see table below)	Coding 4 bit per status, see below
9	8	Reserve		
10	9		Diagnostic: run time in 10sec steps	



Reg. No.	Reg. Addr.	Value (UMB Channel)	Range	Scaling Factor, signed/unsigned, Remarks
		Values Independ	dent of the Unit System	
11	10	200	Relative Humidity (act.)	Factor 10, s
12	11	220	Relative Humidity (min.)	Factor 10, s
13	12	240	Relative Humidity (max.)	Factor 10, s
14	13	260	Relative Humidity (avg.)	Factor 10, s
15	14	305	Rel. Air Pressure (act.)	Factor 10, s
16	15	325	Rel. Air Pressure (min.)	Factor 10, s
17	16	345	Rel. Air Pressure (max.)	Factor 10, s
18	17	365	Rel. Air Pressure (avg.)	Factor 10, s
19	18	500	Wind Direction (act.)	Factor 10, s
20	19	520	Wind Direction (min.)	Factor 10, s
21	20	540	Wind Direction (max.)	Factor 10, s
22	21	580	Wind Direction (vct.)	Factor 10, s
23	22	501	Wind Direction fast	Factor 10, s
24	23	502	Wind Direction compass corr.	Factor 10, s
25	24	510	Compass	Factor 10, s
26	25	700	Precipitation Type	Factor 1, s
27	26	805	Wind Measurement Quality	Factor 1, u
28	27	900	Global Radiation (act.)	Factor 10, s
29	28	920	Global Radiation (min.)	Factor 10, s
30	29	940	Global Radiation (max.)	Factor 10, s
31	30	960	Global Radiation (avg.)	Factor 10, s



Reg. No.	Reg. Addr.	Value (UMB Channel)	Range	Scaling Factor, signed/unsigned Remarks
		Values in Metri	c Units	
32	31	100	Air Temperature °C (act.)	Factor 10, s
33	32	120	Air Temperature °C (min.)	Factor 10, s
34	33	140	Air Temperature °C (max.)	Factor 10, s
35	34	160	Air Temperature °C (avg.)	Factor 10, s
36	35	110	Dew Point °C (akt.)	Factor 10, s
37	36	130	Dew Point °C (min.)	Factor 10, s
38	37	150	Dew Point °C (max.)	Factor 10, s
39	38	170	Dew Point °C (avg.)	Factor 10, s
40	39	111	Wind Chill-Temperature °C	Factor 10, s
41	40	112	Heating Temperature Wind °C	Factor 10, s
42	41	113	Heating Temperature R2S °C	Factor 10, s
43	42	400	Wind Speed m/s (akt.)	Factor 10, s
44	43	420	Wind Speed m/s (min.)	Factor 10, s
45	44	440	Wind Speed m/s (max.)	Factor 10, s
46	45	460	Wind Speed m/s (avg.)	Factor 10, s
47	46	480	Wind Speed m/s (vct.)	Factor 10, s
48	47	401	Wind Speed fast m/s	Factor 10, s
49	48	620	Precipitation abs. mm	Factor 100, u, limited to 655.34mm
50	49	625	Precipitation diff. mm	Factor 100, u, limited to 100.00mm
51	50	820	Precipitation intens. mm/h	Factor 100, u, limited to 200.00mm/h



Reg. No.	Reg. Addr.	Value (UMB Channel)	Range	Scaling Factor, signed/unsigned Remarks
		Values in US Un	its	
52	51	105	Air Temperature °F (act.)	Factor 10, s
53	52	125	Air Temperature °F (min.)	Factor 10, s
54	53	145	Air Temperature °F (max.)	Factor 10, s
55	54	165	Air Temperature °F (avg.)	Factor 10, s
56	55	115	Dew Point °F (act.)	Factor 10, s
57	56	135	Dew Point °F (min.)	Factor 10, s
58	57	155	Dew Point °F (max.)	Factor 10, s
59	58	175	Dew Point °F (avg.)	Factor 10, s
60	59	116	Wind Chill-Temperature °F	Factor 10, s
61	60	117	Heating Temperature Wind °F	Factor 10, s
62	61	118	Heating Temperature R2S °F	Factor 10, s
63	62	410	Wind Speed mph (act.)	Factor 10, s
64	63	430	Wind Speed mph (min.)	Factor 10, s
65	64	450	Wind Speed mph (max.)	Factor 10, s
66	65	470	Wind Speed mph (avg.)	Factor 10, s
67	66	490	Wind Speed mph (vct.)	Factor 10, s
68	67	411	Wind Speed fast mph	Factor 10, s
69	68	640	Precipitation abs. In	Factor 1000, u, limited to 25.800 in
70	69	645	Precipitation diff. in	Factor 10000, u, limited to 3.9370in
71	70	840	Precipitation Intens. in/h	Factor 10000, u, limited to 6.5534 in



Reg. No.	Reg. Addr.	Value (UMB Channel)	Range	Scaling Factor, signed/unsigned, Remarks
		Further Values	S	
72	71	205	Absolute Humidity (act.)	Factor 10, s
73	72	225	Absolute Humidity (min.)	Factor 10, s
74	73	245	Absolute Humidity (max.)	Factor 10, s
75	74	265	Absolute Humidity (avg.)	Factor 10, s
76	75	210	Mixing Ratio (act.)	Factor 10, s
77	76	230	Mixing Ratio (min.)	Factor 10, s
78	77	250	Mixing Ratio (max.)	Factor 10, s
79	78	270	Mixing Ratio (avg.)	Factor 10, s
80	79	300	Abs. Air Pressure (act.)	Factor 10, s
81	80	320	Abs. Air Pressure (min.)	Factor 10, s
82	81	340	Abs. Air Pressure (max.)	Factor 10, s
83	82	360	Abs. Air Pressure (avg.)	Factor 10, s
84	83	405	Wind Speed km/h (act.)	Factor 10, s
85	84	425	Wind Speed km/h (min.)	Factor 10, s
86	85	445	Wind Speed km/h (max.)	Factor 10, s
87	86	465	Wind Speed km/h (avg.)	Factor 10, s
88	87	485	Wind Speed km/h (vct.)	Factor 10, s
89	88	415	Wind Speed kts (act.)	Factor 10, s
90	89	435	Wind Speed kts (min.)	Factor 10, s
91	90	455	Wind Speed kts (max.)	Factor 10, s
92	91	475	Wind Speed kts (avg.)	Factor 10, s
93	92	495	Wind Speed kts (vct.)	Factor 10, s
94	93	406	Wind Speed fast km/h	Factor 10, s
95	94	416	Wind Speed fast kts	Factor 10, s
96	95	403	Wind Speed Std. Dev. m/s *	Factor 100, s
97	96	413	Wind Speed Std. Dev. Mph *	Factor 100, s
98	97	503	Wind Dir. Standard Dev.*	Factor 100, s
99	98	114	Wet Bulb Temp. °C (act)	Factor 10, s
100	99	119	Wet Bulb Temp. °F (act)	Factor 10, s
101	100	215	Specific Enthalpy (act)	Factor 10, s
102	101	310	Air Density (act)	Factor 1000, s

^{*)} Note: Standard deviation values are available after the first request. Please see p. 13

Reg. No.	Reg. Addr.	Value (UMB Channel)	Range	Scaling Factor, signed/unsigned, Remarks
		Further Values		
103	102	825	Precipitation Int. (WS100 only)	Factor 10000, u
104	103	845	Precipitation Int. (WS100 only)	Factor 200000 , u
105	104	750	reserved	Factor 1, s
106	105	770	reserved	Factor 1, s
107	106	711	reserved	Factor 1, s
108	107	101	External Temperature °C (act)	Factor 10, s
109	108	109	External Temperature °F (act)	Factor 10, s
110	109	806	Wind Value Quality (fast)	Factor 1, u
111	110	617	Lightning Events (minute)	Factor 1, u
112	111	677	Lightning Events (Intervall)	Factor 1, u
113	112	780	WMO Synop Code 4680 wawa (WS100 only)	Factor 1, u
114	113	781	WMO Synop Code 4680 WaWa (WS100 only)	Factor 1, u
115	114	785	WMO Synop Code 4677 ww (WS100 only)	Factor 1, u
116	115	786	WMO Synop Code 4677 WW (WS100 only)	Factor 1, u
117	116	Reserved		

Service Channels

Air temperature (WS100-UMB only, no radiation shield)

Reg. No.	Reg. Addr.	Value (UMB Channel)	Range	Scaling Factor, signed/unsigned Remarks
		Values in Metric	Units	
150	149	4100	Air Temperature °C (act.)	Factor 10, s
151	150	4120	Air Temperature °C (min.)	Factor 10, s
152	151	4140	Air Temperature °C (max.)	Factor 10, s
153	152	4160	Air Temperature °C (avg.)	Factor 10, s
154	153	4105	Air Temperature °F (act.)	Factor 10, s
155	154	4125	Air Temperature °F (min.)	Factor 10, s
156	155	4145	Air Temperature °F (max.)	Factor 10, s
157	156	4156	Air Temperature °F (avg.)	Factor 10, s



Drop Diameter Distribution (WS100-UMB only)

Reg. No.	Reg. Addr.	Value (UMB Channel)	Range	Scaling Factor, signed/unsigned, Remarks
130	129	4600	Total particles	Faktor 1, u
131	130	4601	Total drops	Faktor 1, u
132	131	4602	Drizzle particles	Faktor 1, u
133	132	4603	Snow particles	Faktor 1, u
134	133	4604	Hail particles	Faktor 1, u
135	134	4620	Drop class 0	Faktor 1, u
136	135	4621	Drop class 1	Faktor 1, u
137	136	4622	Drop class 2	Faktor 1, u
138	137	4623	Drop class 3	Faktor 1, u
139	138	4624	Drop class 4	Faktor 1, u
140	139	4625	Drop class 5	Faktor 1, u
141	140	4626	Drop class 6	Faktor 1, u
142	141	4627	Drop class 7	Faktor 1, u
143	142	4628	Drop class 8	Faktor 1, u
144	143	4629	Drop class 9	Faktor 1, u
145	144	4630	Drop class 10	Faktor 1, u
146	145	4631	Drop class 11	Faktor 1, u
		Reserve		

(WS100 only) Copy of precipitation relevant registers, to permit reading all precipitation relevant values in one Modbus request

NOTE: When requesting precipitation differences, register numbers 50, 70 **OR** 162, 166 shall be requested. Both register groups use the same storage and reset the value after reading!

Reg. No.	Reg. Addr.	Value (UMB Channel)	Range	Scaling Factor, signed/unsigned Remarks
160	159	700	Precipitation type	Factor 1, u
161	160	620	Total precipitation mm	Factor 100, u
162	161	625	Precipitation difference mm	Factor 100, u
163	162	820	Precipitation intensity mm/h	Factor 100, u
164	163	113	Heating temperature °C	Factor 10, s
165	164	640	Total precipitation in	Factor 1000, u
166	165	645	Precipitation difference in	Factor 1000, u
167	166	840	Precipitation intensity in/h	Factor 1000, u
168	167	118	Heating temperature °F	Factor 10, s
169	168	780	WMO Synop Code 4680 wawa	Factor 1, u
170	169	781	WMO Synop Code 4680 WaWa	Factor 1, u
171	170	785	WMO Synop Code 4677 ww	Factor 1, u
172	171	786	WMO Synop Code 4677 WW	Factor 1, u



Smart Weather Sensor Type Code

WS100-UMB	24	WS303-UMB	33
WS200-UMB	2	WS304-UMB	43
WS300-UMB	3	WS310-UMB	93
WS400-UMB	4	WS501-UMB	15
WS500-UMB	5	WS502-UMB	25
WS600-UMB	6	WS503-UMB	35
WS700-UMB	7	WS504-UMB	45
WS800-UMB	8	WS510-UMB	95
WS301-UMB	13	WS401-UMB	14
WS302-UMB	23	WS601-UMB	16

Sensor Status:

Each register holds 4 sensor status coded with 4 bits per status, so that together they build one 16bit number. The sequence defined in the table above is to understand as from most significant half byte to least significant half byte. Most of the sensors have two status values, one for the sensor itself and the current measurement value, another one for the buffer, from which average, min. And max values are evaluated.

Assignment of Status Information to Status Register

Register	Byte	Half- Byte	Status
	∐iah	High	Temperature Buffer
Sensor Status 1	High	Low	Temperature
Serisor Status I	Low	High	Dewpoint Buffer
	LOW	Low	Dewpoint
	High	High	Rel. Humidity Buffer
Sensor Status 2	riigii	Low	Rel. Humidity
Serisor Status 2	Low	High	Abs. Humidity Buffer
	LOW	Low	Abs. Humidity
	∐iah	High	Mixing Ratio Buffer
Sensor Status 3	High	Low	Mixing Ratio
Sensor Status 3	Low	High	Air Pressure Buffer
		Low	Air Pressure
	High	High	Wind Buffer
Sensor Status 4		Low	Wind
Sensor Status 4	1	High	Precipitation
	Low	Low	Compass
	∐iah	High	Global Radiation Buffer
Sensor Status 5	High	Low	Global Radiation
Serisor Status 5	Low	High	reserved
	LOW	Low	reserved
Sensor Status 6	High	Low	External Temperature
Sensor Status o	Low	High	Lightning Sensor Buffer
	LOW	Low	Lightning Sensor



Example Sensor Status 1:

Temperature buffer status, temperature status, dewpoint buffer status, dewpoint status

High	Byte	Low Byte	
High	Low	High	Low
Temperatur e-Buffer	Temperatur e	Dew point- Buffer	Dew point
5	3	0	7

The example values above (for illustration only, the given combination will not occur in reality) are combined to the register value 0x5307 = 21255.

The single status are retrieved from the register as integer part of

Status 1 = register / 4096

Status 2 = (register / 256) AND 0x000F Status 3 = (register / 16) AND 0x000F Status 4 = register AND 0x000F

Following table shows the status coding:

Coding of Sensor Status:

Sensor State	Code
OK	0
UNGLTG_KANAL	1
E2_CAL_ERROR E2_CRC_KAL_ERR FLASH_CRC_ERR FLASH_WRITE_ERR FLASH_FLOAT_ERR	2
MEAS_ERROR, MEAS_UNABLE	3
INIT_ERROR	4
VALUE_OVERFLOW CHANNEL_OVERRANGE VALUE_UNDERFLOW CHANNEL_UNDERRANGE	5
BUSY	6
Other Sensor State	7





19.8 Communication: XDR Protocol

Note: XDR protocol is not available for WS100-UMB.

The XDR protocol allows to transmit a selected data set of the Smart Weather Sensor in a NMEA compatible format. The data telegram can be transmitted on request, or the Smart Weather Sensor can be set into auto transmit mode, where the data telegram will be triggered automatically at an selectable interval.

A set of ASCII configuration messages allows to apply some configuration settings without leaving the XDR protocol.

For configuration settings exceeding this command set use the UMB Config Tool. To change into the UMB protocol a UMB message must be addressed to the device within 5 seconds after power up or reset.




Figure 48: Sensor Configuration XDR

Protocol

Automatic telegram output

Air pressure mode

Output Interval NMEA NMEA talker device identifier

XDR protocol selected

activate continous mode (automatic result message transmission)

select absolute or relative air pressure for the measurement data message (seconds)

Interval for automatic result message transmission Select the Talker ID part of the NMEA telegram header

441

19.8.1 Basic Interface Properties

- Baud rate configurable from 1200bps to 57600bps, character format 8 bits, no parity, 1 stop bit (8N1).
- Unit ID equal to UMB device ID, but limited to 98. 99 is the broadcast ID
- Data output on request or continuously (configurable)
- Commands and messages use strictly ASCII text mode

19.8.2 Message Format for Commands and Responses

Byte		
0	1*1	Start Character
1,2	'01'	Destination ID
3,4	'00'	Source ID
5 n		Command Data (min. 2)
n+1, n+2	<cr><lf></lf></cr>	Termination Characters

The command data field always starts with the 2-character command identifier, optionally followed by a parameter, starting with '='.

Currently implemented commands are

•	P9	single measurement XDR format

PP start continuous measurement XDR format

PB single measurement PWSD format

PC start continuous measurement PWSD format

GW option: add MWD sentence (wind data) to XDR format

MI continuous measurement interval

J3 pressure mode (absolute air pressure / relative air pressure)

JS pressure sensor elevation

JW spot or average output of wind data

BR baud rateID unit ID

NH message prefix

If the device receives an invalid command (missing start or termination character, invalid ID, invalid structure etc.), it will not respond.

If a setting command contains an invalid parameter value, the device will not respond.

Setting commands must usually be preceded by the "Write Enable" command EW. This command does not generate a response, and may be, different from other commands, transmitted without message terminators (<CR><LF>). I.e. the write enable and the set command may be concatenated without terminators between the commands.

Example:

0100EW*0100J3=1<CR><LF>

and

0100EW<CR><LF>*0100J3=1<CR><LF>

are both valid command sequences for setting the pressure mode.

Setting commands not requiring a preceding write enable are marked in the command description.



19.8.3 Message Format for Measurement Data XDR

The message format for P9 / PP measurement data follows the definition for NMEA WI (weather instrument) XDR messages.

The message is field oriented, with variable length. The fields are separated by ','.

Message format:

\$hhhhh,P,x.xxxx,B,0,C,yy.y,C,0,H,zz.z,P,0<CR><LF>

\$hhhhh Message header, default \$WIXDR (WI : Talker identifier "weather

instruments", XDR: sentence identifier "transducer measurements") *)

separator

P transducer type "pressure"

, separator

x.xxxx air pressure value in Bar

separator

B unit: bars (= hPa)

, separator

0 Transducer ID, set to 0

, separator

C transducer type temperature

, separator

yy.y temperature in °C

, separator C unit: °C , separator

0 Transducer ID, set to 0

, separator

H transducer type humidity zz.z relative humidity in %

, separator P unit: % separator

0 Transducer ID, set to 0 <CR><LF> sentence terminator



^{*)} The message header can be modified. The UMB config tool allows modifying the talker ID bytes. The XDR setting command NH allows changing the complete message header. The leading '\$' is fixed and can not be modified.

19.8.4 Message Format for Measurement Data MWD

The P9 / PP measurement data transmission can be optionally extended by a MWD sentence containing wind data. The MWD sentence follows the definition for NMEA WI (weather instrument) messages.

This option can be activated or deactivated by the GW command.

The JW command selects between spot value and average value output of wind data.

The message is field oriented, with variable length. The fields are separated by ','.

Message format:

\$hhhhh, aaa.a,T,bbb.b,M,cc.c,N,dd.d,M <CR><LF>

\$hhhhh Message header, default \$WIMWD (WI : Talker identifier "weather

instruments", MWD: sentence identifier "wind measurements") *)

, separator

aaa.a wind direction in °"

separator

T identifier "True North"

separator

bbb.b wind direction in °

, separator

M identifier "Magnetic Nord"

separator

cc.c wind speed in knots

, separator N unit: kts . separator

dd.d wind speed in m/s

, separator M unit: m/s

<CR><LF> sentence terminator



^{*)} The message header can be modified. The MWD sentence uses the same talker ID as the XDR sentence, which can be modified by the UMB config tool or the XDR setting command NH. The leading '\$' is and the identifier MWD are fixed and can not be modified **) here wind direction "true" and wind direction "magnetic" are identical.

19.8.5 Message Format for Measurement 0R0

The 0R0 sentence format is a proprietary format similar to NMEA 0183 rules. The 0R0 sentence contains essential measurement values of the compact weather station and is designed for compatibility with existing installations.

The sentence is requested by the PB command for single measurement and PC for cyclic transmission.

If certain measurement values are not available for the subtype of the individual weather station the related value will be replaced by 999999. The same applies for measurement values with status not "OK".

The message is field oriented, with variable length. The fields are separated by ','.

Message Format:

0R0,Dm=aaaD,Sm=bb.bM,Ta=cc.cC,Ua=dd.dP,Pa=e.eeeeB,Rc=f.ffM, Pt=ggN<CR><LF>

0R0 message header

separator

Dm identifier wind direction

= separator

aaa wind direction in °

D unit °, separator

Sm identifier wind speed

= separator

bb.b wind speed in m/s

M unit m/s , separator

Ta identifier air temperature

= separator

cc.c air temperature in °C

C unit: °C , separator

Ua identifier relative humidity

= separator

dd.d relative humidity in %

P unit %, separator

Pa identifier air pressure

= separator

e.eeee air pressure in Bar

B unit Bar , separator

Rc identifier precipitation difference

= separator

ff.ff precipitation difference (related to last transmission) in mm

M unit mm , separator



Pt identifier precipitation type

= separator

gg precipitation code (00 no precip., 60 rain, 70 snow)

C unit: Code

<CR><LF> sentence terminator



19.8.6 Measurement Commands

Command Examples are shown for unit ID 01

19.8.6.1 Single Measurement XDR format

Command identifier: **P9**Parameter: none

Command example:

Command: *0100P9<CR><LF>

Response (wind data not activated):

\$WIXDR,P,cressure in bar>,B,0,C,<air temperature °C>,C,0,H,<rel. Humidity %>,P,0<CR><LF>

Response (wind data activated):

WIXDR,P,pressure in bar>,B,0,C,<air temperature °C>,C,0,H,<rel. Humidity %>,P,0<CR><LF>

WIMWD,< wind direction $^\circ>, T, <$ wind direction $^\circ>, M,<$ wind speed kts>, N ,< wind speed m/s>, M<CR><LF>

Serial numbers of pressure and T/H sensor are not available and set to 0.

19.8.6.2 Continuous Measurement XDR format

Command identifier: **PP**Parameter: none

Command example:

Command *0100PP<CR><LF>

After this command the device will start to transmit the result message as defined in for the single measurement automatically with the interval defined by the transmission interval command (see 19.8.7.1) or set by the UMB Config Tool.

The default interval is 60 seconds, minimum allowed interval is 10sec, maximum interval is 43200sec (=12h).

The continuous mode will be stored in the E2PROM of the device, so that after a reset the device will continue to transmit automatically.

The continuous mode is terminated by a Single Measurement Command (19.8.6.1, 19.8.6.3).

19.8.6.3 Single Measurement 0R0 Format

Command identifier: PB
Parameter: none

Command example:

Command *0100PB<CR><LF>

Response:

0R0,Dm=<wind dir.>D,Sm=<wind speed>M,Ta=<air temp.>C,Ua=<rel. humidity>P,Pa=<air press.>B,Rc=<precip. diff.>M, Pt=<precip. type>N<CR><LF>



19.8.6.4 Continuous Measurement 0R0 Format

Command identifier: PC
Parameter: none

Command example:

Command *0100PC<CR><LF>

After this command the device will start to transmit the result message as defined in for the single measurement automatically with the interval defined by the transmission interval command (see 19.8.7.1) or set by the UMB Config Tool.

The default interval is 60 seconds, minimum allowed interval is 10sec, maximum interval is 43200sec (=12h).

The continuous mode will be stored in the E2PROM of the device, so that after a reset the device will continue to transmit automatically.

The continuous mode is terminated by a Single Measurement Command (19.8.6.1, 19.8.6.3).



19.8.7 Configuration Commands

Command Examples are shown for unit ID 01

19.8.7.1 Transmission Interval for Continuous Measurement

Command identifier: MI

Parameter: interval in seconds (min. 10, max. 43200, default 60)

Request command example: Command: *0100MI<CR><LF> Response: *0001MI=60<CR><LF>

The command requests the current setting of the result transmission interval

Setting command example (to be preceded by the write enable command)

Command: *0100MI=60<CR><LF> Response: *0001MI=60<CR><LF>

The command sets the interval for automatic measurement result transmission (19.8.6.2) in

seconds.

19.8.7.2 Option Append Wind Data (MWD) to XDR Sentence

Command identifier: **GW**

Parameter: 0 = wind data off, 1 = wind data on

Request command example:
Command: *0100GW<CR><LF>
Response: *0001GW=0<CR><LF>

The command requests the current setting of the wind data option.

Setting command example (to be preceded by the write enable command)

Command: *0100GW=1<CR><LF> Response: *0001GW=1<CR><LF> The command sets the wind data option.

4

Note: if an automatic XDR transmission is active it must be restarted to make the modification effective.

19.8.7.3 Select Spot Values or Average Values of Wind Data

Command identifier: JW

Parameter: 0 = wind data spot values, 1 = wind data average values

Request command example: Command: *0100JW<CR><LF> Response: *0001JW=1<CR><LF>

The command requests the current setting of the wind data average setting.

Setting command example (to be preceded by the write enable command)

Command: *0100JW=0<CR><LF> Response: *0001JW=0<CR><LF>

The command sets the wind data average or spot transmission.



19.8.7.4 Pressure Mode Selection Command

Command identifier: J3

Parameter: 0 = absolute pressure, 1 = relative pressure

Selects, if the absolute or relative (sea level) air pressure is transmitted in the measurement value message (0). For correct function of the conversion to relative (sea level) pressure it is essential, that the sensor elevation has been set correctly (JS command (19.8.7.5) or UMB Config Tool)

Request command example:

Command: *0100J3<CR><LF>
Response: *0001J3=1<CR><>LF>
Requests the current pressure mode

Setting command example (to be preceded by the write enable command):

Command: *0100J3=0<CR><LF> Response: *0100J3=0<CR><LF>

Sets the pressure mode:
0 absolute air pressure
1 relative air pressure

19.8.7.5 Sensor Elevation Setting Command

Command identifier: JS

Parameter: sensor elevation (above sea level) in m

Remark: the sensor elevation may be entered as integer value or as fixed point value, the sensor will round the value for internal storage to integer (full meters).

Request command example:
Command: *0100JS<CR><LF>
Response: *0001JS=353<CR><LF>

Requests the current elevation setting

Setting command example (to be preceded by the write enable command):

Command: *0100JS=82<CR><LF> or *0100JS=82.3<CR><LF>

Response: *0001JS=82<CR><LF>

Sets the elevation of the sensor above sea level in m (range -100m to 5000m)



19.8.7.6 NMEA Message Prefix Setting Command

Command identifier: NH

Parameter: complete NMEA Header ('\$' + max. 6 char)



Note: The parameter must always start with the '\$' character. This character is nevertheless fixed and will not be modified.

Request command example: Command: *0100NH<CR><LF>

Response: *0001NH=\$WIXDR<CR><LF>

Requests the current header of the NMEA measurement value sentence

Setting command example (to be preceded by the write enable command):

Command: *0100NH=\$WIXDR<CR><LF>
Response: *0001NH=\$WIXDR<CR><LF>

Sets the prefix of the NMEA measurement value

19.8.7.7 Baud Rate Setting Command

Command identifier: BR

Parameter: Baudrate (1200, 2400, 4800, 9600, 19200, 28800, 38400,

57600)

-

Note: this command only provides the set mode and is only valid with the broadcast destination ID 99.

After execution of the command the Smart Weather Sensor will perform a reset and then start with the new baudrate.

The command does not require to be preceded by the write enable command.

Setting command example:

Command: *9900BR=9600<CR><LF> Response: *9900BR=9600<CR><LF>

Sets the baud rate

19.8.7.8 Unit ID Setting Command

Command identifier: ID
Parameter: none



Note: This command does not accept a separate parameter, but uses the source ID of the address fields as input. The ID of the device is set to (source ID + 1). Source ID values 0 ... 97 are allowed.

The command only provides the set mode and is only valid with the broadcast destination ID 99.

After execution of the command the Smart Weather Sensor will perform a reset and then start with the new unit ID.

The command does not require to be preceded by the write enable command.

Setting command example:

Command: *9900ID<CR><LF>
Response: *9901ID<CR><LF>
Sets the unit ID to source ID + 1



19.8.7.9 Write Enable Command

Command identifier: **EW**Parameter: none

This command is intended to protect the device from accidental setting modifications and must precede most of the setting commands.

The command is not available as request command and does not generate a response.

This command is valid with and without termination characters.

Command example:

*0100EW

or

*0100EW<CR><LF>



19.9 (WS100-UMB only) Communication: UMB-ASCII 2.0 Protokoll

UMB-ASCII 2.0 provides query of measurement values and sensor configuration in a human readable format. Details and general commands can be found in the UMB-ASCII 2.0 manual (Manual_Lufft_UMB-ASCII_2_0_Version_1_1_en.pdf).

The separators used for the output strings can be adjusted to the requirements of a logger (see Chapter 0)

In addition to the general configuration commands described in the UMB-ASCII 2.0 manual device specific commands for configuration work have been defined for the WS100-UMB (see Chapter 19.9.2)

In UMB-ASCII 2.0 mode defined sets of measurement values can be transmitted automatically at adjustable intervals without further query commands. WS100-UMB provides four standard sets:

- S1: General precipitation values, metric units
- S5: General precipitation values, imperial units
- S10: Service channels (drop distribution, air temperature), metric units
- S15: Service channels (drop distribution, air temperature), imperial units

19.9.1 Format of the Standard Sets

The following list uses UMB-ASCII 2.0 factory setting separators.

Byte	Wert	Beschreibung
0	<stx></stx>	02 Hex
1-4	<add></add>	Device address hex, e.g. 7001 for WSx-UMB with device ID 1
5	:	3A hex
6-7	<nr></nr>	Request number hex, always 00 for auto transmission
8	:	3A hex
9-10	SS	<cmd>, standard set</cmd>
11	;	3B hex
12	<set></set>	standard set number
	=	3D hex
	<telno></telno>	Number of auto transmitted messages from start
	;	3B hex
	<serno></serno>	Lufft serial number
	;	3B vex
		measurement value 1
	;	3B hex
		measurement value 2
	;	3B hex
	;	3B hex
		measurement value n
	;	3B hex
	<status></status>	device status, hex
	:	3A hex
	<status></status>	command status, hex
	:	3A hex
	<checksum></checksum>	check sum, hex
	<cr></cr>	0D hex
	<lf></lf>	0A hex
	<eot></eot>	04 hex

Depending on the measurement value type the output is formatted as integer or fixed point representation. Measurement value lists of the standard sets follow:



19.9.1.1 Standard Set S1 Precipitation Data Metric

Measurement Value	Channel	Unit	Format
Precipitation Type	700	-	**
Precipitation quantity abs.	620	mm	** **
Precipitation quantity diff.	625	mm	** **
Precipitation intensity	820	mm/h	** **
Precipitation intensity	825	mm/min	** ***
Heating temperature	113	°C	** *

19.9.1.2 Standard Set S1 Precipitation Data Imperial Units

Measurement Value	Channel	Unit	Format
Precipitation Type	700	-	**
Precipitation quantity abs.	640	inch	** ****
Precipitation quantity diff.	645	inch	** ****
Precipitation intensity	820	inch /h	** ****
Precipitation intensity	825	inch /min	** ****
Heating temperature	113	°F	** *

19.9.1.3 Standard Set S10 Service Channels metric

Measurement Value	Channel	Unit	Format
Total precip. Particles	4600	Events	**
Total drops	4601	Events	**
Drizzle particles	4602	Events	**
Snow particles	4603	Events	**
Hail particles	4604	Events	**
Drop class 0	4620	Events	**
Drop class 1	4621	Events	**
Drop class 2	4622	Events	**
Drop class 3	4623	Events	**
Drop class 4	4624	Events	**
Drop class 5	4625	Events	**
Drop class 6	4626	Events	**
Drop class 7	4627	Events	**
Drop class 8	4628	Events	**
Drop class 9	4629	Events	**
Drop class 10	4630	Events	**
Drop class 11	4631	Events	**
Air temperature curr.	4100	°C	** *
Air temperature min.	4120	°C	** *
Air temperature max.	4140	°C	** *
Air temperature avg.	4160	°C	** *
(Air tomporature without radi	-4:l-:-l	-111	

(Air temperature without radiation shield!)



19.9.1.4 Standard Set S15 Service Channels Imperial Units

Measurement Value	Channel	Unit	Format
Total precip. Particles	4600	Events	**
Total drops	4601	Events	**
Drizzle particles	4602	Events	**
Snow particles	4603	Events	**
Hail particles	4604	Events	**
Drop class 0	4620	Events	**
Drop class 1	4621	Events	**
Drop class 2	4622	Events	**
Drop class 3	4623	Events	**
Drop class 4	4624	Events	**
Drop class 5	4625	Events	**
Drop class 6	4626	Events	**
Drop class 7	4627	Events	**
Drop class 8	4628	Events	**
Drop class 9	4629	Events	**
Drop class 10	4630	Events	**
Drop class 11	4631	Events	**
Air temperature curr.	4105	°F	** *
Air temperature min.	4125	°F	** *
Air temperature max.	4145	°F	** *
Air temperature avg.	4165	°F	** *

(Air temperature without radiation shield!)

19.9.2 Device Specific Configuration Commands

Following configuration commands have been defined for WS100-UMB:

Command	Function
TMI	Averaging Intervall Temperature
EVP	Evaporation Parameter
RCF	Rain Correction Factor
SCF	Snow Correction Factor
PTT	Follow Up Time for Precipitation Type
HTM	Heating Operation Mode
HIT	Temperature Threshold for Heating Mode 1
HST	Heating Setpoint Temperature
MIT	Follow Up Time for Heating Eco Mode 1
POM	Radar Operation Mode
RGR	Resolution for Rain Gauge Simulation
DHE	Drizzle / Hail Evaluation
RSC	Clear Accumulated Precipitation and Reset

For details regarding the listed settings please refer to chapters 10.2.7, 10.2.13 and 10.5.



Format of configuration commands:

Byte	Value	Description
0-3	<add></add>	Device Address Hex, e.g. 7001 for WSx-UMB with device ID 1
4	:	3A Hex
5-6	<nr></nr>	Request No. Hex, may be used for identification of the response
7	:	3A Hex
8-10	<xxx></xxx>	Command Code
11	=	3D Hex (for setting of parameters only)
12	<value></value>	Value of Parameter (for setting of parameters only)
	<cr></cr>	0D Hex
	<lf></lf>	0A Hex

Format of response

Byte	Value	Description
0	<stx></stx>	02 Hex
1-4	<add></add>	Device Adress Hex, e.g. 7001 for WSx-UMB with device ID 1
5	:	3A Hex
6-7	<nr></nr>	Request number hex, always 00 for auto transmission
8	:	3A Hex
9-10	<xxx></xxx>	Command Code
11	=	3D Hex
12	<value></value>	Value of Parameter
	:	3A Hex
	<status></status>	Command Status, Hex
	:	3A Hex
	<checksum></checksum>	Checksum, Hex
	<cr></cr>	0D Hex
	<lf></lf>	0A Hex
	<eot></eot>	04 Hex

Example: Request of averaging interval time from device with ID 1

7001:00:TMI<CR><LF>

Response:

<STX>7001:00:TMI=10:00:<CheckSum><CR><LF><EOT>

Example: Setting of averaging interval time to 5sec

7001:00:TMI=5<CR><LF>

Response:

<STX>7001:00:TMI=5:00:<CheckSum><CR><LF><EOT>



19.9.2.1 Command Averaging Interval Temperature Measurement

Command Code: TMI Request: TMI

Adjust: TMI=<value> Value Range: 1 ... 10

19.9.2.2 Command Evaporation Parameter

Command Code: EVP Request: EVP

Adjust: EVP=<value>
Value Range: 0.0 ... **0.24** ...100.0

19.9.2.3 Command Rain Correction Factor

Command Code: RCF Request: RCF

Adjust: RCF=<value> Value Range: 0.2 ... **1.0** ...5.0

19.9.2.4 Command Snow Correction Factor

Command Code: SCF Request: SCF

Adjust: SCF=<value> Value Range: 0.2 ... **1.0** ...5.0

19.9.2.5 Command Precipitation Type Follow Up Time

Command Code: PTT Request: PTT

Adjust: PTT=<value>

Value Range: 0 ... **120** ... 3600 [sec]

19.9.2.6 Command Heating Operation Mode

Command Code: HTM Request: HTM

Adjust: HTM=<value>

Value Range: 0 ...3

<value></value>	Operation Mode
0	Automatic
1	Mode 1
2	Off
3	Eco Mode 1

See Chapter 10.5 for heating operation modes



19.9.2.7 Temperature Threshold for Heating Mode 1

Command Code: HIT Request: HIT

Adjust: HIT=<value>

Value Range: -10.0 ... **5.0** ... 20.0 [°C]

19.9.2.8 Heating Setpoint Temperature

Command Code: HST Request: HST

Adjust: HST=<value>

Value Range: -10.0 ... **15.0** ...60.0 [°C]

19.9.2.9 Follow Up Time for Heating Eco Mode 1

Command Code: MIT Request: MIT

Adjust: MIT=<value>

Value Range: 1 ... 30 ...120 [min]

19.9.2.10 Radar Operation Mode

Command Code: POM Request: POM

Adjust: POM=<value>

Value Range: **0** ... 1

<value></value>	Operation Mode
0	Continuous
1	Power Saving Mode 1

See Chapter 10.4.1

19.9.2.11 Resolution Rain Gauge Simulation

Command Code: RGR Request: RGR

Adjust: RGR=<value>

Value Range: 0 ... 4

<value></value>	Operation Mode
0	1.0mm
1	0.5mm
2	0.2mm
3	0.1mm
4	0.01mm

19.9.2.12 Drizzle / Hail Evaluation

Command Code: DHE Request: DHE

Adjust: DHE=<value> Value Range: 0, 16, 32, **48**

<value></value>	Function
0	Drizzle/hail inactive
16	Drizzle active
32	Hail active
48	Drizzle + hail active

19.9.2.13 Clear Accumulated Precipitation Amount

Command Code: RSC

Request: -

Adjust: RSC

Value Range: -

This command sets the accumulated precipitation amount to 0.0 and then initiates a device reset. The device will not respond for a few seconds during the reset.



20 List of Figures

Figure 1: Sensor Technology	15
Figure 2: Fastening to the Mast	26
Figure 3: North Markings	27
Figure 4: Alignment to North	27
Figure 5: Installation Sketch	29
Figure 6: Connections	30
Figure 7: Connection to ISOCON-UMB	32
Figure 8: Select a Workspace	35
Figure 9: Sensor Selection	35
Figure 10: General Settings	36
Figure 11: Temperature, Humidity and Fan Settings	36
Figure 12: Pressure Settings	37
Figure 13: Wind Settings	37
Figure 14: Precipitation Sensor Settings (Radar)	38
Figure 15: Precipitation Sensor Settings (Rain Gauge)	38
Figure 16: Global Radiation Settings	39
Figure 17: Lightning Sensor Settings	39
Figure 18: Energy Management Settings	39
Figure 19: Reset Precipitation Quantity	40
Figure 20: Select operation mode "Simulated Rain Gauge"	
Figure 21: Configure the resolution of the simulated rain gauge	
Figure 22: WMO station settings	41
Figure 23: Configure UMB-ASCII 2.0 protocol properties	42
Figure 24 Measurement Polling Channels	
Figure 25 Example of Measurement Polling	
Figure 26: Operating Modes for Equipment Heating	
Figure 27: WS601-UMB with removed funnel	
Figure 28: WS100-UMB	56
Figure 29: WS200-UMB	56
Figure 30: WS200-UMB	57
Figure 31: WS301-UMB	58
Figure 32: WS310-UMB	59
Figure 33: WS400-UMB	60
Figure 34: WS401-UMB	61
Figure 35: WS500-UMB	62
Figure 36: WS501-UMB	63
Figure 37: WS510-UMB	64
Figure 38: WS600-UMB	65
Figure 39: WS601-UMB	66
Figure 40: WS700-UMB, WS800-UMB	67
Figure 41: Setting type of external sensor	75
Figure 42: Example WS501-UMB and WTB100	76
Figure 43: Sensor Configuration SDI-12	
Figure 44: Sensor Configuration SDI-12 Units	90
Figure. 45: Connecting to a logger with integrated power supply	91
Figure. 46: Connecting to a logger and a separate power supply up to device version 41	91
Figure. 47: Connecting to a logger and a separate power supply device version 42 and newer, all WS100	91
Figure 48: Sensor Configuration XDR	148



21 Index

Α		
	Accessories	11
	Accuracy	53
	Air Density13,	18
	Air Pressure13,	17
	Air Temperature	12
	Altitude	37
	ASCII-Protokoli	82
В		
	Binary Protocol	79
С		
·	Certificate of Conformity	65
	Channel List	
	Channel List per TLS2002	
	Class ID	
	Commissioning	
	Communication	
	Communication	
	Communication	
	Compass	
_	Connections	3(
D		
	Data Request	
	Declination	
	Delivery Status	
	Designated Use	
	Device ID79,	
	Dimensions	
	Disposal	
	Distance between objects	
	Drawings	56
Ε		
	Energy Management	39
	Enthalpy13,	18
	Error Codes81,	84
	External Rain Gauge14,	73
	External Sensors	30
	External Temperature Sensor13,	73
F		
	Factory Settings	35
	Fan	
	Fault Description	
	Firmware Update	
G	Timuro opuaio	
J	Clohal Radiation	_
	Global Radiation13,	24
Н		
	Heating	
	Humidity12,	17
I		
	Incorrect Use	6

	Installation	26
	Installation Location	28
	Interface	31, 52
	ISOCON-UMB	32
L		
	Local Altitude	37
М		
IVI		40
	Maintenance	
	Measurement Output	
	Measurement Polling (UMB-Config-Tool)	
	Measurement Values	
	Measuring Range	
	Modbus	133
N		
	North Alignment	27
0		
	Operating Conditions	52
	Operating Modes	45
	Order Numbers	9
Р		
•	Power Saving Mode	<i>1</i> 5 81
	Power Supply Unit	
	Precipitation	
	Protection type	
_	··	32
R		
	Relative Air Pressure	
	Reset Precipitation Quantity	40
S		
	Safety Instructions	6
	Scope of Delivery	8
	SDI-12 Mode	88
	Sensor Technology	15
	Storage Conditions	52
	Supply Voltage	30, 31
	Symbols Used	6
Т		
	Technical Data	51
	Technical Support	
	Temperature	
	Terminal-Mode	
U		
U	LIMP Confin Tool	25 44
	UMB-Config-Tool	35, 44
W		
	Warranty	-
	Weight	
	Wet Bulb Temperature	
	WetBulb Temperature	13
	Wind	13, 19
X		
	XDR Protocol	146



Blank page for printing purposes.



Blank page for printing purposes.



Blank page for printing purposes.



G. LUFFT Mess- und Regeltechnik GmbH

Lufft Germany:
Fellbach Headquarter:
Address:
Gutenbergstrasse 20
D-70736 Fellbach
Postal Address:
P.O. Box 4252
70719 Fellbach
GERMANY

Tel.: +49 (0)711 51822-0 Fax: +49 (0)711 51822-41

www.lufft.com info@lufft.de

Berlin Office:

G. Lufft GmbH Berlin

Carl-Scheele-Strasse 16 12489 Berlin

GERMANY
Phone: +49 711 51822-831n · passion pour la précision · pasión por la precisión · passione per la precision · +49 711 51822-944

Lufft North America: Lufft USA, Inc. 1110 Eugenia Pl Unit B Carpinteria, CA 93013 USA Tel.: +1 888 519 8443 Fax: +1 805-220-6409 sales@lufftusainc.com www.lufft.com

Lufft China:

Shanghai Office:

Shanghai Office:
Lufft Shanghai Measurement and
Control Technology Co., Ltd.
Room 507, Building No. 3
Yinshi Science and Business Park
No. 2568 Gudai Road,
Minhang District
Shanghai 201100
CHINA
Tel.: +86 21 5437 0890
Fax: +86 21 5437 0910
china@lufft.com
www.lufft.cn

